

LEAD IN DRINKING WATER SAMPLING

Of

Pittsburgh Public Schools

Sample Dates: April 12 through December 7, 2022

Prepared for:

Pittsburgh Public Schools
Facilities
1305 Muriel Street
Pittsburgh, PA 15203

Prepared By:



207 Pine Creek Road
Wexford, PA 15090

TABLE OF CONTENTS

1. INTRODUCTION	1
2. SAMPLING METHODOLOGY	1
3. LEAD IN DRINKING WATER RESULTS AND DISCUSSION	2
4. RECOMMENDATIONS	11
REPORT DISCLAIMER:	12
APPENDIX A DRINKING WATER RESULTS TABLES.....	13
APPENDIX B LABORATORY RESULTS	14
APPENDIX C FACILITY MAPS	15

1. INTRODUCTION

AGX, Inc. was retained by Pittsburgh Public School District to test for the presence of lead in drinking water. Fixture verification and sampling was conducted at thirty-nine (39) facility buildings, field houses, and City Connection Program locations from April 12 through December 7, 2022. The objective of the testing was to screen the drinking water and cooking use fixtures and faucets for lead concentrations.

2. SAMPLING METHODOLOGY

Sample collection, delivery, and analysis were conducted according to the EPA's "3Ts for Reducing Lead in Drinking Water in Schools and Child Care Facilities: A Training, Testing, and Taking Action Approach, October 2018. As per 3Ts, the EPA encourages schools to "prioritize remediation efforts based on lead sample results and to use the steps in the toolkit to pinpoint potential lead sources to reduce lead levels to the lowest possible concentration".

In accordance with the Pennsylvania Public School Code of 1949, as amended June 22, 2018, Section 742, the lead level of drinking water in schools should not exceed the concentrations established by the United States Environmental Protection Agency's (EPA) National Primary Drinking Water Regulations, currently 15 parts per billion (ppb). The testing procedures and recommended lead concentration were designed to pinpoint specific drinking water sources that require remediation. The sampling protocol maximizes the likelihood that the highest concentration of lead is found in the first 250 mL sample.

The action level for lead is not a health based standard and is based upon EPA's evaluation of available data.

Cold water drinking and cooking use fixtures were tested for lead concentrations. Drinking water and cooking fixtures were defined as classroom faucets, home economic faucets, ice machines, kitchen faucets, cafeteria faucets, nurse's office sink faucets, office sink faucets, teacher's lounge sinks, water fountains and miscellaneous sinks found in classrooms and offices. All samples were collected in 250 mL plastic containers that were prepackaged by the analytical laboratory. At each sample location, a first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight (8) hours but less than eighteen (18) hours. A second draw sample was collected after the water in the system was discharged for thirty (30) seconds. All samples were analyzed by RJ Lee, Inc., 350 Hochberg Road, Monroeville, PA 15146, an independent PA certified laboratory.

3. LEAD IN DRINKING WATER RESULTS AND DISCUSSION

Drinking water was tested for lead in thirty-nine (39) schools, field houses, facility buildings, and City Connection Program locations. A total of two thousand four hundred and one (2,401) samples were collected from one thousand one hundred and sixty-five (1,165) designated drinking water and cooking use fixtures and faucets, service lines, and water mains. Analytical results were received by AGX and reviewed in relation to the EPA “3Ts for Reducing Lead in Drinking Water in Schools and Child Care Facilities: A Training, Testing, and Taking Action Approach, October 2018 and in accordance with the Pennsylvania Public School Code of 1949, as amended June 22, 2018, Section 742 (Act 39). Based on Act 39, which recognizes the United States Environmental Protection Agency’s (EPA) National Primary Drinking Water Regulations, any lead concentrations at or above 15 parts per billion (ppb) were considered to be elevated.

The results of the sampling showed lead concentrations below 15 parts per billion (ppb) in one thousand one hundred and thirty-one (1,131) of the one thousand one hundred and sixty-five (1,165) tested fixtures, or 3%. The low percentage and isolated fixtures with lead concentrations at or above 15 ppb indicated that there were no source water or facility wide lead concerns. Based on testing and observation it is presumed that sources of elevated lead concentrations could be attributed to lack of routine use, fixtures not routinely cleaned, and / or older outdated fixtures. Corrective actions, which include shutting off the fixture, posting signage, removing or replacing the aerator, replacing with new sink assembly, and / or removing the sink at any location that exceeded the recommended action level of 15 parts per billion (ppb) has been recommended. Following remediation of fixtures that exceeded the recommended lead concentration, verification sampling was conducted to ensure the lead concentrations in drinking water was reduced below 15 parts per billion (ppb).

Arlington:

At Pittsburgh Arlington PreK-8, a total of thirty-six (36) samples were collected from seventeen (17) drinking water and cooking use fixtures and faucets on June 29, 2022. No samples collected were above the recommended action level of 15 ppb.

Banksville:

At Pittsburgh Banksville K-5 a total of forty-eight (48) samples were collected from twenty-three (23) drinking water and cooking use fixtures and faucets on May 24, 2022. No samples collected were above the recommended action level of 15 ppb.

Brookline:

At Pittsburgh Brookline PreK-8 a total of ninety-four (94) samples were collected from forty-five (45) drinking water and cooking use fixtures and faucets on June 22 and September 2, 2022. Two (2) fixtures (BRO-01-CF-78 and BRO-02-CF-102) tested were above the recommended action level of 15 ppb.

Carrick Field House:

At Pittsburgh Carrick Field House a total of seven (7) samples were collected from three (3) drinking water and cooking use fixtures and faucets on August 19 and September 13, 2022. No samples collected were above the recommended action level of 15 ppb.

Carrick:

At Pittsburgh Carrick High School a total of one hundred and sixty-eight (168) samples were collected from eighty-five (85) drinking water and cooking use fixtures and faucets on May 14, September 13, and September 20, 2022. One (1) fixture (CAR-02-NF-171) tested was above the recommended action level of 15 ppb.

Central Operations:

At Pittsburgh Central Operations a total of fifty-one (51) samples were collected from twenty-five (25) drinking water and cooking use fixtures and faucets on July 13 and October 7, 2022. No samples collected were above the recommended action level of 15 ppb.

Chartiers:

At Pittsburgh Chartiers Early Childhood Center a total of sixty-two (62) samples were collected from thirty (30) drinking water and cooking use fixtures and faucets on April 19, 2022. No samples collected were above the recommended action level of 15 ppb.

City Connections Program (City East):

At City Connections Program (City East) a total of four (4) samples were collected from one (1) drinking water / cooking use fixture / faucet on September 16, 2022. No samples collected were above the recommended action level of 15 ppb.

City Connections Program (City North):

At City Connections Program (City North), zero (0) samples were collected. Lead in drinking water sampling was conducted in the past and elevated concentrations were identified. At that time all sinks were taken out of service, as far as potential drinking sources, and hand wash only signage was posted throughout the facility.

City Connections Program (City West):

At City Connections Program (City West) a total of six (6) samples were collected from two (2) drinking water and cooking use fixtures and faucets on June 2, 2022. No samples collected were above the recommended action level of 15 ppb.

Clayton:

At Pittsburgh Clayton Academy a total of forty-eight (48) samples were collected from twenty-two (22) drinking water and cooking use fixtures and faucets on August 23, 2022. No samples collected were above the recommended action level of 15 ppb.

Crescent:

At Pittsburgh Crescent Early Childhood Center a total of eighty (82) samples were collected from forty (40) drinking water and cooking use fixtures and faucets on April 13, 2022. One (1) fixture (CRE-03-CF-58) tested was above the recommended action level of 15 ppb.

Cupples Stadium:

At Pittsburgh Cupples Stadium, a total of thirty-seven (37) samples were collected from eighteen (18) drinking water and cooking use fixtures and faucets on July 7, 2022. No samples collected were above the recommended action level of 15 ppb.

Faison:

At Pittsburgh Faison K-5 a total of eighty (82) samples were collected from forty (40) drinking water and cooking use fixtures and faucets on August 11, 2022. No samples collected were above the recommended action level of 15 ppb.

Greenfield:

At Pittsburgh Greenfield PreK-8 a total of fifty-six (56) samples were collected from twenty-seven (27) drinking water and cooking use fixtures and faucets on May 5, 2022. One (1) fixture (GRE-01-MS-37) tested was above the recommended action level of 15 ppb.

King:

At Pittsburgh King PreK-8 a total of one hundred and fifty-eight (158) samples were collected from seventy-eight (78) drinking water and cooking use fixtures and faucets on August 27 and December 7, 2022. Seventeen (17) fixtures (KIN-01-CF-07, KIN-01-CF-30, KIN-01-MS-33, KIN-02-CF-80, KIN-02-CF-84, KIN-03-CF-101, KIN-03-CF-105, KIN-03-CF-106, KIN-03-TF-127, KIN-03-CF-135, KIN-03-CF-136, KIN-03-CF-137, KIN-03-CF-138, KIN-03-CF-144, KIN-03-CF-145, KIN-03-CF-161, and KIN-01-MS-171) collected were above the recommended action level of 15 ppb.

Langley:

At Pittsburgh Langley K-8, a total of one hundred and fifty-seven (157) samples were collected from seventy-eight (78) drinking water and cooking use fixtures and faucets on August 18 and December 1, 2022. No samples collected were above the recommended action level of 15 ppb.

Lincoln:

At Pittsburgh Lincoln PreK-5 a total of fifty (50) samples were collected from twenty-four (24) drinking water and cooking use fixtures and faucets on May 17, 2022. No samples collected were above the recommended action level of 15 ppb.

Linden:

At Pittsburgh Linden K-5 a total of forty-six (46) samples were collected from twenty-two (22) drinking water and cooking use fixtures and faucets on June 23 and September 8, 2022. One (1) fixture (LND-01-NF-27) tested was above the recommended action level of 15 ppb.

Manchester:

At Pittsburgh Manchester PreK-8 a total of eighty (80) samples were collected from thirty-nine (39) drinking water and cooking use fixtures and faucets on August 10 and October 7, 2022. One (1) fixture (MAN-02-CF-49) tested was above the recommended action level of 15 ppb.

Miller:

At Pittsburgh Miller PreK-5 a total of sixty-four (64) samples were collected from thirty-one (31) drinking water and cooking use fixtures and faucets on April 27, 2022. One (1) fixture (MIL-01-CF-36) tested was above the recommended action level of 15 ppb.

Milliones:

At Pittsburgh Milliones 6-12 a total of sixty-six (66) samples were collected from thirty-two (32) drinking water and cooking use fixtures and faucets on May 28 and November 10, 2022. No samples collected were above the recommended action level of 15 ppb.

Montessori:

At Pittsburgh Montessori PreK-5 a total of sixty-eight (68) samples were collected from thirty-two (32) drinking water and cooking use fixtures and faucets on April 20 and April 29, 2022. No samples collected were above the recommended action level of 15 ppb.

Morrow Intermediate:

At Pittsburgh Morrow Intermediate 5-8 a total of sixty-three (63) samples were collected from thirty-one (31) drinking water and cooking use fixtures and faucets on July 6, 2022. No samples collected were above the recommended action level of 15 ppb.

Morrow:

At Pittsburgh Morrow PreK-4 a total of seventy-two (72) samples were collected from thirty-five (35) drinking water and cooking use fixtures and faucets on April 26 and May 18, 2022. Two (2) fixtures (MOR-01-CF-29 and MOR-02-CF-47) tested were above the recommended action level of 15 ppb.

Online Academy:

At Pittsburgh Online Academy a total of twenty-four (24) samples were collected from eleven (11) drinking water and cooking use fixtures and faucets on July 12, 2022. Two (2) fixtures (SOU-02-WC-46 and SOU-02-CF-47) tested were above recommended action level of 15 ppb.

Perry Field House:

At Pittsburgh Perry Field House a total of twelve (12) samples were collected from five (5) drinking water and cooking use fixtures and faucets on June 10, 2022. No samples collected were above the recommended action level of 15 ppb.

Perry:

At Pittsburgh Perry High School a total of one hundred and nine (109) samples were collected from fifty-three (53) drinking water and cooking use fixtures and faucets on June 11 and August 2, 2022. No samples collected were above the recommended action level of 15 ppb.

Pioneer:

At Pittsburgh Pioneer a total of eighteen (18) samples were collected from eight (8) drinking water and cooking use fixtures and faucets on June 7, 2022. No samples collected were above the recommended action level of 15 ppb.

Roosevelt:

At Pittsburgh Roosevelt 2-5 a total of thirty-four (34) samples were collected from sixteen (16) drinking water and cooking use fixtures and faucets on June 1, 2022. No samples collected were above the recommended action level of 15 ppb.

Schenley Field House:

At Pittsburgh Schenley Field House a total of fifteen (15) samples were collected from seven (7) drinking water and cooking use fixtures and faucets on May 28 and October 14, 2022. One (1) fixture (SFH-GF-FF-13) collected was above the recommended action level of 15 ppb.

Science and Technology Academy:

At Pittsburgh Science and Technology Academy 6-12 a total of sixty-four (64) samples were collected from thirty-one (31) drinking water and cooking use fixtures and faucets on June 24 and September 29, 2022. No samples collected were above the recommended action level of 15 ppb.

Service Center:

At Pittsburgh Service Center, a total of twenty-nine (29) samples were collected from fourteen (14) drinking water and cooking use fixtures and faucets on July 14, 2022. No samples collected were above the recommended action level of 15 ppb.

South Brook:

At Pittsburgh South Brook 6-8 a total of fifty (50) samples were collected from twenty-four (24) drinking water and cooking use fixtures and faucets on June 7, 2022. No samples collected were above the recommended action level of 15 ppb.

Sterrett:

At Pittsburgh Sterrett 6-8 a total of fifty-seven (57) samples were collected from twenty-eight (28) drinking water and cooking use fixtures and faucets on June August 17, 2022. One (1) fixture (STE-02-CF-85) tested was above the recommended action level of 15 ppb.

Sunnyside:

At Pittsburgh Sunnyside PreK-8 a total of eighty-eight (88) samples were collected from forty-three (43) drinking water and cooking use fixtures and faucets on May 10 and September 16, 2022. No samples collected were above the recommended action level of 15 ppb.

Weil:

At Pittsburgh Weil PreK-5 a total of sixty-six (66) samples were collected from thirty-two (32) drinking water and cooking use fixtures and faucets on May 4, 2022. Two (2) fixtures (WEI-02-CF-44 and WEI-02-CF-46) tested were above the recommended action level of 15 ppb.

West Liberty:

At Pittsburgh West Liberty K-5 a total of fifty-six (56) samples were collected from twenty-seven (27) drinking water and cooking use fixtures and faucets on June 28 and September 13, 2022. No samples collected were above the recommended action level of 15 ppb.

Westinghouse Academy:

At Pittsburgh Westinghouse Academy 6-12 a total of one hundred and sixty-four (164) samples were collected from eighty-two (82) drinking water and cooking use fixtures and faucets on April 14, May 11, and November 4, 2022. One (1) fixture (WES-GF-NF-118) tested was above the recommended action level of 15 ppb.

Westinghouse Field House:

At Pittsburgh Westinghouse Field House a total of ten (10) samples were collected from four (4) drinking water and cooking use fixtures and faucets on April 14, 2022. No samples collected were above the recommended action level of 15 ppb.

Table 1: Facility drinking water and cooking use fixtures and faucets along with total number of drinking water samples obtained.

School/Building	Date(s) Sampled	Total # of Fixtures	# Samples Collected
Pittsburgh Arlington PreK-8 (Phillip Murray)	6/29/2022	17	36
Pittsburgh Banksville K-5	5/24/2022	23	48
Pittsburgh Brookline PreK-8	6/22/2022 and 9/2/2022	45	94
Pittsburgh Carrick Field House	8/19/2022 and 9/13/2022	3	7
Pittsburgh Carrick High School	5/14/2022, 9/13/2022, and 9/20/2022	85	168
Pittsburgh Central Operations	7/13/2022 and 10/7/2022	25	51
Pittsburgh Chartiers ECC	4/19/2022	30	62
City Connections Program (City East)	9/16/2022	1	4
City Connections Program (City West)	6/2/2022	2	6
Pittsburgh Clayton Academy	8/23/2022	22	48
Pittsburgh Crescent ECC	4/13/2022	40	82
Pittsburgh Cupples Stadium	7/7/2022	18	37
Pittsburgh Faison K-5	8/11/2022	40	82
Pittsburgh Greenfield PreK-8	5/5/2022	27	56
Pittsburgh King PreK-8	8/27/2022 and 12/7/2022	78	158
Pittsburgh Langley K-8	8/18/2022 and 12/1/2022	78	157
Pittsburgh Lincoln K-5	5/17/2022	24	50
Pittsburgh Linden K-5	6/23/2022 and 9/8/2022	22	46

School/Building	Date(s) Sampled	Total # of Fixtures	# Samples Collected
Pittsburgh Manchester PreK-8	8/10/2022 and 10/7/2022	39	80
Pittsburgh Miller PreK-5	4/27/2022	31	64
Pittsburgh Milliones 6-12	5/28/2022 and 11/10/2022	32	66
Pittsburgh Montessori PreK-5	4/20/2022 and 4/29/2022	32	68
Pittsburgh Morrow Intermediate 5-8	7/6/2022	31	63
Pittsburgh Morrow PreK-4	4/26/2022 and 5/18/2022	35	72
Pittsburgh Online Academy (South Annex)	7/12/2022	11	24
Pittsburgh Perry Field House	6/10/2022	5	12
Pittsburgh Perry High School	6/11/2022 and 8/2/2022	53	109
Pittsburgh Pioneer	6/7/2022	8	18
Pittsburgh Roosevelt 2-5	6/1/2022	16	34
Pittsburgh Schenley Field House	5/28/2022 and 10/14/2022	7	15
Pittsburgh Science and Technology Academy 6-12	6/24/2022 and 9/29/2022	31	64
Pittsburgh Service Center	7/14/2022	14	29
Pittsburgh South Brook 6-8	6/7/2022	24	50
Pittsburgh Sterrett 6-8	8/17/2022	28	57
Pittsburgh Sunnyside PreK-8	5/10/2022 and 9/16/2022	43	88
Pittsburgh Weil PreK-5	5/4/2022	32	66

School/Building	Date(s) Sampled	Total # of Fixtures	# Samples Collected
Pittsburgh West Liberty K-5	6/28/2022 and 9/13/2022	27	56
Pittsburgh Westinghouse Academy 6-12	4/14/2022, 5/11/2022, and 11/4/2022	82	164
Pittsburgh Westinghouse Field House	4/14/2022	4	10

4. RECOMMENDATIONS

1. In accordance with the Pennsylvania Public School Code of 1949, as amended June 22, 2018, Section 742, the lead level of drinking water in schools should not exceed the concentrations established by the United States Environmental Protection Agency's National Primary Drinking Water Regulations, currently 15 parts per billion (ppb) and the Pittsburgh Public School District's chosen action level for lead concentrations of 15 parts per billion (ppb); all drinking water sources that exceed 15 ppb or greater should be remediated to reduce lead concentrations. Remediation may include but not be limited to posting signs indicating "not for drinking", cleaning fixtures, replacing individual fixtures with lead free fixtures, replacing the system or plumbing (lead solder joints or brass) with lead free materials, point of source filters and / or disabling fixtures. The remediation action(s) will depend on the fixture and circumstances involved. Following remediation efforts before any drinking water source is placed back into service the fixture(s) were re-tested to ensure the lead level was reduced below the recommended lead concentration of 15 parts per billion (ppb).
2. A procedure should be implemented to inform staff of best drinking water practices, which should include but not be limited to:
 - a. Staff and students should refrain from using classroom faucets for drinking water. Instead, they should be encouraged to use designated water fountains, kitchen faucets, and teachers' lounge sinks.
 - b. Prior to drinking, water should be run for one minute or until the water runs cold.
 - c. Only use cold water for drinking and cooking.
3. Following any break longer than five (5) days the water in the facility should be run through drinking water sources to ensure stagnant water has been moved through the plumbing. It is recommended that flushing directions provided by EPA's "Lead in Drinking Water in Schools and Non-Residential Buildings, EPA 812-B-94-002", April 1994 and "3Ts for Reducing Lead in Drinking Water in Schools and Child Care Facilities: A Training, Testing, and Taking Action Approach, October 2018 be followed.
4. A procedure should be implemented to routinely clean drinking water sources and distribution piping. Cleaning should include but not be limited to ensuring fixtures are free from debris, drain properly, aerators (screens) are clean and free from debris, and filters changed in accordance with the manufacture's guidelines.

5. Designate specific drinking water sources and differentiate “Hand Wash Only” or “Not for Drinking” using signs posted at designated non-drinking water sources (restrooms, science labs, utility sinks, wash sinks, etc.).

REPORT DISCLAIMER:

This AGX, Inc. report is based on information supplied by the client, occupants and on conditions readily observable or measurable on the date or dates of this study. The results and recommendations presented herein should not be relied upon exclusively for the prevention of all possible illnesses, injuries, or losses. These services are a supplement to, and not a substitute for, the client’s responsibility for protecting the health and safety of the occupants of the facility, and others, and for complying with applicable laws and regulations.

This report and the associated attachments and appendices have been produced and developed for, and at the request of, Pittsburgh Public Schools. It conveys the findings of AGX as of the date(s) noted herein. This report is intended for the exclusive use of Pittsburgh Board of Public Education (including its management, officers, and the School Board).

APPENDIX A

DRINKING WATER RESULTS TABLES

Pittsburgh Arlington PreK-8

Lead in Drinking Water Sample Results

School: Pittsburgh Arlington PreK-8 (Phillip Murray)

Address: 800 Rehtanwald Street, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PMU-GF-SL-00	SL	Service Line	Pipe Space	6/29/2022	0607	P	1.15	N/A	N/A	
PMU-GF-WM-00	WM	Water Main	Pipe Space	6/29/2022	0610	P	<1.00	N/A	N/A	
PMU-GF-WC-02	WC	Water fountain with cooler	Corridor GA	6/29/2022	0612	P	<1.00	P	<1.00	
PMU-GF-WC-03	WC	Water fountain with cooler	Corridor GA	6/29/2022	0613	P	<1.00	P	<1.00	
PMU-GF-WF-13	WF	Water fountain with filter & cooler	Corridor GA	6/29/2022	0616	P	<1.00	P	<1.00	
PMU-GF-WFC-14	WFC	Filtering water cooler w/ bottle filler	Corridor GA	6/29/2022	0617	P	<1.00	P	<1.00	
PMU-GF-WC-30	WC	Water fountain with cooler	Corridor GD	6/29/2022	0621	P	<1.00	P	<1.00	
PMU-GF-WC-31	WC	Water fountain with cooler	Corridor GD	6/29/2022	0620	P	<1.00	P	<1.00	
PMU-BS-WF-39	WF	Water fountain with filter & cooler	Lunch Room (B1)	6/29/2022	0626	P	<1.00	P	<1.00	
PMU-BS-WFC-40	WFC	Filtering water cooler w/ bottle filler	Lunch Room (B1)	6/29/2022	0625	P	<1.00	P	<1.00	
PMU-BS-KF-43	KF	Kitchen faucets	Kitchen (B2)	6/29/2022	0628	P	<1.00	P	<1.00	
PMU-01-WC-45	WC	Water fountain with cooler	Corridor 1A	6/29/2022	0634	P	<1.00	P	<1.00	
PMU-01-WC-46	WC	Water fountain with cooler	Corridor 1A	6/29/2022	0633	P	<1.00	P	<1.00	
PMU-01-CF-50	CF	Classroom faucets	203							Posted Hand Wash Only
PMU-01-MS-51	MS	Miscellaneous sinks	203							Posted Hand Wash Only
PMU-01-MS-53	MS	Miscellaneous sinks	202							Posted Hand Wash Only
PMU-01-CF-55	CF	Classroom faucets	202							Posted Hand Wash Only
PMU-01-WF-56	WF	Water fountain with filter & cooler	Corridor 1A	6/29/2022	0645	P	<1.00	P	<1.00	
PMU-01-WFC-57	WFC	Filtering water cooler w/ bottle filler	Corridor 1A	6/29/2022	0644	P	<1.00	P	<1.00	
PMU-01-WC-70	WC	Water fountain with cooler	Corridor 1D	6/29/2022	0652	P	<1.00	P	<1.00	
PMU-01-WC-71	WC	Water fountain with cooler	Corridor 1D	6/29/2022	0650	P	<1.00	P	<1.00	
PMU-GF-TF-78	TF	Teacher's lounge sinks	102							Posted Hand Wash Only
PMU-GF-HF-83	HF	Home economics faucets (with cooking)	118							Posted Hand Wash Only
PMU-GF-CF-89	CF	Classroom faucets	104							Posted Hand Wash Only
PMU-GF-CF-90	CF	Classroom faucets	104							Posted Hand Wash Only
PMU-01-CF-104	CF	Classroom faucets	226							Posted Hand Wash Only
PMU-01-GF-110	GF	Filtered Glass Filler	202	6/29/2022	0640	P	<1.00	P	<1.00	
PMU-01-GF-111	GF	Filtered Glass Filler	203	6/29/2022	0637	P	<1.00	P	<1.00	

Pittsburgh Banksville K-5

Lead in Drinking Water Sample Results

School: Pittsburgh Banksville K-5

Address: 1001 Carnahan Road, Pittsburgh, PA 15216

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
BAN-BS-SL-00	SL	Service Line	B-6	5/24/2022	0606	P	<1.00	N/A	N/A	
BAN-BS-WM-00	WM	Water Main	B-6	5/24/2022	0608	P	<1.00	N/A	N/A	
BAN-BS-TF-01	TF	Teacher's lounge sinks	B-5-B	5/24/2022	0605	P	<1.00	P	<1.00	
BAN-GF-WF-05	WF	Water fountain with filter & cooler	Corridor 1	5/24/2022	0614	P	<1.00	P	<1.00	
BAN-GF-WFC-06	WFC	Filtering water cooler w/ bottle filler	Corridor 1	5/24/2022	0615	P	<1.00	P	<1.00	
BAN-GF-CF-07	CF	Classroom faucets	111	5/24/2022	0617	P	1.50	P	<1.00	
BAN-GF-CF-09	CF	Classroom faucets	113	5/24/2022	0622	P	2.35	P	<1.00	
BAN-GF-KF-12	KF	Kitchen faucets	12-A	5/24/2022	0620	P	1.15	P	<1.00	
BAN-GF-WF-13	WF	Water fountain with filter & cooler	Multi-Purpose (12)	5/24/2022	0619	P	<1.00	P	<1.00	
BAN-GF-WF-17	WF	Water fountain with filter & cooler	Corridor 1	5/24/2022	0611	P	<1.00	P	<1.00	
BAN-GF-WFC-18	WFC	Filtering water cooler w/ bottle filler	Corridor 1	5/24/2022	0610	P	<1.00	P	<1.00	
BAN-GF-NF-19	NF	Nurse's office sink faucets	Nurse's Office	5/24/2022	0625	P	<1.00	P	<1.00	
BAN-GF-CF-21	CF	Classroom faucets	104	5/24/2022	0630	P	<1.00	P	<1.00	
BAN-GF-CF-22	CF	Classroom faucets	107	5/24/2022	0628	P	1.75	P	<1.00	
BAN-GF-CF-23	CF	Classroom faucets	105	5/24/2022	0632	P	2.10	P	<1.00	
BAN-02-CF-28	CF	Classroom faucets	208	5/24/2022	0640	P	3.94	P	<1.00	
BAN-02-WF-29	WF	Water fountain with filter & cooler	Corridor 201	5/24/2022	0646	P	<1.00	P	<1.00	
BAN-02-WFC-30	WFC	Filtering water cooler w/ bottle filler	Corridor 201	5/24/2022	0645	P	<1.00	P	<1.00	
BAN-02-CF-31	CF	Classroom faucets	211	5/24/2022	0649	P	1.60	P	<1.00	
BAN-02-WC-35	WC	Water fountain with cooler	Corridor 201	5/24/2022	0637	P	<1.00	P	<1.00	
BAN-02-WC-36	WC	Water fountain with cooler	Corridor 201	5/24/2022	0636	P	<1.00	P	<1.00	
BAN-02-CF-40	CF	Classroom faucets	208	5/24/2022	0641	P	2.15	P	<1.00	
BAN-02-CF-41	CF	Classroom faucets	210	5/24/2022	0647	P	<1.00	P	<1.00	
BAN-02-MS-42	MS	Miscellaneous sinks	Library (209-A)	5/24/2022	0643	P	1.85	P	<1.00	
BAN-GF-GF-44	GF	Filtered Glass Filler	Nurse's Office	5/24/2022	0626	P	<1.00	P	<1.00	

Pittsburgh Brookline PreK-8

Lead in Drinking Water Sample Results

School: Pittsburgh Brookline PreK-8

Address: 500 Woodbourne Avenue, Pittsburgh, PA 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
BRO-GF-SL-00	SL	Service Line	Custodian's Office (15)	6/22/2022	0557	P	1.16	N/A	N/A	
BRO-GF-WM-00	WM	Water Main	Custodian's Office (15)	6/22/2022	0600	P	<1.00	N/A	N/A	
BRO-GF-KF-06	KF	Kitchen faucets	Kitchen (3D)	6/22/2022	0606	P	1.72	P	<1.00	
BRO-GF-CF-24	CF	Classroom faucets	Demountable Classroom (321)	9/2/2022	0602	P	5.58	P	<1.00	
BRO-GF-CF-27	CF	Classroom faucets	Demountable Classroom (323)	6/22/2022	0739	P	5.83	P	1.44	
BRO-01-WF-32	WF	Water fountain with filter & cooler	Corridor 100A	6/22/2022	0624	P	<1.00	P	<1.00	
BRO-01-WFC-33	WFC	Filtering water cooler w/ bottle filler	Corridor 100A	6/22/2022	0626	P	<1.00	P	<1.00	
BRO-01-WC-43	WC	Water fountain with cooler	Corridor 100B	6/22/2022	0629	P	<1.00	P	<1.00	
BRO-01-WFC-44	WFC	Filtering water cooler w/ bottle filler	Corridor 100B	6/22/2022	0630	P	<1.00	P	<1.00	
BRO-02-TF-48	TF	Teacher's lounge sinks	216	6/22/2022	0650	P	1.21	P	<1.00	
BRO-02-WF-49	WF	Water fountain with filter & cooler	Corridor 200A	6/22/2022	0657	P	<1.00	P	<1.00	
BRO-02-WFC-50	WFC	Filtering water cooler w/ bottle filler	Corridor 200A	6/22/2022	0658	P	<1.00	P	<1.00	
BRO-02-CF-55	CF	Classroom faucets	202A	6/22/2022	0706	P	1.88	P	1.60	
BRO-02-NF-57	NF	Nurse's office sink faucets	Nurse's Office (200-A)	6/22/2022	0653	P	3.55	P	1.06	
BRO-02-WC-64	WC	Water fountain with cooler	Corridor 200	6/22/2022	0700	P	<1.00	P	<1.00	
BRO-02-WC-65	WC	Water fountain with cooler	Corridor 200	6/22/2022	0701	P	<1.00	P	<1.00	
BRO-02-CF-66	CF	Classroom faucets	213	6/22/2022	0703	P	1.28	P	<1.00	
BRO-GF-CF-71	CF	Classroom faucets	11F	6/22/2022	0612	P	1.46	P	<1.00	
BRO-GF-CF-72	CF	Classroom faucets	11	6/22/2022	0616	P	<1.00	P	<1.00	
BRO-01-CF-73	CF	Classroom faucets	103A	6/22/2022	0635	P	1.61	P	1.15	
BRO-01-WC-74	WC	Water fountain with cooler	Corridor 100A	6/22/2022	0641	P	<1.00	P	<1.00	
BRO-01-WC-75	WC	Water fountain with cooler	Corridor 100A	6/22/2022	0643	P	<1.00	P	<1.00	
BRO-01-CF-76	CF	Classroom faucets	104A	6/22/2022	0640	P	11.5	P	4.25	
BRO-01-CF-77	CF	Classroom faucets	107A	6/22/2022	0637	P	11.1	P	1.69	
BRO-01-CF-78	CF	Classroom faucets	105A	6/22/2022	0645	F	15.7	P	9.61	Retested and Passed on 9/2/2022
BRO-01-CF-79	CF	Classroom faucets	106A	6/22/2022	0647	P	12.7	P	<1.00	
BRO-01-MS-80	MS	Miscellaneous sinks	Library (115)	6/22/2022	0633	P	1.21	P	<1.00	
BRO-02-WC-81	WC	Water fountain with cooler	Corridor 200A	6/22/2022	0715	P	<1.00	P	<1.00	
BRO-02-WC-82	WC	Water fountain with cooler	Corridor 200A	6/22/2022	0716	P	<1.00	P	<1.00	
BRO-02-CF-83	CF	Classroom faucets	206A	6/22/2022	0713	P	7.14	P	1.30	
BRO-02-CF-84	CF	Classroom faucets	205A	6/22/2022	0720	P	<1.00	P	1.15	
BRO-GF-CF-86	CF	Classroom faucets	Demountable Classroom (320)	6/22/2022	0735	P	1.41	P	1.07	
BRO-GF-CF-89	CF	Classroom faucets	Demountable Classroom (322)	6/22/2022	0743	P	4.98	P	1.02	
BRO-GF-WF-91	WF	Water fountain with filter & cooler	Corridor 1	6/22/2022	0602	P	<1.00	P	<1.00	
BRO-GF-WFC-92	WFC	Filtering water cooler w/ bottle filler	Corridor 1	6/22/2022	0603	P	<1.00	P	<1.00	
BRO-GF-CF-93	CF	Classroom faucets	13	6/22/2022	0609	P	<1.00	P	<1.00	
BRO-GF-MS-94	MS	Miscellaneous sinks	11B	6/22/2022	0620	P	1.17	P	<1.00	
BRO-GF-CF-95	CF	Classroom faucets	11F	6/22/2022	0613	P	<1.00	P	<1.00	
BRO-GF-KF-97	KF	Kitchen faucets	Kitchen (3D)	6/22/2022	0605	P	1.93	P	1.32	
BRO-GF-SL-98	SL	Service Line	Street	6/22/2022	0727	P	<1.00	N/A	N/A	
BRO-GF-WM-98	WM	Water Main	Street	6/22/2022	0730	P	<1.00	N/A	N/A	
BRO-02-CF-102	CF	Classroom faucets	203A	6/22/2022	0718	F	33.1	P	6.68	Retested on 9/2/2022; Posted Hand Wash Only on 10/13/2022
BRO-GF-CF-104	CF	Classroom faucets	11	6/22/2022	0617	P	<1.00	P	<1.00	
BRO-GF-GF-105	GF	Filtered glass filler	11	6/22/2022	0618	P	<1.00	P	<1.00	
BRO-GF-GF-106	GF	Filtered glass filler	Demountable Classroom (320)	6/22/2022	0736	P	<1.00	P	<1.00	
BRO-GF-GF-107	GF	Filtered glass filler	Demountable Classroom (321)	9/2/2022	0604	P	<1.00	P	<1.00	
BRO-GF-GF-108	GF	Filtered glass filler	Demountable Classroom (322)	6/22/2022	0744	P	<1.00	P	<1.00	
BRO-GF-GF-109	GF	Filtered glass filler	Demountable Classroom (323)	6/22/2022	0740	P	<1.00	P	<1.00	

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
BRO-02-GF-110	GF	Filtered glass filler	Nurse's Office (200-A)	6/22/2022	0655	P	<1.00	P	<1.00	

Pittsburgh Carrick Field House

Lead in Drinking Water Sample Results

School: Pittsburgh Carrick Field House

Address: Park Boulevard, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CFH-01-SL-00	SL	Service Line	Utility Room	8/19/2022	0605	P	<1.00	N/A	N/A	
CFH-01-WM-00	WM	Water Main	Utility Room	8/19/2022	0608	P	<1.00	N/A	N/A	
CFH-01-US-03	US	Utility sinks	Utility Room	8/19/2022	0604	P	2.86	P	<1.00	
CFH-01-WO-16	WO	Water fountain without cooler	Outside Field House	9/13/2022	0607	P	1.80	P	<1.00	
CFH-01-IM-19	IM	Ice machines	Training Room	8/19/2022	0559	P	<1.00	N/A	N/A	

Pittsburgh Carrick High School

Lead in Drinking Water Sample Results

School: Pittsburgh Carrick High School

Address: 125 Parkfield Street, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CAR-SB-SL-00	SL	Service Line	Boiler Room	5/14/2022	0702	P	<1.00	N/A	N/A	
CAR-SB-WM-00	WM	Water Main	Boiler Room	5/14/2022	0705	P	<1.00	N/A	N/A	
CAR-BS-WC-03	WC	Water fountain with cooler	B-9	5/14/2022	0715	P	3.08	P	2.55	
CAR-BS-CF-04	CF	Classroom faucets	B-9	5/14/2022	0717	P	<1.00	P	<1.00	
CAR-BS-WFC-05	WFC	Filtering water cooler w/ bottle filler	Basement Corridor	5/14/2022	0719	P	<1.00	P	<1.00	
CAR-BS-CF-07	CF	Classroom faucets	B-1	5/14/2022	0712	P	<1.00	P	<1.00	
CAR-BS-WC-08	WC	Water fountain with cooler	B-1	5/14/2022	0714	P	2.33	P	3.65	
CAR-01-CF-09	CF	Classroom faucets	703	5/14/2022	0742	P	<1.00	P	<1.00	
CAR-01-CF-10	CF	Classroom faucets	703	5/14/2022	0740	P	<1.00	P	<1.00	
CAR-01-CF-11	CF	Classroom faucets	701	5/14/2022	0736	P	<1.00	P	<1.00	
CAR-01-WF-13	WF	Water fountain with filter & cooler	Corridor 700	5/14/2022	0748	P	<1.00	P	<1.00	
CAR-01-WFC-14	WFC	Filtering water cooler w/ bottle filler	Corridor 700	5/14/2022	0747	P	<1.00	P	<1.00	
CAR-01-WC-21	WC	Water fountain with cooler	Corridor 700	9/13/2022	0538	P	1.90	P	1.07	
CAR-01-WC-22	WC	Water fountain with cooler	Corridor 700	5/14/2022	0755	P	1.75	P	<1.00	
CAR-01-WC-48	WC	Water fountain with cooler	Pool Deck (715)	5/14/2022	0752	P	<1.00	P	<1.00	
CAR-01-MS-56	MS	Miscellaneous sinks	704	5/14/2022	0745	P	<1.00	P	<1.00	
CAR-01-IM-57	IM	Ice machines	704	5/14/2022	0746	P	<1.00	N/A	N/A	
CAR-01-WC-67	WC	Water fountain with cooler	728	5/14/2022	0759	P	2.60	P	1.25	
CAR-01-WC-68	WC	Water fountain with cooler	736	5/14/2022	0802	P	1.19	P	1.45	
CAR-01-WC-69	WC	Water fountain with cooler	736	5/14/2022	0801	P	<1.00	P	<1.00	
CAR-01-WC-84	WC	Water fountain with cooler	726	9/13/2022	0544	P	2.66	P	<1.00	
CAR-01-WFC-100	WFC	Filtering water cooler w/ bottle filler	Corridor 100	5/14/2022	0729	P	<1.00	P	<1.00	
CAR-01-MS-105	MS	Miscellaneous sinks	116	5/14/2022	0732	P	<1.00	P	<1.00	
CAR-01-KF-107	KF	Kitchen faucets	Kitchen	5/14/2022	0727	P	<1.00	P	<1.00	
CAR-01-KF-109	KF	Kitchen faucets	Kitchen	5/14/2022	0726	P	1.66	P	<1.00	
CAR-01-KF-110	KF	Kitchen faucets	Kitchen	5/14/2022	0725	P	<1.00	P	<1.00	
CAR-01-KF-112	KF	Kitchen faucets	Kitchen	5/14/2022	0724	P	1.89	P	<1.00	
CAR-01-MS-116	MS	Miscellaneous sinks	200	5/14/2022	0809	P	<1.00	P	<1.00	
CAR-01-TF-117	TF	Teacher's lounge sinks	201	5/14/2022	0808	P	<1.00	P	<1.00	
CAR-01-CF-120	CF	Classroom faucets	205	5/14/2022	0812	P	<1.00	P	<1.00	
CAR-01-CF-121	CF	Classroom faucets	205	5/14/2022	0813	P	1.62	P	<1.00	
CAR-01-WF-122	WF	Water fountain with filter & cooler	Corridor 200	5/14/2022	0815	P	<1.00	P	<1.00	
CAR-01-WFC-123	WFC	Filtering water cooler w/ bottle filler	Corridor 200	5/14/2022	0814	P	<1.00	P	<1.00	
CAR-01-CF-127	CF	Classroom faucets	227	5/14/2022	0821	P	<1.00	P	<1.00	
CAR-01-CF-129	CF	Classroom faucets	230	9/13/2022	0550	P	<1.00	P	<1.00	
CAR-01-KF-130	KF	Home EC. Kitchen Faucet	226	5/14/2022	0824	P	8.79	P	2.90	
CAR-01-IM-131	IM	Ice machines	226	5/14/2022	0828	P	<1.00	N/A	N/A	
CAR-01-HF-136	HF	Home economics faucets (with cooking)	228	5/14/2022	0833	P	<1.00	P	<1.00	Kitchen 1
CAR-01-HF-137	HF	Home economics faucets (with cooking)	228	5/14/2022	0835	P	<1.00	P	<1.00	Kitchen 2
CAR-01-HF-138	HF	Home economics faucets (with cooking)	228	5/14/2022	0836	P	1.14	P	<1.00	Kitchen 3
CAR-01-HF-139	HF	Home economics faucets (with cooking)	228	5/14/2022	0834	P	<1.00	P	<1.00	Kitchen 4
CAR-01-HF-140	HF	Home economics faucets (with cooking)	228	5/14/2022	0832	P	1.32	P	<1.00	Kitchen 5
CAR-01-HF-141	HF	Home economics faucets (with cooking)	228	5/14/2022	0831	P	<1.00	P	<1.00	Kitchen 6
CAR-01-KF-142	KF	Home EC. Kitchen Faucet	226	5/14/2022	0825	P	<1.00	P	<1.00	
CAR-01-KF-143	KF	Home EC. Kitchen Faucet	226	5/14/2022	0826	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Carrick High School

Address: 125 Parkfield Street, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CAR-01-KF-145	KF	Home EC. Kitchen Faucet	226	5/14/2022	0827	P	2.34	P	<1.00	
CAR-01-CF-149	CF	Classroom faucets	206	5/14/2022	0818	P	<1.00	P	<1.00	
CAR-02-CF-150	CF	Classroom faucets	338	5/14/2022	0842	P	<1.00	P	<1.00	
CAR-02-CF-151	CF	Classroom faucets	338	5/14/2022	0843	P	<1.00	P	<1.00	
CAR-02-CF-152	CF	Classroom faucets	338	5/14/2022	0844	P	<1.00	P	<1.00	
CAR-02-WC-153	WC	Water fountain with cooler	Corridor 300	5/14/2022	0850	P	1.32	P	<1.00	
CAR-02-CF-154	CF	Classroom faucets	337	5/14/2022	0849	P	<1.00	P	<1.00	
CAR-02-CF-155	CF	Classroom faucets	337	5/14/2022	0848	P	<1.00	P	<1.00	
CAR-02-CF-156	CF	Classroom faucets	335	5/14/2022	0857	P	<1.00	P	<1.00	
CAR-02-WF-162	WF	Water fountain with filter & cooler	Corridor 300	5/14/2022	0900	P	<1.00	P	<1.00	
CAR-02-WFC-163	WFC	Filtering water cooler w/ bottle filler	Corridor 300	5/14/2022	0859	P	<1.00	P	<1.00	
CAR-02-MS-169	MS	Miscellaneous sinks	305	5/14/2022	0902	P	<1.00	P	<1.00	
CAR-02-NF-171	NF	Nurse's office sink faucets	301C	5/14/2022	0904	F	15.2	P	1.74	Retested and Passed on 9/13/2022
CAR-02-NF-172	NF	Nurse's office sink faucets	301B	5/14/2022	0905	P	3.62	P	<1.00	
CAR-02-NF-173	NF	Nurse's office sink faucets	301	5/14/2022	0906	P	2.68	P	<1.00	
CAR-02-TF-174	TF	Teacher's lounge sinks	401	5/14/2022	0910	P	<1.00	P	<1.00	
CAR-02-WF-176	WF	Water fountain with filter & cooler	Corridor 400	5/14/2022	0913	P	<1.00	P	<1.00	
CAR-02-WFC-177	WFC	Filtering water cooler w/ bottle filler	Corridor 400	5/14/2022	0912	P	<1.00	P	<1.00	
CAR-03-WC-228	WC	Water fountain with cooler	Corridor 500	5/14/2022	0920	P	<1.00	P	<1.00	
CAR-03-WF-339	WF	Water fountain with filter & cooler	Corridor 500	5/14/2022	0924	P	<1.00	P	<1.00	
CAR-03-WFC-340	WFC	Filtering water cooler w/ bottle filler	Corridor 500	5/14/2022	0923	P	<1.00	P	<1.00	
CAR-03-TF-354	TF	Teacher's lounge sinks	502	5/14/2022	0925	P	<1.00	P	<1.00	
CAR-03-TF-355	TF	Teacher's lounge sinks	601	5/14/2022	0928	P	2.19	P	<1.00	
CAR-03-WF-357	WF	Water fountain with filter & cooler	Corridor 600	5/14/2022	0931	P	<1.00	P	<1.00	
CAR-03-WFC-358	WFC	Filtering water cooler w/ bottle filler	Corridor 600	5/14/2022	0930	P	<1.00	P	<1.00	
CAR-03-MS-362	MS	Miscellaneous sinks	611	5/14/2022	0938	P	<1.00	P	<1.00	
CAR-04-TF-366	TF	Teacher's lounge sinks	801	5/14/2022	0942	P	<1.00	P	<1.00	
CAR-04-WF-368	WF	Water fountain with filter & cooler	Corridor 800	5/14/2022	0944	P	<1.00	P	<1.00	
CAR-04-WFC-369	WFC	Filtering water cooler w/ bottle filler	Corridor 800	5/14/2022	0943	P	<1.00	P	<1.00	
CAR-BS-MS-375	MS	Miscellaneous sinks	B-6	5/14/2022	0710	P	<1.00	P	<1.00	
CAR-01-WO-376	WO	Water Fountain Attached to Sink	701	5/14/2022	0737	P	1.34	P	<1.00	
CAR-01-WO-377	WO	Water Fountain Attached to Sink	703	5/14/2022	0741	P	4.03	P	3.04	
CAR-01-IM-385	IM	Ice machines	Kitchen	9/20/2022	0545	P	<1.00	N/A	N/A	
CAR-03-WC-388	WC	Water fountain with cooler	Outside 328	5/14/2022	0853	P	5.47	P	1.29	
CAR-01-KF-390	KF	Home EC. Kitchen Faucet	226							Not in Operation
CAR-02-TF-392	TF	Teacher's lounge sinks	302	5/14/2022	0908	P	<1.00	P	<1.00	
CAR-02-CF-393	CF	Classroom faucets	335	5/14/2022	0856	P	<1.00	P	<1.00	
CAR-02-CF-394	CF	Classroom faucets	338	5/14/2022	0845	P	<1.00	P	<1.00	
CAR-02-CF-395	CF	Classroom faucets	338	5/14/2022	0846	P	<1.00	P	<1.00	
CAR-02-WC-396	WC	Water fountain with cooler	418	5/14/2022	0915	P	<1.00	P	2.45	
CAR-02-CF-397	CF	Classroom faucets	418	5/14/2022	0916	P	<1.00	P	<1.00	
CAR-01-WC-399	WC	Water fountain with cooler	711	5/14/2022	0750	P	<1.00	P	<1.00	
CAR-01-IM-402	IM	Ice machines	728B	9/20/2022	0600	P	<1.00	N/A	N/A	

Pittsburgh Central Operations

Lead in Drinking Water Sample Results

School: Pittsburgh Central Operations

Address: 8 S. 13th Street, Pittsburgh, PA 15203

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
COP-01-SL-00	SL	Service Line	Storage (131)	7/13/2022	0532	P	<1.00	N/A	N/A	
COP-01-WM-00	WM	Water Main	Storage (131)	7/13/2022	0535	P	<1.00	N/A	N/A	
COP-01-KF-04	KF	Kitchen faucets	Lunch Room (106)	7/13/2022	0536	P	<1.00	P	<1.00	
COP-01-WF-06	WF	Water fountain with filter & cooler	Corridor 117	7/13/2022	0543	P	<1.00	P	<1.00	
COP-01-WFC-07	WFC	Filtering water cooler w/ bottle filler	Corridor 117	7/13/2022	0542	P	<1.00	P	<1.00	
COP-01-KF-14	KF	Kitchen faucets	Kitchen	7/13/2022	0547	P	<1.00	P	<1.00	
COP-01-KF-15	KF	Kitchen faucets	Kitchen	7/13/2022	0548	P	<1.00	P	<1.00	
COP-01-WC-18	WC	Water fountain with cooler	Kitchen	7/13/2022	0551	P	3.72	P	3.10	
COP-01-WC-21	WC	Water fountain with cooler	Kitchen	7/13/2022	0554	P	1.48	P	1.24	
COP-01-KF-24	KF	Kitchen faucets	Kitchen	7/13/2022	0600	P	<1.00	P	<1.00	
COP-01-KF-25	KF	Kitchen faucets	Kitchen	7/13/2022	0556	P	<1.00	P	<1.00	
COP-01-WC-26	WC	Water fountain with cooler	Kitchen	7/13/2022	0602	P	<1.00	P	<1.00	
COP-01-KF-28	KF	Kitchen faucets	Kitchen	7/13/2022	0603	P	<1.00	P	<1.00	
COP-01-KF-29	KF	Kitchen faucets	Kitchen	7/13/2022	0605	P	<1.00	P	<1.00	
COP-02-MS-30	MS	Miscellaneous sinks	Conference Room	7/13/2022	0613	P	<1.00	P	<1.00	
COP-02-WC-31	WC	Water fountain with cooler	Elevator Lobby	7/13/2022	0610	P	<1.00	P	<1.00	
COP-02-WC-32	WC	Water fountain with cooler	Elevator Lobby	7/13/2022	0611	P	<1.00	P	<1.00	
COP-03-MS-38	MS	Miscellaneous sinks	Coffee (204)	7/13/2022	0620	P	<1.00	P	<1.00	
COP-03-WC-39	WC	Water fountain with cooler	Office Area	10/7/2022	0525	P	<1.00	P	<1.00	
COP-03-WC-40	WC	Water fountain with cooler	Office Area	7/13/2022	0617	P	<1.00	P	<1.00	
COP-03-MS-55	MS	Miscellaneous sinks	Plant Operations	7/13/2022	0625	P	<1.00	P	<1.00	
COP-03-WC-58	WC	Water fountain with cooler	Corridor 233	7/13/2022	0627	P	1.65	P	<1.00	
COP-03-WC-59	WC	Water fountain with cooler	Corridor 233	7/13/2022	0628	P	<1.00	P	<1.00	
COP-01-IM-62	IM	Ice machines	Lunch Room (106)	7/13/2022	0538	P	<1.00	N/A	N/A	
COP-01-MS-63	MS	Miscellaneous sinks	Lunch Room (106)	7/13/2022	0540	P	<1.00	P	<1.00	
COP-03-MS-72	MS	Miscellaneous sinks	Coffee (204)	7/13/2022	0621	P	<1.00	P	<1.00	
COP-01-MS-75	MS	Miscellaneous sinks	Kitchen	7/13/2022	0558	P	<1.00	P	<1.00	

Pittsburgh Chartiers Early Childhood Center

Lead in Drinking Water Sample Results

School: Pittsburgh Chartiers Early Childhood Center

Address: 3799 Chartiers Avenue, Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CHA-01-SL-00	SL	Service Line	113	4/19/2022	0600	P	<1.00	N/A	N/A	
CHA-01-WM-00	WM	Water Main	113	4/19/2022	0603	P	<1.00	N/A	N/A	
CHA-01-CF-1	CF	Classroom faucets	105	4/19/2022	0615	P	<1.00	P	<1.00	
CHA-01-CF-4	CF	Classroom faucets	101	4/19/2022	0619	P	<1.00	P	<1.00	
CHA-01-WFC-5	WFC	Filtering water cooler w/ bottle filler	Corridor 100	4/19/2022	0608	P	<1.00	P	<1.00	
CHA-01-NF-11	NF	Nurse's office sink faucets	102	4/19/2022	0613	P	1.94	P	1.31	
CHA-01-WF-13	WF	Water fountain with filter & cooler	Corridor 100	4/19/2022	0609	P	<1.00	P	<1.00	
CHA-01-KF-15	KF	Kitchen faucets	121-B	4/19/2022	0623	P	<1.00	P	<1.00	
CHA-01-WF-16	WF	Water fountain with filter & cooler	121	4/19/2022	0625	P	<1.00	P	<1.00	
CHA-01-WF-17	WF	Water fountain with filter & cooler	121	4/19/2022	0626	P	<1.00	P	<1.00	
CHA-01-TF-23	TF	Teacher's lounge sinks	124	4/19/2022	0638	P	<1.00	P	<1.00	
CHA-01-WFC-24	WFC	Filtering water cooler w/ bottle filler	Corridor 100-B	4/19/2022	0632	P	<1.00	P	<1.00	
CHA-01-WF-25	WF	Water fountain with filter & cooler	Corridor 100-B	4/19/2022	0633	P	<1.00	P	<1.00	
CHA-01-CF-31	CF	Classroom faucets	202	4/19/2022	0641	P	1.51	P	<1.00	
CHA-01-CF-32	CF	Classroom faucets	201	4/19/2022	0644	P	1.08	P	<1.00	
CHA-01-CF-33	CF	Classroom faucets	204	4/19/2022	0648	P	<1.00	P	<1.00	
CHA-01-CF-34	CF	Classroom faucets	206	4/19/2022	0650	P	4.05	P	<1.00	
CHA-01-GF-35	GF	Filtered Glass Filler	105	4/19/2022	0616	P	<1.00	P	<1.00	
CHA-01-GF-36	GF	Filtered Glass Filler	101 Restroom	4/19/2022	0618	P	<1.00	P	<1.00	
CHA-01-GF-37	GF	Filtered Glass Filler	101	4/19/2022	0620	P	2.75	P	<1.00	
CHA-01-GF-38	GF	Filtered Glass Filler	Girl's Restroom (106)	4/19/2022	0605	P	1.71	P	<1.00	
CHA-01-GF-39	GF	Filtered Glass Filler	Girl's Restroom (106)	4/19/2022	0606	P	<1.00	P	<1.00	
CHA-01-GF-40	GF	Filtered Glass Filler	Boy's Restroom (103)	4/19/2022	0612	P	1.11	P	<1.00	
CHA-01-GF-41	GF	Filtered Glass Filler	Boy's Restroom (103)	4/19/2022	0611	P	2.06	P	<1.00	
CHA-01-GF-42	GF	Filtered Glass Filler	124	4/19/2022	0637	P	<1.00	P	<1.00	
CHA-01-GF-43	GF	Filtered Glass Filler	Boy's Restroom (123)	4/19/2022	0630	P	3.25	P	<1.00	
CHA-01-GF-44	GF	Filtered Glass Filler	Boy's Restroom (123)	4/19/2022	0629	P	3.51	P	<1.00	
CHA-01-GF-45	GF	Filtered Glass Filler	Girl's Restroom (125)	4/19/2022	0636	P	<1.00	P	<1.00	
CHA-01-GF-46	GF	Filtered Glass Filler	Girl's Restroom (125)	4/19/2022	0635	P	4.02	P	<1.00	
CHA-01-GF-47	GF	Filtered Glass Filler	202	4/19/2022	0640	P	<1.00	P	<1.00	
CHA-01-GF-48	GF	Filtered Glass Filler	201	4/19/2022	0643	P	<1.00	P	<1.00	
CHA-01-GF-49	GF	Filtered Glass Filler	204	4/19/2022	0647	P	2.33	P	<1.00	

City Connections Program – City East

Lead in Drinking Water Sample Results

School: City Connections Program - City East

Address: 6322 Forward Avenue, Pittsburgh, PA 15217

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Locations	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CTET-BS-SL-00	SL	Service Line	Basement	9/16/2022	0735	P	3.00	N/A	N/A	
CTET-BS-WM-00	WM	Water Main	Basement	9/16/2022	0738	P	1.33	N/A	N/A	
CTET-01-KF-01	KF	Kitchen faucets	Kitchen	9/16/2022	0740	P	1.24	P	<1.00	

City Connections Program – City West

Lead in Drinking Water Sample Results

School: City Connections Program - City West

Address: 2945 Chartiers Avenue, Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Locations	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CTWT-BS-SL-00	SL	Service Line	Basement	6/2/2022	0812	P	<1.00	N/A	N/A	
CTWT-BS-WM-00	WM	Water Main	Basement	6/2/2022	0815	P	<1.00	N/A	N/A	
CTWT-01-KF-03	KF	Kitchen faucets	1st Floor Kitchen	6/2/2022	0817	P	<1.00	P	<1.00	
CTWT-02-KF-08	KF	Kitchen faucets	2nd Floor Kitchen	6/2/2022	0819	P	1.58	P	<1.00	

Pittsburgh Clayton Academy

Lead in Drinking Water Sample Results

School: Pittsburgh Clayton Academy

Address: 1901 Clayton Avenue, Pittsburgh, PA 15214

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CLA-BS-SL-00	SL	Service Line	Boiler Room	8/23/2022	0529	P	<1.00	N/A	N/A	
CLA-BS-WM-00	WM	Water Main	Boiler Room	8/23/2022	0532	P	<1.00	N/A	N/A	
CLA-BS-MS-02	MS	Miscellaneous sinks	SB02	8/23/2022	0533	P	<1.00	P	<1.00	
CLA-GF-WF-03	WF	Water fountain with filter & cooler	Gym Corridor	8/23/2022	0538	P	<1.00	P	<1.00	
CLA-GF-KF-06	KF	Kitchen faucets	Kitchen	8/23/2022	0541	P	1.78	P	<1.00	
CLA-GF-KF-09	KF	Kitchen faucets	Kitchen	8/23/2022	0540	P	2.51	P	<1.00	
CLA-01-NF-13	NF	Nurse's office sink faucets	Nurse's Office (104B)	8/23/2022	0549	P	2.38	P	2.81	
CLA-01-WF-16	WF	Water fountain with filter & cooler	Across from 105	8/23/2022	0553	P	<1.00	P	<1.00	
CLA-01-WFC-17	WFC	Filtering water cooler w/ bottle filler	Across from 105	8/23/2022	0552	P	<1.00	P	<1.00	
CLA-01-MS-20	MS	Miscellaneous sinks	Art Room (116)	8/23/2022	0555	P	<1.00	P	<1.00	
CLA-01-WF-23	WF	Water fountain with filter & cooler	Outside 108	8/23/2022	0557	P	<1.00	P	<1.00	
CLA-01-WFC-24	WFC	Filtering water cooler w/ bottle filler	Outside 108	8/23/2022	0558	P	<1.00	P	<1.00	
CLA-GF-MS-28	MS	Miscellaneous sinks	Computer Lab (110)	8/23/2022	0601	P	<1.00	P	<1.00	
CLA-02-MS-34	MS	Miscellaneous sinks	Library (201)	8/23/2022	0606	P	1.06	P	2.74	
CLA-02-WF-39	WF	Water fountain with filter & cooler	Across from 203	8/23/2022	0609	P	<1.00	P	<1.00	
CLA-02-WFC-40	WFC	Filtering water cooler w/ bottle filler	Across from 203	8/23/2022	0608	P	<1.00	P	<1.00	
CLA-02-WF-42	WF	Water fountain with filter & cooler	Outside 205	8/23/2022	0612	P	<1.00	P	<1.00	
CLA-02-WFC-43	WFC	Filtering water cooler w/ bottle filler	Outside 205	8/23/2022	0613	P	<1.00	P	<1.00	
CLA-02-MS-48	MS	Miscellaneous sinks	Comuter Lab (206)	8/23/2022	0616	P	10.4	P	<1.00	
CLA-01-TF-53	TF	Teacher's lounge sinks	Teacher's Lab (103A)	8/23/2022	0544	P	1.03	P	<1.00	
CLA-01-SL-71	SL	Service Line	Demountable (AC3)	8/23/2022	0622	P	14.6	N/A	N/A	
CLA-01-WM-71	WM	Water Main	Demountable (AC3)	8/23/2022	0625	P	4.58	N/A	N/A	
CLA-01-WFC-74	WFC	Filtering water cooler w/ bottle filler	Demountable Entry	8/23/2022	0626	P	<1.00	P	<1.00	
CLA-GF-WFC-78	WFC	Filtering water cooler w/ bottle filler	Gym Corridor	8/23/2022	0537	P	<1.00	P	<1.00	
CLA-01-GF-80	GF	Filtered Glass Filler	Teacher's Lab (103A)	8/23/2022	0545	P	<1.00	P	<1.00	
CLA-01-GF-81	GF	Filtered Glass Filler	Nurse's Office (104B)	8/23/2022	0548	P	<1.00	P	<1.00	

Pittsburgh Crescent Early Childhood Center

Drinking Water Sample Results

School: Pittsburgh Crescent Early Childhood Center

Address: 8080 Bennett Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CRE-BS-SL-00	SL	Service Line	Boiler Room	4/13/2022	0622	P	<1.00	N/A	N/A	
CRE-BS-WM-00	WM	Water Main	Boiler Room	4/13/2022	0625	P	<1.00	N/A	N/A	
CRE-01-WF-8	WF	Water fountain with filter & cooler	Corridor 100	4/13/2022	0632	P	<1.00	P	<1.00	
CRE-01-WF-9	WF	Water fountain with filter & cooler	Corridor 100	4/13/2022	0633	P	<1.00	P	<1.00	
CRE-01-WF-10	WF	Water fountain with filter & cooler	Corridor 100	4/13/2022	0647	P	<1.00	P	<1.00	
CRE-01-WFC-11	WFC	Filtering water cooler w/ bottle filler	Corridor 100	4/13/2022	0648	P	<1.00	P	<1.00	
CRE-01-CF-15	CF	Classroom faucets	115	4/13/2022	0637	P	<1.00	P	<1.00	
CRE-01-CF-16	CF	Classroom faucets	115	4/13/2022	0640	P	<1.00	P	<1.00	
CRE-01-CF-20	CF	Classroom faucets	105	4/13/2022	0628	P	2.96	P	<1.00	
CRE-01-CF-23	CF	Classroom faucets	101	4/13/2022	0654	P	1.64	P	<1.00	
CRE-01-CF-24	CF	Classroom faucets	101	4/13/2022	0655	P	1.38	P	<1.00	
CRE-01-KF-28	KF	Kitchen faucets	Lobby 119-A	4/13/2022	0659	P	3.03	P	<1.00	
CRE-02-WF-34	WF	Water fountain with filter & cooler	Corridor 200	4/13/2022	0706	P	<1.00	P	<1.00	
CRE-02-WF-35	WF	Water fountain with filter & cooler	Corridor 200	4/13/2022	0707	P	<1.00	P	<1.00	
CRE-02-MS-36	MS	Miscellaneous sinks	Library	4/13/2022	0710	P	<1.00	P	<1.00	
CRE-02-WF-37	WF	Water fountain with filter & cooler	Corridor 200	4/13/2022	0716	P	<1.00	P	<1.00	
CRE-02-WFC-38	WFC	Filtering water cooler w/ bottle filler	Corridor 200	4/13/2022	0717	P	<1.00	P	<1.00	
CRE-02-CF-42	CF	Classroom faucets	207	4/13/2022	0712	P	2.63	P	<1.00	
CRE-03-WF-47	WF	Water fountain with filter & cooler	Corridor 300	4/13/2022	0728	P	<1.00	P	<1.00	
CRE-03-WF-48	WF	Water fountain with filter & cooler	Corridor 300	4/13/2022	0730	P	<1.00	P	<1.00	
CRE-03-CF-49	CF	Classroom faucets	304	4/13/2022	0727	P	4.03	P	1.14	
CRE-03-CF-50	CF	Classroom faucets	303	4/13/2022	0732	P	4.57	P	1.37	
CRE-03-WF-51	WF	Water fountain with filter & cooler	Corridor 300	4/13/2022	0737	P	<1.00	P	<1.00	
CRE-03-WFC-52	WFC	Filtering water cooler w/ bottle filler	Corridor 300	4/13/2022	0738	P	<1.00	P	<1.00	
CRE-02-CF-56	CF	Classroom faucets	207	4/13/2022	0713	P	3.97	P	<1.00	
CRE-03-CF-58	CF	Classroom faucets	303	4/13/2022	0734	F	15.3	P	2.45	Retested and Passed on 4/22/2022
CRE-01-GF-61	GF	Filtered Glass Filler	Boy's Restroom (100)	4/13/2022	0646	P	1.28	P	<1.00	
CRE-01-GF-62	GF	Filtered Glass Filler	Boy's Restroom (100)	4/13/2022	0645	P	2.83	P	<1.00	
CRE-01-GF-63	GF	Filtered Glass Filler	Girl's Restroom (100)	4/13/2022	0650	P	<1.00	P	<1.00	
CRE-01-GF-64	GF	Filtered Glass Filler	Girl's Restroom (100)	4/13/2022	0652	P	<1.00	P	<1.00	
CRE-01-GF-65	GF	Filtered Glass Filler	Room 115	4/13/2022	0636	P	<1.00	P	<1.00	
CRE-01-GF-66	GF	Filtered Glass Filler	Room 115	4/13/2022	0639	P	<1.00	P	<1.00	
CRE-01-GF-67	GF	Filtered Glass Filler	Room 115 Restroom	4/13/2022	0641	P	<1.00	P	<1.00	
CRE-01-GF-68	GF	Filtered Glass Filler	Room 101 Restroom	4/13/2022	0656	P	<1.00	P	<1.00	
CRE-02-GF-70	GF	Filtered Glass Filler	Boy's Restroom (200)	4/13/2022	0704	P	3.89	P	<1.00	
CRE-02-GF-71	GF	Filtered Glass Filler	Boy's Restroom (200)	4/13/2022	0703	P	10.7	P	<1.00	
CRE-02-GF-72	GF	Filtered Glass Filler	Girl's Restroom (200)	4/13/2022	0718	P	<1.00	P	<1.00	
CRE-02-GF-73	GF	Filtered Glass Filler	Girl's Restroom (200)	4/13/2022	0719	P	<1.00	P	<1.00	
CRE-03-GF-74	GF	Filtered Glass Filler	Boy's Restroom (300)	4/13/2022	0724	P	1.01	P	<1.00	
CRE-03-GF-75	GF	Filtered Glass Filler	Boy's Restroom (300)	4/13/2022	0723	P	3.45	P	<1.00	
CRE-03-GF-76	GF	Filtered Glass Filler	Girl's Restroom (300)	4/13/2022	0740	P	5.19	P	<1.00	
CRE-03-GF-77	GF	Filtered Glass Filler	Girl's Restroom (300)	4/13/2022	0741	P	2.21	P	<1.00	

Pittsburgh Cupples Stadium

Lead in Drinking Water Sample Results

School: Pittsburgh Cupples Stadium

Address: 800 E. Carson Street, Pittsburgh, PA 15203

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CUP-GF-SL-00	SL	Service Line	Storage 102	7/7/2022	0559	P	<1.00	N/A	N/A	
CUP-GF-WM-00	WM	Water Main	Storage 102	7/7/2022	0601	P	<1.00	N/A	N/A	
CUP-GF-WF-01	WF	Water fountain with filter & cooler	Men's Restroom (East)	7/7/2022	0558	P	<1.00	P	<1.00	
CUP-GF-WF-04	WF	Water fountain with filter & cooler	Women's Restroom (East)	7/7/2022	0605	P	<1.00	P	<1.00	
CUP-GF-WF-20	WF	Water fountain with filter & cooler	Dressing Room (105)	7/7/2022	0618	P	<1.00	P	<1.00	
CUP-GF-IM-21	IM	Ice machines	Dressing Room (105)	7/7/2022	0620	P	<1.00	N/A	N/A	
CUP-GF-WFC-25	WFC	Filtering water cooler w/ bottle filler	Corridor 109	7/7/2022	0623	P	<1.00	P	<1.00	
CUP-GF-IM-31	IM	Ice machines	Dressing Room (115)	7/7/2022	0628	P	<1.00	N/A	N/A	
CUP-GF-IM-32	IM	Ice machines	Dressing Room (115)							Not in Operation - No Ice
CUP-GF-WF-34	WF	Water fountain with filter & cooler	Dressing Room (115)	7/7/2022	0629	P	<1.00	P	<1.00	
CUP-01-MS-53	MS	Miscellaneous sinks	Press Box	7/7/2022	0635	P	<1.00	P	<1.00	
CUP-GF-IM-58	IM	Ice machines	Concession Stand	7/7/2022	0612	P	<1.00	N/A	N/A	
CUP-GF-KF-59	KF	Kitchen faucets	Concession Stand	7/7/2022	0610	P	1.56	P	<1.00	
CUP-GF-KF-60	KF	Kitchen faucets	Concession Stand	7/7/2022	0611	P	1.56	P	<1.00	
CUP-GF-WF-65	WF	Water fountain with filter & cooler	Public Restroom (201)	7/7/2022	0646	P	<1.00	P	<1.00	
CUP-GF-WF-66	WF	Water fountain with filter & cooler	Public Restroom (203)	7/7/2022	0648	P	<1.00	P	<1.00	
CUP-GF-MS-71	MS	Miscellaneous sinks	Grounds Keeper (110)	7/7/2022	0625	P	4.51	P	<1.00	
CUP-GF-SL-72	SL	Service Line	Public Restroom (202)	7/7/2022	0642	P	5.45	N/A	N/A	
CUP-GF-WM-73	WM	Water Main	Public Restroom (202)	7/7/2022	0645	P	2.18	N/A	N/A	
CUP-GF-WFC-76	WFC	Filtering water cooler w/ bottle filler	Dressing Room (105)	7/7/2022	0619	P	<1.00	P	<1.00	
CUP-GF-WFC-78	WFC	Filtering water cooler w/ bottle filler	Dressing Room (115)	7/7/2022	0630	P	<1.00	P	<1.00	
CUP-GF-WF-80	WF	Water fountain with filter & cooler	Men's Restroom (East)	7/7/2022	0602	P	<1.00	P	<1.00	
CUP-GF-WFC-81	WFC	Filtering water cooler w/ bottle filler	Women's Restroom (East)	7/7/2022	0606	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Faison K-5

Address: 7430 Tioga Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
FAI-01-SL-00	SL	Service Line	133	8/11/2022	0604	P	<1.00	N/A	N/A	
FAI-01-WM-00	WM	Water Main	133	8/11/2022	0607	P	<1.00	N/A	N/A	
FAI-01-KF-03	KF	Kitchen faucets	125A	8/11/2022	0608	P	1.56	P	<1.00	
FAI-01-WF-04	WF	Water fountain with filter & cooler	Café Lobby	8/11/2022	0611	P	<1.00	P	<1.00	
FAI-01-WFC-05	WFC	Filtering water cooler w/ bottle filler	Café Lobby	8/11/2022	0612	P	<1.00	P	<1.00	
FAI-01-MS-16	MS	Miscellaneous sinks	139	8/11/2022	0615	P	1.82	P	<1.00	
FAI-01-WF-17	WF	Water fountain with filter & cooler	Gallery 100	8/11/2022	0617	P	<1.00	P	<1.00	
FAI-01-WFC-18	WFC	Filtering water cooler w/ bottle filler	Gallery 100	8/11/2022	0618	P	<1.00	P	<1.00	
FAI-01-CF-22	CF	Classroom faucets	101	8/11/2022	0621	P	<1.00	P	<1.00	
FAI-01-WF-23	WF	Water fountain with filter & cooler	Outside 105A	8/11/2022	0626	P	<1.00	P	<1.00	
FAI-01-WFC-24	WFC	Filtering water cooler w/ bottle filler	Outside 105A	8/11/2022	0625	P	<1.00	P	<1.00	
FAI-01-MS-27	MS	Miscellaneous sinks	105	8/11/2022	0629	P	<1.00	P	<1.00	
FAI-01-MS-30	MS	Miscellaneous sinks	122A	8/11/2022	0623	P	2.99	P	<1.00	
FAI-01-NF-32	NF	Nurse's office sink faucets	121B	8/11/2022	0633	P	<1.00	P	<1.00	
FAI-01-CF-33	CF	Classroom faucets	119	8/11/2022	0636	P	<1.00	P	<1.00	
FAI-01-CF-34	CF	Classroom faucets	119	8/11/2022	0637	P	<1.00	P	<1.00	
FAI-01-CF-35	CF	Classroom faucets	119	8/11/2022	0638	P	1.02	P	<1.00	
FAI-01-WF-36	WF	Water fountain with filter & cooler	Outside 110A	8/11/2022	0642	P	<1.00	P	<1.00	
FAI-01-WFC-37	WFC	Filtering water cooler w/ bottle filler	Outside 110A	8/11/2022	0641	P	<1.00	P	<1.00	
FAI-01-MS-40	MS	Miscellaneous sinks	110	8/11/2022	0644	P	<1.00	P	<1.00	
FAI-01-MS-44	MS	Miscellaneous sinks	117A	8/11/2022	0646	P	1.06	P	<1.00	
FAI-01-CF-45	CF	Classroom faucets	109	8/11/2022	0648	P	<1.00	P	<1.00	
FAI-01-CF-46	CF	Classroom faucets	111	8/11/2022	0651	P	1.23	P	<1.00	
FAI-01-WF-48	WF	Water fountain with filter & cooler	Outside 115A	8/11/2022	0655	P	<1.00	P	<1.00	
FAI-01-WF-49	WF	Water fountain with filter & cooler	Outside 115A	8/11/2022	0653	P	<1.00	P	<1.00	
FAI-01-MS-52	MS	Miscellaneous sinks	115	8/11/2022	0657	P	1.29	P	<1.00	
FAI-01-CF-57	CF	Classroom faucets	114	8/11/2022	0659	P	1.17	P	<1.00	
FAI-02-WF-59	WF	Water fountain with filter & cooler	Outside 205A	8/11/2022	0705	P	<1.00	P	<1.00	
FAI-02-WFC-60	WFC	Filtering water cooler w/ bottle filler	Outside 205A	8/11/2022	0704	P	<1.00	P	<1.00	
FAI-02-MS-63	MS	Miscellaneous sinks	205	8/11/2022	0707	P	1.33	P	<1.00	
FAI-02-CF-66	CF	Classroom faucets	204	8/11/2022	0710	P	2.20	P	<1.00	
FAI-02-MS-67	MS	Miscellaneous sinks	204A	8/11/2022	0712	P	8.58	P	<1.00	
FAI-02-CF-68	CF	Classroom faucets	206	8/11/2022	0713	P	1.25	P	<1.00	
FAI-02-WF-69	WF	Water fountain with filter & cooler	Outside 210A	8/11/2022	0716	P	<1.00	P	<1.00	
FAI-02-WFC-70	WFC	Filtering water cooler w/ bottle filler	Outside 210A	8/11/2022	0715	P	<1.00	P	<1.00	
FAI-02-MS-73	MS	Miscellaneous sinks	210	8/11/2022	0719	P	1.01	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Faison K-5

Address: 7430 Tioga Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
FAI-02-TF-76	TF	Teacher's lounge sinks	221	8/11/2022	0721	P	5.83	P	<1.00	
FAI-02-WF-82	WF	Water fountain with filter & cooler	Outside 215A	8/11/2022	0724	P	<1.00	P	<1.00	
FAI-02-WFC-83	WFC	Filtering water cooler w/ bottle filler	Outside 215A	8/11/2022	0723	P	<1.00	P	<1.00	
FAI-02-MS-86	MS	Miscellaneous sinks	215	8/11/2022	0727	P	1.88	P	<1.00	
FAI-01-KF-90	KF	Kitchen faucets	125A	8/11/2022	0609	P	1.35	P	<1.00	
FAI-01-GF-93	GF	Filtered Glass Filler	121B	8/11/2022	0632	P	1.04	P	<1.00	

Pittsburgh Greenfield PreK-8

Lead in Drinking Water Sample Results

School: Pittsburgh Greenfield PreK-8

Address: 1 Alger Street, Pittsburgh, PA 15207

Fixture ID	School Code	Building Level	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
GRE-BS-SL-00	GRE	BS	SL	Service Line	Duct Space Under Pool	5/5/2022	0616	P	<1.00	N/A	N/A	
GRE-BS-WM-00	GRE	BS	WM	Water Main	Duct Space Under Pool	5/5/2022	0618	P	<1.00	N/A	N/A	
GRE-BS-MS-02	GRE	BS	MS	Miscellaneous sinks	007	5/5/2022	0615	P	3.98	P	<1.00	
GRE-BS-MS-03	GRE	BS	MS	Miscellaneous sinks	006	5/5/2022	0619	P	1.64	P	<1.00	
GRE-BS-WF-04	GRE	BS	WF	Water fountain with filter and cooler	Pool Deck	5/5/2022	0624	P	<1.00	P	<1.00	
GRE-BS-WF-05	GRE	BS	WF	Water fountain with filter and cooler	Pool Deck	5/5/2022	0625	P	<1.00	P	<1.00	
GRE-01-WF-10	GRE	01	WF	Water fountain with filter & cooler	108	5/5/2022	0639	P	<1.00	P	<1.00	
GRE-01-WC-12	GRE	01	WC	Water fountain with cooler	Corridor 100	5/5/2022	0634	P	<1.00	P	<1.00	
GRE-01-WFC-32	GRE	01	WFC	Filtering water cooler with bottle filler	Corridor 100	5/5/2022	0645	P	<1.00	P	<1.00	
GRE-01-MS-37	GRE	01	MS	Miscellaneous sinks	109A	5/5/2022	0636	F	16.8	P	2.92	Retested on 8/25/2022 and 9/29/2022; Posted Hand Wash Only on 10/13/2022
GRE-01-CF-39	GRE	01	CF	Classroom faucets	112	5/5/2022	0647	P	<1.00	P	1.17	
GRE-01-CF-40	GRE	01	CF	Classroom faucets	102	5/5/2022	0649	P	<1.00	P	<1.00	
GRE-01-KF-41	GRE	01	KF	Kitchen faucets	101	5/5/2022	0650	P	<1.00	P	<1.00	
GRE-01-KF-42	GRE	01	KF	Kitchen faucets	101	5/5/2022	0651	P	<1.00	P	<1.00	
GRE-02-WC-47	GRE	02	WC	Water fountain with cooler	Corridor 200	5/5/2022	0657	P	<1.00	P	<1.00	
GRE-02-MS-48	GRE	02	MS	Miscellaneous sinks	207C	5/5/2022	0700	P	1.14	P	<1.00	
GRE-02-NF-49	GRE	02	NF	Nurse's office sink faucets	210B	5/5/2022	0655	P	<1.00	P	<1.00	
GRE-02-WFC-51	GRE	02	WFC	Filtering water cooler with bottle filler	Corridor 200	5/5/2022	0707	P	<1.00	P	<1.00	
GRE-02-TF-58	GRE	02	TF	Teacher's lounge sinks	213A	5/5/2022	0705	P	<1.00	P	<1.00	
GRE-02-WF-60	GRE	02	WF	Water fountain with filter & cooler	201	5/5/2022	0711	P	<1.00	P	<1.00	
GRE-03-WC-66	GRE	03	WC	Water fountain with cooler	Corridor 300	5/5/2022	0716	P	<1.00	P	<1.00	
GRE-03-CF-67	GRE	03	CF	Classroom faucets	310							Posted Hand Wash Only
GRE-03-CF-69	GRE	03	CF	Classroom faucets	312	5/5/2022	0718	P	5.86	P	4.63	
GRE-03-WFC-70	GRE	03	WFC	Filtering water cooler with bottle filler	Corridor 300	5/5/2022	0722	P	<1.00	P	<1.00	
GRE-BS-WF-76	GRE	BS	WF	Water fountain with filter & cooler	002	5/5/2022	0629	P	<1.00	P	<1.00	
GRE-03-CF-79	GRE	03	CF	Classroom faucets	303	5/5/2022	0720	P	<1.00	P	<1.00	
GRE-BS-WF-80	GRE	BS	WF	Water fountain with filter & cooler	002	5/5/2022	0631	P	<1.00	P	<1.00	
GRE-01-WF-81	GRE	01	WF	Water fountain with filter & cooler	108	5/5/2022	0640	P	<1.00	P	<1.00	
GRE-02-WF-86	GRE	02	WF	Water fountain with filter & cooler	201	5/5/2022	0710	P	<1.00	P	<1.00	
GRE-01-CF-91	GRE	01	CF	Classroom faucets	102	5/5/2022	0644	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh King PreK-8

Address: 50 Montgomery Place, Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
KIN-01-SL-00	SL	Service Line	141	8/27/2022	0656	P	<1.00	N/A	N/A	
KIN-01-WM-00	WM	Water Main	141	8/27/2022	0659	P	<1.00	N/A	N/A	
KIN-01-MS-05	MS	Miscellaneous sinks	111 (G4)	8/27/2022	0709	P	1.52	P	1.65	
KIN-01-CF-06	CF	Classroom faucets	123 (G2)	8/27/2022	0707	P	2.69	P	<1.00	
KIN-01-CF-07	CF	Classroom faucets	119 (G3)	8/27/2022	0714	F	28.9	P	1.50	Retested on 12/7/2022; Posted Hand Wash Only on 1/5/2023
KIN-01-CF-10	CF	Classroom faucets	111 (G4)	8/27/2022	0711	P	5.46	P	1.39	
KIN-01-MS-11	MS	Miscellaneous sinks	139	8/27/2022	0702	P	<1.00	P	<1.00	
KIN-01-WF-13	WF	Water fountain with filter & cooler	Gym Lobby	8/27/2022	0720	P	<1.00	P	<1.00	
KIN-01-WFC-14	WFC	Filtering water cooler w/ bottle filler	Gym Lobby	8/27/2022	0719	P	<1.00	P	<1.00	
KIN-01-WF-15	WF	Water fountain with filter & cooler	Gym Lobby	8/27/2022	0718	P	<1.00	P	<1.00	
KIN-01-WFC-16	WFC	Filtering water cooler w/ bottle filler	Gym Lobby	8/27/2022	0717	P	<1.00	P	<1.00	
KIN-01-WFC-28	WFC	Filtering water cooler w/ bottle filler	176A (G5)	8/27/2022	0736	P	2.05	P	1.15	
KIN-01-MS-29	MS	Miscellaneous sinks	180 (G6A)							Not in Operation - Taken Out of Service
KIN-01-CF-30	CF	Classroom faucets	184 (G8)	8/27/2022	0726	F	34.8	P	2.11	Retested on 12/7/2022; Posted Hand Wash Only on 1/5/2023
KIN-01-WF-31	WF	Water fountain with filter & cooler	Corridor 183	8/27/2022	0725	P	<1.00	P	<1.00	
KIN-01-WFC-32	WFC	Filtering water cooler w/ bottle filler	Corridor 183	8/27/2022	0724	P	<1.00	P	<1.00	
KIN-01-MS-33	MS	Miscellaneous sinks	186 (G9)	8/27/2022	0728	F	15.3	P	3.55	Retested and Passed on 12/7/2022
KIN-02-WF-44	WF	Water fountain with filter & cooler	Cafeteria (223)	8/27/2022	0745	P	<1.00	P	<1.00	
KIN-02-WFC-45	WFC	Filtering water cooler w/ bottle filler	Cafeteria (223)	8/27/2022	0744	P	<1.00	P	<1.00	
KIN-02-WFC-48	WFC	Filtering water cooler w/ bottle filler	221 (P2)	8/27/2022	0801	P	1.92	P	<1.00	
KIN-02-CF-49	CF	Classroom faucets	219 (P3)	12/7/2022	0610	P	9.12	P	1.92	
KIN-02-CF-50	CF	Classroom faucets	219 (P3)	8/27/2022	0759	P	5.99	P	1.44	
KIN-02-CF-51	CF	Classroom faucets	217 (P1)	8/27/2022	0806	P	5.91	P	1.14	
KIN-02-CF-52	CF	Classroom faucets	217 (P1)	8/27/2022	0804	P	11.3	P	2.18	
KIN-02-KF-55	KF	Kitchen faucets	Kitchen (224)	8/27/2022	0743	P	<1.00	P	<1.00	
KIN-02-KF-57	KF	Kitchen faucets	Kitchen (224)	8/27/2022	0742	P	<1.00	P	<1.00	
KIN-02-WF-58	WF	Water fountain with filter & cooler	Cafeteria (223)	8/27/2022	0756	P	<1.00	P	<1.00	
KIN-02-WFC-59	WFC	Filtering water cooler w/ bottle filler	Cafeteria (223)	8/27/2022	0754	P	<1.00	P	<1.00	
KIN-02-NF-60	NF	Nurse's office sink faucets	Nurse's Office (P18A)	8/27/2022	0816	P	8.42	P	<1.00	
KIN-02-WF-66	WF	Water fountain with filter & cooler	Corridor 209	8/27/2022	0822	P	<1.00	P	<1.00	
KIN-02-WFC-67	WFC	Filtering water cooler w/ bottle filler	Corridor 209	8/27/2022	0821	P	<1.00	P	<1.00	
KIN-02-WFC-69	WFC	Filtering water cooler w/ bottle filler	Main Office Corridor (241)	8/27/2022	0810	P	<1.00	P	<1.00	
KIN-02-WFC-76	WFC	Filtering water cooler w/ bottle filler	Main Office (233)	8/27/2022	0819	P	<1.00	P	<1.00	
KIN-02-WF-77	WF	Water fountain with filter & cooler	Corridor 209	8/27/2022	0832	P	<1.00	P	<1.00	
KIN-02-WFC-78	WFC	Filtering water cooler w/ bottle filler	Corridor 209	8/27/2022	0831	P	<1.00	P	<1.00	
KIN-02-CF-80	CF	Classroom faucets	259 (P10)	8/27/2022	0834	F	19.3	P	<1.00	Not in Operation - Taken Out of Service
KIN-02-CF-81	CF	Classroom faucets	259 (P10)							Not in Operation - Taken Out of Service
KIN-02-CF-83	CF	Classroom faucets	261 (P8)	8/27/2022	0838	P	3.85	P	9.16	
KIN-02-CF-84	CF	Classroom faucets	261 (P8)	8/27/2022	0837	F	16.0	P	4.32	Retested and Passed on 12/7/2022
KIN-02-CF-91	CF	Classroom faucets	268 (P15)							Not in Operation - Taken Out of Service
KIN-02-CF-92	CF	Classroom faucets	270 (P13)	8/27/2022	0827	P	1.83	P	<1.00	
KIN-03-CF-96	CF	Classroom faucets	A1	8/27/2022	0917	P	9.92	P	2.03	
KIN-03-CF-97	CF	Classroom faucets	A2	8/27/2022	0915	P	4.28	P	1.81	
KIN-03-CF-98	CF	Classroom faucets	A3	8/27/2022	0912	P	7.05	P	2.46	
KIN-03-CF-99	CF	Classroom faucets	A5	8/27/2022	0910	P	5.12	P	1.08	
KIN-03-CF-100	CF	Classroom faucets	A6	8/27/2022	0908	P	6.36	P	1.00	
KIN-03-CF-101	CF	Classroom faucets	A7	8/27/2022	0906	F	67.4	P	8.17	Retested and Passed on 12/7/2022

Lead in Drinking Water Sample Results

School: Pittsburgh King PreK-8

Address: 50 Montgomery Place, Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
KIN-03-CF-102	CF	Classroom faucets	B1	8/27/2022	0858	P	4.88	P	<1.00	
KIN-03-CF-103	CF	Classroom faucets	B2	8/27/2022	0856	P	9.53	P	2.09	
KIN-03-CF-104	CF	Classroom faucets	B3	8/27/2022	0854	P	4.39	P	<1.00	
KIN-03-CF-105	CF	Classroom faucets	B5	8/27/2022	0852	F	18.6	P	1.97	Retested and Passed on 12/7/2022
KIN-03-CF-106	CF	Classroom faucets	B6	8/27/2022	0850	F	23.7	P	1.92	Retested and Passed on 12/7/2022
KIN-03-CF-107	CF	Classroom faucets	B7	8/27/2022	0848	P	11.0	P	1.93	
KIN-03-WF-113	WF	Water fountain with filter & cooler	Corridor 335	8/27/2022	0921	P	<1.00	P	<1.00	
KIN-03-WFC-114	WFC	Filtering water cooler w/ bottle filler	Corridor 335	8/27/2022	0920	P	<1.00	P	<1.00	
KIN-03-CF-126	CF	Classroom faucets	F3	8/27/2022	0931	P	3.76	P	<1.00	
KIN-03-TF-127	TF	Teacher's lounge sinks	F2	8/27/2022	0933	F	20.4	P	<1.00	Retested and Passed on 12/7/2022
KIN-03-CF-128	CF	Classroom faucets	F1	8/27/2022	0936	P	7.06	P	<1.00	
KIN-03-WF-129	WF	Water fountain with filter & cooler	Corridor 335	8/27/2022	0958	P	<1.00	P	<1.00	
KIN-03-WFC-130	WFC	Filtering water cooler w/ bottle filler	Corridor 335	8/27/2022	0957	P	<1.00	P	<1.00	
KIN-03-CF-134	CF	Classroom faucets	E1	8/27/2022	1000	P	7.93	P	2.86	
KIN-03-CF-135	CF	Classroom faucets	E2	8/27/2022	1003	F	18.8	P	1.57	Retested and Passed on 12/7/2022
KIN-03-CF-136	CF	Classroom faucets	E3	8/27/2022	1005	F	74.0	P	2.46	Retested and Passed on 12/7/2022
KIN-03-CF-137	CF	Classroom faucets	E5	8/27/2022	1007	F	22.9	F	15.3	Retested on 12/7/2022; Posted Hand Wash Only on 1/5/2023
KIN-03-CF-138	CF	Classroom faucets	E6	8/27/2022	1010	F	26.1	F	16.7	Retested and Passed on 12/7/2022
KIN-03-CF-139	CF	Classroom faucets	E7	8/27/2022	1012	P	11.7	P	2.57	
KIN-03-CF-140	CF	Classroom faucets	D1	8/27/2022	0943	P	13.0	P	2.82	
KIN-03-CF-141	CF	Classroom faucets	D2	8/27/2022	0945	P	10.9	P	1.88	
KIN-03-CF-142	CF	Classroom faucets	D3	8/27/2022	0947	P	4.89	P	1.22	
KIN-03-CF-143	CF	Classroom faucets	D5	8/27/2022	0949	P	14.0	P	2.35	
KIN-03-CF-144	CF	Classroom faucets	D6	8/27/2022	0952	F	24.6	P	3.07	Retested on 12/7/2022; Posted Hand Wash Only on 1/5/2023
KIN-03-CF-145	CF	Classroom faucets	D7	8/27/2022	0954	F	24.5	P	2.54	Retested and Passed on 12/7/2022
KIN-03-WF-146	WF	Water fountain with filter & cooler	Corridor 358	8/27/2022	0902	P	<1.00	P	<1.00	
KIN-03-WFC-147	WFC	Filtering water cooler w/ bottle filler	Corridor 358	8/27/2022	0901	P	<1.00	P	<1.00	
KIN-03-CF-159	CF	Classroom faucets	C1	8/27/2022	0924	P	12.8	P	2.20	
KIN-03-CF-160	CF	Classroom faucets	C2	8/27/2022	0926	P	4.77	P	<1.00	
KIN-03-CF-161	CF	Classroom faucets	C3	8/27/2022	0928	F	20.0	P	2.47	Retested and Passed on 12/7/2022
KIN-03-WF-166	WF	Water fountain with filter & cooler	Corridor 358	8/27/2022	0940	P	<1.00	P	<1.00	
KIN-03-WFC-167	WFC	Filtering water cooler w/ bottle filler	Corridor 358	8/27/2022	0939	P	<1.00	P	<1.00	
KIN-01-MS-171	MS	Miscellaneous sinks	181(G6B)	8/27/2022	0733	F	58.7	P	5.94	Retested on 12/7/2022; Posted Hand Wash Only on 1/5/2023
KIN-02-CF-175	CF	Classroom faucets	268 (P15)							Not in Operation - Taken Out of Service
KIN-02-CF-177	CF	Classroom faucets	270 (P13)	8/27/2022	0826	P	7.53	P	1.07	
KIN-01-GF-227	GF	Filtered Glass Filler	111 (G4)	8/27/2022	0710	P	<1.00	P	<1.00	
KIN-02-GF-228	GF	Filtered Glass Filler	Nurse's Office (P18A)	8/27/2022	0815	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Langley K-8

Address: 2940 Sheraden Boulevard, Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
LAN-GF-SL-00	SL	Service Line	4	8/18/2022	0507	P	<1.00	N/A	N/A	
LAN-GF-WM-00	WM	Water Main	4	8/18/2022	0510	P	<1.00	N/A	N/A	
LAN-GF-MS-03	MS	Miscellaneous sinks	Custodian's Office (5)	8/18/2022	0511	P	1.26	P	<1.00	
LAN-GF-CF-14	CF	Classroom faucets	11	8/18/2022	0516	P	1.29	P	<1.00	
LAN-GF-WF-16	WF	Water fountain with filter & cooler	Corridor 01	8/18/2022	0521	P	<1.00	P	<1.00	
LAN-GF-WFC-17	WFC	Filtering water cooler w/ bottle filler	Corridor 01	8/18/2022	0522	P	<1.00	P	<1.00	
LAN-GF-CF-18	CF	Classroom faucets	15	8/18/2022	0524	P	<1.00	P	<1.00	
LAN-GF-CF-19	CF	Classroom faucets	15	8/18/2022	0526	P	<1.00	P	<1.00	
LAN-GF-WF-55	WF	Water fountain with filter & cooler	Corridor 25C	8/18/2022	0533	P	<1.00	P	<1.00	
LAN-GF-WFC-56	WFC	Filtering water cooler w/ bottle filler	Corridor 25C	8/18/2022	0532	P	<1.00	P	<1.00	
LAN-GF-WF-57	WF	Water fountain with filter & cooler	Vestibule (25)	8/18/2022	0536	P	<1.00	P	<1.00	
LAN-GF-WFC-58	WFC	Filtering water cooler w/ bottle filler	Vestibule (25)	8/18/2022	0537	P	<1.00	P	<1.00	
LAN-01-WFC-138	WFC	Filtering water cooler w/ bottle filler	Lobby (145A)	8/18/2022	0548	P	<1.00	P	<1.00	
LAN-01-WF-139	WF	Water fountain with filter & cooler	Corridor 101	8/18/2022	0554	P	<1.00	P	<1.00	
LAN-01-WFC-140	WFC	Filtering water cooler w/ bottle filler	Corridor 101	8/18/2022	0555	P	<1.00	P	<1.00	
LAN-01-MS-141	MS	Miscellaneous sinks	Principal's Office (104)	8/18/2022	0551	P	3.45	P	<1.00	
LAN-01-MS-142	MS	Miscellaneous sinks	Main Office (105)	8/18/2022	0557	P	<1.00	P	<1.00	
LAN-01-WF-149	WF	Water fountain with filter & cooler	Corridor 101	8/18/2022	0600	P	<1.00	P	<1.00	
LAN-01-WFC-150	WFC	Filtering water cooler w/ bottle filler	Corridor 101	8/18/2022	0601	P	<1.00	P	<1.00	
LAN-01-CF-151	CF	Classroom faucets	119	8/18/2022	0603	P	1.97	P	<1.00	
LAN-01-CF-152	CF	Classroom faucets	120	8/18/2022	0604	P	8.68	P	1.16	
LAN-01-CF-156	CF	Classroom faucets	122	8/18/2022	0624	P	3.29	P	<1.00	
LAN-01-CF-157	CF	Classroom faucets	122	8/18/2022	0623	P	2.15	P	<1.00	
LAN-01-CF-158	CF	Classroom faucets	122	8/18/2022	0622	P	2.57	P	<1.00	
LAN-01-WF-162	WF	Water fountain with filter & cooler	Corridor 101C	8/18/2022	0627	P	<1.00	P	<1.00	
LAN-01-WFC-163	WFC	Filtering water cooler w/ bottle filler	Corridor 101C	8/18/2022	0628	P	<1.00	P	<1.00	
LAN-01-CF-170	CF	Classroom faucets	131	8/18/2022	0631	P	2.77	P	<1.00	
LAN-01-CF-171	CF	Classroom faucets	134	8/18/2022	0619	P	1.09	P	<1.00	
LAN-01-WF-173	WF	Water fountain with filter & cooler	Corridor 101B	8/18/2022	0617	P	<1.00	P	<1.00	
LAN-01-WFC-174	WFC	Filtering water cooler w/ bottle filler	Corridor 101B	8/18/2022	0616	P	<1.00	P	<1.00	
LAN-01-NF-177	NF	Nurse's office sink faucets	Health Suite (142)	8/18/2022	0609	P	1.20	P	<1.00	
LAN-01-MS-182	MS	Miscellaneous sinks	Library (137B)	8/18/2022	0613	P	1.60	P	<1.00	
LAN-01-WF-196	WF	Water fountain with filter & cooler	Corridor 146	8/18/2022	0636	P	<1.00	P	<1.00	
LAN-01-WFC-197	WFC	Filtering water cooler w/ bottle filler	Corridor 146	8/18/2022	0637	P	<1.00	P	<1.00	
LAN-01-KF-198	KF	Kitchen faucets	Kitchen (151A)	8/18/2022	0640	P	3.41	P	<1.00	
LAN-01-KF-199	KF	Kitchen faucets	Kitchen (151A)	8/18/2022	0642	P	2.33	P	<1.00	
LAN-01-KF-200	KF	Kitchen faucets	Kitchen (151A)	8/18/2022	0641	P	<1.00	P	<1.00	
LAN-02-CF-202	CF	Classroom faucets	201	8/18/2022	0649	P	2.04	P	<1.00	
LAN-02-CF-203	CF	Classroom faucets	204	12/1/2022	0552	P	3.63	P	1.76	
LAN-02-CF-204	CF	Classroom faucets	204	12/1/2022	0553	P	2.33	P	1.41	
LAN-02-CF-210	CF	Classroom faucets	207	12/1/2022	0557	P	2.92	P	<1.00	
LAN-02-HF-215	HF	Home economics faucets (with cooking)	Home Ec. Room (210)	8/18/2022	0659	P	2.27	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Langley K-8

Address: 2940 Sheraden Boulevard, Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
LAN-02-HF-216	HF	Home economics faucets (with cooking)	Home Ec. Room (210)	8/18/2022	0700	P	3.01	P	<1.00	
LAN-02-HF-217	HF	Home economics faucets (with cooking)	Home Ec. Room (210)	8/18/2022	0701	P	5.39	P	<1.00	
LAN-02-HF-218	HF	Home economics faucets (with cooking)	Home Ec. Room (210)	8/18/2022	0702	P	1.65	P	1.53	
LAN-02-HF-219	HF	Home economics faucets (with cooking)	Home Ec. Room (210)	8/18/2022	0706	P	12.9	P	<1.00	
LAN-02-WF-220	WF	Water fountain with filter & cooler	Corridor 200	8/18/2022	0703	P	<1.00	P	<1.00	
LAN-02-WFC-221	WFC	Filtering water cooler w/ bottle filler	Corridor 200	8/18/2022	0704	P	<1.00	P	<1.00	
LAN-02-CF-228	CF	Classroom faucets	216	8/18/2022	0709	P	<1.00	P	<1.00	
LAN-02-MS-232	MS	Miscellaneous sinks	218	12/1/2022	0601	P	2.17	P	1.95	
LAN-02-CF-233	CF	Classroom faucets	219	8/18/2022	0725	P	4.74	P	1.56	
LAN-02-CF-234	CF	Classroom faucets	219	8/18/2022	0727	P	6.82	P	2.00	
LAN-02-WFC-239	WFC	Filtering water cooler w/ bottle filler	Corridor 200C	8/18/2022	0730	P	<1.00	P	<1.00	
LAN-02-WF-240	WF	Water fountain with filter & cooler	Corridor 200C	8/18/2022	0731	P	<1.00	P	<1.00	
LAN-02-WF-245	WF	Water fountain with filter & cooler	Corridor 200B	8/18/2022	0720	P	<1.00	P	<1.00	
LAN-02-WFC-246	WFC	Filtering water cooler w/ bottle filler	Corridor 200B	8/18/2022	0718	P	<1.00	P	<1.00	
LAN-02-WF-250	WF	Water fountain with filter & cooler	Corridor 236A	8/18/2022	0738	P	<1.00	P	<1.00	
LAN-02-WFC-251	WFC	Filtering water cooler w/ bottle filler	Corridor 236A	8/18/2022	0737	P	<1.00	P	<1.00	
LAN-02-WF-259	WF	Water fountain with filter & cooler	Corridor 236E	8/18/2022	0743	P	<1.00	P	<1.00	
LAN-02-WFC-260	WFC	Filtering water cooler w/ bottle filler	Corridor 236E	8/18/2022	0744	P	<1.00	P	<1.00	
LAN-02-CF-261	CF	Classroom faucets	242	8/18/2022	0747	P	3.47	P	<1.00	
LAN-02-CF-262	CF	Classroom faucets	242	8/18/2022	0746	P	2.55	P	1.14	
LAN-02-CF-263	CF	Classroom faucets	244	8/18/2022	0749	P	1.37	P	<1.00	
LAN-02-CF-264	CF	Classroom faucets	244	8/18/2022	0750	P	2.14	P	1.26	
LAN-02-CF-265	CF	Classroom faucets	248	8/18/2022	0752	P	2.03	P	<1.00	
LAN-02-CF-266	CF	Classroom faucets	248	8/18/2022	0753	P	1.39	P	<1.00	
LAN-03-MS-267	MS	Miscellaneous sinks	301	8/18/2022	0800	P	2.09	P	<1.00	
LAN-02-CF-270	CF	Classroom faucets	207	8/18/2022	0655	P	1.56	P	<1.00	
LAN-02-WF-271	WF	Water fountain with filter & cooler	Corridor 200	8/18/2022	0652	P	<1.00	P	<1.00	
LAN-02-WF-272	WF	Water fountain with filter & cooler	Corridor 200	8/18/2022	0653	P	<1.00	P	<1.00	
LAN-01-CF-274	CF	Classroom faucets	131	8/18/2022	0632	P	<1.00	P	<1.00	
LAN-01-CF-275	CF	Classroom faucets	131	12/1/2022	0546	P	3.56	P	<1.00	
LAN-GF-WF-277	WF	Water fountain with filter & cooler	Corridor 26	8/18/2022	0539	P	<1.00	P	<1.00	
LAN-GF-WFC-278	WFC	Filtering water cooler w/ bottle filler	Corridor 26	8/18/2022	0541	P	<1.00	P	<1.00	
LAN-GF-CF-282	CF	Classroom faucets	11	8/18/2022	0517	P	<1.00	P	<1.00	
LAN-GF-CF-283	CF	Classroom faucets	11	8/18/2022	0518	P	1.50	P	<1.00	
LAN-GF-IM-293	IM	Ice machines	34B	12/1/2022	0535	P	1.96	N/A	N/A	
LAN-02-CF-297	CF	Classroom faucets	256	8/18/2022	0740	P	1.37	P	<1.00	
LAN-01-GF-300	GF	Filtered Glass Filler	Health Suite (142)	8/18/2022	0608	P	<1.00	P	<1.00	
LAN-02-GF-301	GF	Filtered Glass Filler	234	8/18/2022	0714	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Lincoln K-5

Address: 328 Lincoln Avenue, Pittsburgh, PA 15206

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
LIN-BS-SL-00	SL	Service Line	Boiler Room	5/17/2022	0548	P	<1.00	N/A	N/A	
LIN-BS-WM-00	WM	Water Main	Boiler Room	5/17/2022	0551	P	<1.00	N/A	N/A	
LIN-01-TF-03	TF	Teacher's lounge sinks	110	5/17/2022	0553	P	<1.00	P	<1.00	
LIN-01-WF-05	WF	Water fountain with filter & cooler	Corridor 100	5/17/2022	0554	P	<1.00	P	<1.00	
LIN-01-WFC-06	WFC	Filtering water cooler w/ bottle filler	Corridor 100	5/17/2022	0555	P	<1.00	P	<1.00	
LIN-01-NF-11	NF	Nurse's office sink faucets	115	5/17/2022	0558	P	<1.00	P	<1.00	
LIN-01-CF-13	CF	Classroom faucets	117	5/17/2022	0600	P	1.13	P	<1.00	
LIN-01-MS-16	MS	Miscellaneous sinks	136	5/17/2022	0603	P	1.05	P	<1.00	
LIN-01-WF-19	WF	Water fountain with filter & cooler	Corridor 100	5/17/2022	0604	P	<1.00	P	<1.00	
LIN-01-CF-20	CF	Classroom faucets	132	5/17/2022	0609	P	<1.00	P	<1.00	
LIN-01-CF-21	CF	Classroom faucets	132	5/17/2022	0608	P	<1.00	P	<1.00	
LIN-01-KF-22	KF	Kitchen faucets	Kitchen (129)	5/17/2022	0612	P	<1.00	P	<1.00	
LIN-01-WF-23	WF	Water fountain with filter & cooler	Corridor 100G	5/17/2022	0615	P	<1.00	P	<1.00	
LIN-01-WFC-24	WFC	Filtering water cooler w/ bottle filler	Corridor 100G	5/17/2022	0614	P	<1.00	P	<1.00	
LIN-01-KF-25	KF	Kitchen faucets	Kitchen (129)	5/17/2022	0611	P	9.06	P	<1.00	
LIN-02-WF-33	WF	Water fountain with filter & cooler	Corridor 200	5/17/2022	0619	P	<1.00	P	<1.00	
LIN-02-WFC-34	WFC	Filtering Water Cooler w/Bottle Filler	Corridor 200	5/17/2022	0618	P	<1.00	P	<1.00	
LIN-02-CF-37	CF	Classroom faucets	216	5/17/2022	0622	P	1.17	P	<1.00	
LIN-02-CF-40	CF	Classroom faucets	205							Posted Hand Wash Only
LIN-02-CF-41	CF	Classroom faucets	205							Posted Hand Wash Only
LIN-02-WF-44	WF	Water fountain with filter & cooler	Corridor 200	5/17/2022	0624	P	<1.00	P	<1.00	
LIN-03-WF-46	WF	Water fountain with filter & cooler	Corridor 300	5/17/2022	0627	P	<1.00	P	<1.00	
LIN-03-WFC-47	WFC	Filtering water cooler w/ bottle filler	Corridor 300	5/17/2022	0628	P	<1.00	P	<1.00	
LIN-03-CF-50	CF	Classroom faucets	306	5/17/2022	0631	P	<1.00	P	<1.00	
LIN-03-CF-51	CF	Classroom faucets	306	5/17/2022	0632	P	<1.00	P	<1.00	
LIN-03-WF-54	WF	Water fountain with filter & cooler	Corridor 300	5/17/2022	0634	P	<1.00	P	<1.00	
LIN-03-CF-57	CF	Classroom faucets	306	5/17/2022	0630	P	<1.00	P	<1.00	
LIN-01-MS-58	MS	Miscellaneous sinks	107A							Inaccessible - Sink Full of Stored Items
LIN-03-MS-62	MS	Miscellaneous sinks	305							Posted Hand Wash Only
LIN-01-WO-63	WO	Water fountain without cooler	107							Not in Operation
LIN-01-GF-64	GF	Filtered Glass Filler	136	5/17/2022	0602	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Linden K-5

Address: 725 S. Linden Avenue, Pittsburgh, PA 15208

Fixture ID	School Code	Building Level	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
LND-GF-SL-00	LND	GF	SL	Service Line	4	6/23/2022	0605	P	<1.00	N/A	N/A	
LND-GF-WM-00	LND	GF	WM	Water Main	4	6/23/2022	0608	P	<1.00	N/A	N/A	
LND-BS-MS-09	LND	GF	MS	Miscellaneous sinks	1-C	6/23/2022	0609	P	7.39	P	<1.00	
LND-GF-WFC-18	LND	GF	WFC	Filtering water cooler w/ bottle filler	Corridor A	6/23/2022	0612	P	<1.00	P	<1.00	
LND-GF-MS-19	LND	GF	MS	Miscellaneous sinks	Speech Room (3-A)	6/23/2022	0614	P	4.76	P	<1.00	
LND-GF-CF-22	LND	GF	CF	Classroom faucets	10	6/23/2022	0620	P	<1.00	P	<1.00	
LND-01-NF-27	LND	01	NF	Nurse's office sink faucets	102A	6/23/2022	0629	F	17.6	P	3.18	Retested on 9/8/2022; Retested and Passed on 11/4/2022
LND-01-WF-34	LND	01	WF	Water fountain with filter & cooler	Corridor 100	6/23/2022	0635	P	<1.00	P	<1.00	
LND-01-WF-40	LND	01	WF	Water fountain with filter & cooler	Corridor 100	6/23/2022	0639	P	<1.00	P	<1.00	
LND-01-WF-41	LND	01	WF	Water fountain with filter & cooler	Corridor 100	6/23/2022	0640	P	<1.00	P	<1.00	
LND-02-TF-42	LND	02	TF	Teacher's lounge sinks	Teacher's Room (212-B)	6/23/2022	0646	P	1.84	P	<1.00	
LND-02-CF-44	LND	02	CF	Classroom faucets	202	6/23/2022	0644	P	<1.00	P	<1.00	
LND-02-WF-47	LND	02	WF	Water fountain with filter & cooler	Corridor 200	6/23/2022	0648	P	<1.00	P	<1.00	
LND-02-WFC-48	LND	02	WFC	Filtering water cooler w/ bottle filler	Corridor 200	6/23/2022	0649	P	<1.00	P	<1.00	
LND-02-WFC-49	LND	02	WFC	Filtering water cooler w/ bottle filler	Corridor 200	6/23/2022	0651	P	<1.00	P	<1.00	
LND-02-WF-57	LND	02	WF	Water fountain with filter & cooler	Corridor 200	9/8/2022	0614	P	<1.00	P	<1.00	
LND-02-WF-58	LND	02	WF	Water fountain with filter & cooler	Corridor 200	9/8/2022	0615	P	<1.00	P	<1.00	
LND-BS-CF-63	LND	GF	CF	Classroom faucets	12	6/23/2022	0616	P	<1.00	P	<1.00	
LND-01-WFC-65	LND	01	WFC	Filtering water cooler w/ bottle filler	Corridor 100	6/23/2022	0636	P	<1.00	P	<1.00	
LND-02-MS-67	LND	02	MS	Miscellaneous sinks	202A							Posted Hand Wash Only
LND-BS-WFC-69	LND	BS	WFC	Filtering water cooler w/ bottle filler	Gym	6/23/2022	0623	P	<1.00	P	<1.00	
LND-BS-WF-70	LND	BS	WF	Water fountain with filter & cooler	Gym	6/23/2022	0624	P	<1.00	P	<1.00	
LND-GF-WFC-73	LND	GF	WFC	Filtering water cooler w/ bottle filler	Between Rooms 10 and 12	6/23/2022	0619	P	<1.00	P	<1.00	
LND-01-WF-75	LND	01	WF	Water fountain with filter & cooler	Corridor 100	6/23/2022	0631	P	<1.00	P	<1.00	
LND-01-WF-76	LND	01	WF	Water fountain with filter & cooler	Corridor 100	6/23/2022	0633	P	<1.00	P	<1.00	

Pittsburgh Manchester PreK-8

Lead in Drinking Water Sample Results

School: Pittsburgh Manchester PreK-8

Address: 1612 Manhattan Street, Pittsburgh, PA 15233

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MAN-01-SL-00	SL	Service Line	Boiler Room	8/10/2022	0609	P	<1.00	N/A	N/A	
MAN-01-WM-00	WM	Water Main	Boiler Room	8/10/2022	0612	P	<1.00	N/A	N/A	
MAN-01-MS-03	MS	Miscellaneous sinks	115	8/10/2022	0613	P	<1.00	P	<1.00	
MAN-01-WFC-04	WFC	Filtering water cooler w/ bottle filler	Corridor 120	8/10/2022	0615	P	<1.00	P	<1.00	
MAN-01-CF-05	CF	Classroom faucets	114	8/10/2022	0617	P	6.71	P	1.20	
MAN-01-CF-06	CF	Classroom faucets	113	8/10/2022	0631	P	2.52	P	<1.00	
MAN-01-KF-08	KF	Kitchen faucets	111	8/10/2022	0637	P	2.75	P	<1.00	
MAN-01-NF-10	NF	Nurse's office sink faucets	112	8/10/2022	0634	P	<1.00	P	<1.00	
MAN-01-CF-12	CF	Classroom faucets	106	8/10/2022	0639	P	2.16	P	<1.00	
MAN-01-WF-22	WF	Water fountain with filter & cooler	Corridor 148	8/10/2022	0624	P	<1.00	P	<1.00	
MAN-01-CF-31	CF	Classroom faucets	128	8/10/2022	0620	P	1.27	P	<1.00	
MAN-01-CF-32	CF	Classroom faucets	127	8/10/2022	0627	P	9.29	P	1.72	
MAN-01-CF-34	CF	Classroom faucets	149	8/10/2022	0643	P	5.90	P	<1.00	
MAN-01-CF-35	CF	Classroom faucets	150	8/10/2022	0646	P	1.70	P	<1.00	
MAN-01-WF-36	WF	Water fountain with filter & cooler	Corridor 154	8/10/2022	0649	P	<1.00	P	<1.00	
MAN-01-CF-37	CF	Classroom faucets	151	8/10/2022	0648	P	2.45	P	<1.00	
MAN-01-CF-38	CF	Classroom faucets	152	8/10/2022	0652	P	2.77	P	<1.00	
MAN-01-MS-40	MS	Miscellaneous sinks	Corridor 157	8/10/2022	0659	P	5.94	P	<1.00	
MAN-01-TF-42	TF	Teacher's lounge sinks	163	8/10/2022	0657	P	1.21	P	<1.00	
MAN-01-WF-43	WF	Water fountain with filter & cooler	Corridor 108	8/10/2022	0654	P	<1.00	P	<1.00	
MAN-02-WFC-45	WFC	Filtering water cooler w/ bottle filler	Corridor 220	8/10/2022	0710	P	<1.00	P	<1.00	
MAN-02-CF-46	CF	Classroom faucets	212	8/10/2022	0725	P	5.47	P	<1.00	
MAN-02-TF-48	TF	Teacher's lounge sinks	207	8/10/2022	0727	P	8.09	P	<1.00	
MAN-02-CF-49	CF	Classroom faucets	201	10/7/2022	0550	F	18.8	P	1.55	Faucet Replaced on 8/18/2022; Posted Hand Wash Only on 10/13/2022
MAN-02-WF-51	WF	Water fountain with filter & cooler	Corridor 213	8/10/2022	0730	P	<1.00	P	<1.00	
MAN-02-MS-53	MS	Miscellaneous sinks	222	8/10/2022	0704	P	12.5	P	3.33	
MAN-02-WF-58	WF	Water fountain with filter & cooler	Corridor 237	8/10/2022	0708	P	<1.00	P	<1.00	
MAN-02-CF-65	CF	Classroom faucets	239	8/10/2022	0715	P	9.34	P	1.17	
MAN-02-CF-67	CF	Classroom faucets	241	8/10/2022	0718	P	9.67	P	1.45	
MAN-02-CF-68	CF	Classroom faucets	242	8/10/2022	0722	P	6.87	P	1.24	
MAN-02-WF-69	WF	Water fountain with filter & cooler	Corridor 244	8/10/2022	0720	P	<1.00	P	<1.00	
MAN-02-CF-70	CF	Classroom faucets	200	8/10/2022	0735	P	6.09	P	<1.00	
MAN-02-CF-74	CF	Classroom faucets	225	8/10/2022	0713	P	4.22	P	<1.00	
MAN-02-CF-76	CF	Classroom faucets	205	8/10/2022	0737	P	11.3	P	1.33	
MAN-01-WFC-96	WFC	Filtering water cooler w/ bottle filler	Corridor 108	8/10/2022	0655	P	<1.00	P	<1.00	
MAN-01-WFC-97	WFC	Filtering water cooler w/ bottle filler	Corridor 148	8/10/2022	0623	P	<1.00	P	<1.00	
MAN-02-WFC-100	WFC	Filtering water cooler w/ bottle filler	Corridor 213	8/10/2022	0731	P	<1.00	P	<1.00	
MAN-02-WFC-102	WFC	Filtering water cooler w/ bottle filler	Corridor 237	8/10/2022	0706	P	<1.00	P	<1.00	
MAN-01-GF-103	GF	Filtered Glass Filler	128	8/10/2022	0621	P	<1.00	P	<1.00	
MAN-01-GF-104	GF	Filtered Glass Filler	112	8/10/2022	0633	P	<1.00	P	<1.00	
MAN-02-GF-105	GF	Filtered Glass Filler	207	8/10/2022	0728	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Miller PreK-5

Address: 2055 Bedford Avenue, Pittsburgh, PA 15219

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MIL-GF-SL-00	SL	Service Line	17A	4/27/2022	0610	P	<1.00	N/A	N/A	
MIL-GF-WM-00	WM	Water Main	17A	4/27/2022	0612	P	<1.00	N/A	N/A	
MIL-GF-WF-01	WF	Water fountain with filter & cooler	Corridor 1A	4/27/2022	0609	P	<1.00	P	<1.00	
MIL-GF-WFC-02	WFC	Filtering water cooler w/ bottle filler	Corridor 1A	4/27/2022	0613	P	<1.00	P	<1.00	
MIL-GF-KF-09	KF	Kitchen faucets	Kitchen (2)	4/27/2022	0616	P	1.11	P	<1.00	
MIL-GF-CF-12	CF	Classroom faucets	17	4/27/2022	0620	P	<1.00	P	<1.00	
MIL-GF-CF-13	CF	Classroom faucets	16	4/27/2022	0623	P	<1.00	P	<1.00	
MIL-GF-CF-15	CF	Classroom faucets	15	4/27/2022	0628	P	<1.00	P	<1.00	
MIL-GF-MS-17	MS	Miscellaneous sinks	7	4/27/2022	0625	P	<1.00	P	<1.00	
MIL-GF-WF-20	WF	Water fountain with filter & cooler	Corridor 1	4/27/2022	0630	P	<1.00	P	<1.00	
MIL-GF-WF-21	WF	Water fountain with filter & cooler	Corridor 1	4/27/2022	0631	P	<1.00	P	<1.00	
MIL-GF-CF-29	CF	Classroom faucets	11	4/27/2022	0635	P	1.77	P	<1.00	
MIL-01-TF-30	TF	Teacher's lounge sinks	117	4/27/2022	0639	P	<1.00	P	<1.00	
MIL-01-NF-33	NF	Nurse's office sink faucets	Nurse (105)	4/27/2022	0641	P	<1.00	P	<1.00	
MIL-01-CF-34	CF	Classroom faucets	114A	4/27/2022	0644	P	9.72	P	<1.00	
MIL-01-CF-35	CF	Classroom faucets	106A	4/27/2022	0645	P	6.01	P	<1.00	
MIL-01-CF-36	CF	Classroom faucets	113A	4/27/2022	0648	F	16.2	P	9.52	Retested and Passed on 7/27/2022
MIL-01-CF-39	CF	Classroom faucets	112A	4/27/2022	0652	P	1.79	P	<1.00	
MIL-01-CF-40	CF	Classroom faucets	107A	4/27/2022	0650	P	3.33	P	<1.00	
MIL-01-WF-44	WF	Water fountain with filter & cooler	Corridor 100	4/27/2022	0654	P	<1.00	P	<1.00	
MIL-01-WFC-45	WFC	Filtering water cooler w/ bottle filler	Corridor 100	4/27/2022	0655	P	<1.00	P	<1.00	
MIL-01-CF-49	CF	Classroom faucets	110	4/27/2022	0656	P	5.82	P	<1.00	
MIL-02-CF-50	CF	Classroom faucets	202A	4/27/2022	0700	P	5.76	P	1.99	
MIL-02-MS-51	MS	Miscellaneous sinks	203	4/27/2022	0702	P	8.59	P	1.00	
MIL-02-CF-53	CF	Classroom faucets	211A	4/27/2022	0704	P	1.90	P	<1.00	
MIL-02-CF-55	CF	Classroom faucets	210A							Posted Hand Wash Only and Cold Water is Shut Off
MIL-02-CF-57	CF	Classroom faucets	209A	4/27/2022	0708	P	1.10	P	<1.00	
MIL-02-CF-59	CF	Classroom faucets	206	4/27/2022	0706	P	10.7	P	1.06	
MIL-02-WF-63	WF	Water fountain with filter & cooler	Corridor 200	4/27/2022	0710	P	<1.00	P	<1.00	
MIL-02-WFC-64	WFC	Filtering water cooler w/ bottle filler	Corridor 200	4/27/2022	0711	P	<1.00	P	<1.00	
MIL-GF-KF-68	KF	Kitchen faucets	Kitchen (2)	4/27/2022	0615	P	1.00	P	<1.00	
MIL-GF-WB-70	WB	Water fountain bubbler (Ceramic or Porcelain)	11							Not in Operation
MIL-GF-GF-71	GF	Filtered Glass Filler	17	4/27/2022	0619	P	<1.00	P	<1.00	
MIL-GF-GF-72	GF	Filtered Glass Filler	16	4/27/2022	0622	P	<1.00	P	<1.00	
MIL-GF-GF-73	GF	Filtered Glass Filler	15	4/27/2022	0627	P	<1.00	P	<1.00	

Pittsburgh Millions 6-12

Lead in Drinking Water Sample Results

School: Pittsburgh Milliones 6-12

Address: 3117 Centre Avenue, Pittsburgh, PA 15219

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MLO-02-SL-00	SL	Service Line	259	5/28/2022	0734	P	<1.00	N/A	N/A	
MLO-02-WM-00	WM	Water Main	259	5/28/2022	0737	P	<1.00	N/A	N/A	
MLO-02-NF-03	NF	Nurse's office sink faucets	251	5/28/2022	0739	P	4.49	P	1.01	
MLO-02-NF-04	NF	Nurse's office sink faucets	253	5/28/2022	0741	P	6.50	P	<1.00	
MLO-02-WFC-09	WFC	Filtering water cooler w/ bottle filler	Corridor 240	5/28/2022	0745	P	<1.00	P	<1.00	
MLO-02-WF-13	WF	Water fountain with filter & cooler	242	5/28/2022	0748	P	<1.00	P	<1.00	
MLO-02-CF-28	CF	Classroom faucets	223	5/28/2022	0751	P	1.87	P	<1.00	
MLO-02-WF-36	WF	Water fountain with filter & cooler	220	5/28/2022	0754	P	<1.00	P	<1.00	
MLO-02-WFC-41	WFC	Filtering water cooler w/ bottle filler	Corridor 221	5/28/2022	0756	P	<1.00	P	<1.00	
MLO-02-KF-45	KF	Kitchen faucets	Kitchen (234)	5/28/2022	0759	P	4.03	P	<1.00	
MLO-02-KF-47	KF	Kitchen faucets	Kitchen (234)	5/28/2022	0801	P	1.10	P	<1.00	
MLO-02-IM-49	IM	Ice machines	Kitchen (234)							Not in Operation - No Ice
MLO-01-MS-55	MS	Miscellaneous sinks	118	5/28/2022	0808	P	<1.00	P	<1.00	
MLO-01-WFC-57	WFC	Filtering water cooler w/ bottle filler	Corridor 129	5/28/2022	0807	P	<1.00	P	<1.00	
MLO-01-WFC-64	WFC	Filtering water cooler w/ bottle filler	Corridor 111	5/28/2022	0815	P	<1.00	P	<1.00	
MLO-01-CF-66	CF	Classroom faucets	110	5/28/2022	0817	P	<1.00	P	<1.00	
MLO-01-CF-67	CF	Classroom faucets	110	5/28/2022	0820	P	<1.00	P	<1.00	
MLO-01-CF-68	CF	Classroom faucets	110	5/28/2022	0822	P	<1.00	P	<1.00	
MLO-03-WF-80	WF	Water fountain with filter & cooler	Corridor 353	11/10/2022	0600	P	<1.00	P	<1.00	
MLO-03-WFC-87	WFC	Filtering water cooler w/ bottle filler	Corridor 329	5/28/2022	0832	P	<1.00	P	<1.00	
MLO-04-TF-116	TF	Teacher's lounge sinks	437	5/28/2022	0845	P	2.54	P	<1.00	
MLO-04-MS-119	MS	Miscellaneous sinks	430-A	5/28/2022	0842	P	<1.00	P	<1.00	
MLO-04-WFC-123	WFC	Filtering water cooler w/ bottle filler	Corridor 426	5/28/2022	0847	P	<1.00	P	<1.00	
MLO-04-WF-124	WF	Water fountain with filter & cooler	Corridor 415	5/28/2022	0850	P	<1.00	P	<1.00	
MLO-05-WFC-149	WFC	Filtering water cooler w/ bottle filler	Corridor 508	5/28/2022	0854	P	<1.00	P	<1.00	
MLO-05-CF-154	CF	Classroom faucets	500A	5/28/2022	0856	P	6.21	P	<1.00	
MLO-05-CF-155	CF	Classroom faucets	517	5/28/2022	0859	P	2.10	P	2.25	
MLO-05-WF-156	WF	Water fountain with filter & cooler	Corridor 505A	5/28/2022	0901	P	<1.00	P	<1.00	
MLO-02-KF-161	KF	Kitchen faucets	Kitchen (234)	5/28/2022	0802	P	1.25	P	<1.00	
MLO-03-CF-163	CF	Classroom faucets	331	5/28/2022	0829	P	3.13	P	<1.00	
MLO-02-GF-175	GF	Filtered Glass Filler	251	5/28/2022	0740	P	<1.00	P	<1.00	
MLO-02-GF-176	GF	Filtered Glass Filler	253	5/28/2022	0742	P	<1.00	P	<1.00	
MLO-01-GF-177	GF	Filtered Glass Filler	110	5/28/2022	0818	P	<1.00	P	<1.00	
MLO-01-GF-178	GF	Filtered Glass Filler	110	5/28/2022	0821	P	<1.00	P	<1.00	
MLO-01-GF-179	GF	Filtered Glass Filler	110	5/28/2022	0823	P	<1.00	P	<1.00	

Pittsburgh Montessori PreK-5

Lead in Drinking Water Sample Results

School: Pittsburgh Montessori PreK-5

Address: 201 S. Graham Street, Pittsburgh, PA 15206

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MON-BS-SL-00	SL	Service Line	01	4/20/2022	0607	P	<1.00	N/A	N/A	
MON-BS-WM-00	WM	Water Main	01	4/20/2022	0609	P	<1.00	N/A	N/A	
MON-BS-TF-1	TF	Teacher's lounge sinks	Former Nurse's Office	4/20/2022	0606	P	1.99	P	<1.00	
MON-BS-CF-2	CF	Classroom faucets	Outside 09	4/20/2022	0611	P	<1.00	P	<1.00	
MON-BS-OF-04	OF	Office sink faucets	Custodian's Office	4/20/2022	0614	P	1.25	P	<1.00	
MON-BS-CF-5	CF	Classroom faucets	10	4/20/2022	0613	P	6.35	P	<1.00	
MON-GF-CF-8	CF	Classroom faucets	Demountable Room 2	4/20/2022	0705	P	1.35	P	<1.00	
MON-GF-CF-10	CF	Classroom faucets	Demountable Room 1	4/20/2022	0707	P	<1.00	P	<1.00	
MON-01-MS-11	MS	Miscellaneous sinks	103	4/20/2022	0620	P	2.99	P	<1.00	
MON-01-WF-15	WF	Water fountain with filter & cooler	Corridor 100	4/20/2022	0617	P	<1.00	P	<1.00	
MON-01-WF-16	WF	Water fountain with filter & cooler	Corridor 100	4/20/2022	0618	P	<1.00	P	<1.00	
MON-01-CF-20	CF	Classroom faucets	104	4/20/2022	0623	P	3.05	P	<1.00	
MON-01-WF-21	WF	Water fountain with filter & cooler	Corridor 100A	4/20/2022	0626	P	<1.00	P	<1.00	
MON-01-WFC-22	WFC	Filtering water cooler w/ bottle filler	Corridor 100A	4/20/2022	0625	P	<1.00	P	<1.00	
MON-01-KF-26	KF	Kitchen faucets	111B	4/20/2022	0627	P	<1.00	P	<1.00	
MON-01-OF-27	OF	Office sink faucets	107 Storage	4/20/2022	0630	P	3.02	P	<1.00	
MON-01-CF-28	CF	Classroom faucets	109	4/20/2022	0632	P	2.00	P	<1.00	
MON-01-WF-29	WF	Water fountain with filter & cooler	Corridor 100	4/20/2022	0634	P	<1.00	P	<1.00	
MON-01-WFC-30	WFC	Filtering water cooler w/ bottle filler	Corridor 100	4/20/2022	0633	P	<1.00	P	<1.00	
MON-02-CF-34	CF	Classroom faucets	201	4/20/2022	0638	P	2.22	P	<1.00	
MON-02-CF-35	CF	Classroom faucets	203A	4/20/2022	0643	P	4.91	P	<1.00	
MON-02-WF-36	WF	Water fountain with filter & cooler	Corridor 200	4/20/2022	0640	P	<1.00	P	<1.00	
MON-02-WFC-37	WFC	Filtering water cooler w/ bottle filler	Corridor 200	4/20/2022	0641	P	<1.00	P	<1.00	
MON-02-NF-40	NF	Nurse's office sink faucets	205	4/20/2022	0645	P	<1.00	P	<1.00	
MON-02-CF-42	CF	Classroom faucets	207A	4/20/2022	0648	P	12.5	P	1.82	
MON-02-CF-43	CF	Classroom faucets	209A	4/20/2022	0652	P	3.18	P	<1.00	
MON-02-WF-44	WF	Water fountain with filter & cooler	Corridor 200	4/20/2022	0649	P	<1.00	P	<1.00	
MON-02-WF-45	WF	Water fountain with filter & cooler	Corridor 200	4/20/2022	0650	P	<1.00	P	<1.00	
MON-01-CF-49	CF	Classroom faucets	103	4/20/2022	0621	P	<1.00	P	<1.00	
MON-GF-WC-51	WC	Water fountain with cooler	Demountable Room 1	4/29/2022	0603	P	<1.00	P	<1.00	
MON-GF-GF-53	GF	Filtered Glass Filler	Demountable Room 2	4/20/2022	0706	P	<1.00	P	<1.00	
MON-GF-GF-54	GF	Filtered Glass Filler	Demountable Room 1	4/20/2022	0708	P	<1.00	P	<1.00	
MON-02-GF-56	GF	Filtered Glass Filler	205	4/20/2022	0644	P	<1.00	P	<1.00	
MON-GF-WC-57	WC	Water fountain with cooler	Demountable Room 2	4/29/2022	0606	P	<1.00	P	<1.00	
MON-GF-SL-58	SL	Service Line	Demountable Room 2 - Utility Room	4/20/2022	0701	P	<1.00	N/A	N/A	
MON-GF-WM-58	WM	Water Main	Demountable Room 2 - Utility Room	4/20/2022	0704	P	<1.00	N/A	N/A	

Pittsburgh Morrow Intermediate 5-8

Lead in Drinking Water Sample Results

School: Pittsburgh Morrow Intermediate 5-8

Address: 3530 Fleming Avenue, Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MRN-BS-SL-00	SL	Service Line	018	7/6/2022	0604	P	<1.00	N/A	N/A	
MRN-BS-WM-00	WM	Water Main	018	7/6/2022	0606	P	<1.00	N/A	N/A	
MRN-BS-CF-01	CF	Classroom faucets	002A	7/6/2022	0614	P	4.93	P	<1.00	
MRN-BS-CF-02	CF	Classroom faucets	002	7/6/2022	0612	P	<1.00	P	<1.00	
MRN-BS-CF-03	CF	Classroom faucets	002	7/6/2022	0611	P	<1.00	P	<1.00	
MRN-BS-CF-05	CF	Classroom faucets	001	7/6/2022	0603	P	<1.00	P	<1.00	
MRN-BS-CF-06	CF	Classroom faucets	001	7/6/2022	0607	P	<1.00	P	<1.00	
MRN-BS-CF-07	CF	Classroom faucets	001A	7/6/2022	0608	P	2.95	P	<1.00	
MRN-BS-WF-12	WF	Water fountain with filter & cooler	Corridor 022	7/6/2022	0616	P	<1.00	P	<1.00	
MRN-BS-WF-14	WF	Water fountain with filter & cooler	Corridor 022	7/6/2022	0623	P	<1.00	P	<1.00	
MRN-BS-CF-18	CF	Classroom faucets	003	7/6/2022	0625	P	<1.00	P	<1.00	
MRN-BS-CF-19	CF	Classroom faucets	003	7/6/2022	0626	P	1.06	P	<1.00	
MRN-BS-KF-24	KF	Kitchen faucets	Food Prep (033)	7/6/2022	0618	P	2.27	P	<1.00	
MRN-BS-KF-25	KF	Kitchen faucets	Food Prep (033)	7/6/2022	0619	P	1.79	P	<1.00	
MRN-BS-IM-26	IM	Ice machines	031	7/6/2022	0621	P	<1.00	N/A	N/A	
MRN-BS-WF-37	WF	Water fountain with filter & cooler	Corridor B100	7/6/2022	0629	P	<1.00	P	<1.00	
MRN-BS-WFC-38	WFC	Filtering water cooler w/ bottle filler	Corridor B100	7/6/2022	0630	P	<1.00	P	<1.00	
MRN-01-WF-51	WF	Water fountain with filter & cooler	Corridor 114	7/6/2022	0634	P	<1.00	P	<1.00	
MRN-01-WF-61	WF	Water fountain with filter & cooler	Corridor 114	7/6/2022	0642	P	<1.00	P	<1.00	
MRN-02-WF-65	WF	Water fountain with filter & cooler	Corridor 218	7/6/2022	0645	P	<1.00	P	<1.00	
MRN-02-HF-68	HF	Home economics faucets (with cooking)	209	7/6/2022	0647	P	<1.00	P	<1.00	
MRN-02-HF-69	HF	Home economics faucets (with cooking)	209	7/6/2022	0648	P	<1.00	P	<1.00	
MRN-02-HF-70	HF	Home economics faucets (with cooking)	209	7/6/2022	0650	P	1.44	P	<1.00	
MRN-02-HF-71	HF	Home economics faucets (with cooking)	209	7/6/2022	0651	P	<1.00	P	<1.00	
MRN-02-MS-72	MS	Miscellaneous sinks	208A	7/6/2022	0653	P	<1.00	P	<1.00	
MRN-02-WF-76	WF	Water fountain with filter & cooler	Corridor 218	7/6/2022	0655	P	<1.00	P	<1.00	
MRN-03-WF-78	WF	Water fountain with filter & cooler	Corridor 312	7/6/2022	0658	P	<1.00	P	<1.00	
MRN-03-WF-79	WF	Water fountain with filter & cooler	Corridor 303	7/6/2022	0702	P	<1.00	P	<1.00	
MRN-03-MS-80	MS	Miscellaneous sinks	302	7/6/2022	0700	P	<1.00	P	<1.00	
MRN-01-NF-85	NF	Nurse's office sink faucets	109	7/6/2022	0638	P	<1.00	P	<1.00	
MRN-01-NF-86	NF	Nurse's office sink faucets	109B	7/6/2022	0640	P	1.39	P	<1.00	
MRN-01-WFC-87	WFC	Filtering water cooler w/ bottle filler	Corridor 114	7/6/2022	0635	P	<1.00	P	<1.00	
MRN-02-WFC-88	WFC	Filtering water cooler w/ bottle filler	Corridor 218	7/6/2022	0656	P	<1.00	P	<1.00	

Pittsburgh Morrow PreK-4

Lead in Drinking Water Sample Results

School: Pittsburgh Morrow PreK-4

Address: 1611 Davis Avenue, Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MOR-BS-SL-00	SL	Service Line	Fan Room (4A)	4/26/2022	0555	P	2.11	N/A	N/A	
MOR-BS-WM-00	WM	Water Main	Fan Room (4A)	4/26/2022	0557	P	<1.00	N/A	N/A	
MOR-BS-WF-1	WF	Water fountain with filter & cooler	Corridor 1B	5/18/2022	0600	P	<1.00	P	<1.00	
MOR-BS-WF-8	WF	Water fountain with filter & cooler	Corridor 1	4/26/2022	0600	P	<1.00	P	<1.00	
MOR-BS-WF-9	WF	Water fountain with filter & cooler	Corridor 1	4/26/2022	0559	P	<1.00	P	<1.00	
MOR-BS-MS-10	MS	Miscellaneous sinks	Custodian's Office (6)	4/26/2022	0602	P	<1.00	P	2.10	
MOR-BS-CF-12	CF	Classroom faucets	Shop (8)	4/26/2022	0604	P	4.12	P	1.13	
MOR-BS-CF-13	CF	Classroom faucets	Shop (8)	4/26/2022	0605	P	2.32	P	1.34	
MOR-BS-WF-17	WF	Water fountain with filter & cooler	Corridor 1G	4/26/2022	0607	P	<1.00	P	<1.00	
MOR-BS-WFC-18	WFC	Filtering water cooler w/ bottle filler	Corridor 1G	4/26/2022	0608	P	<1.00	P	<1.00	
MOR-BS-WB-19	WB	Water fountain bubbler (Ceramic or Porcelain)	19A							Not in Operation - Capped
MOR-BS-CF-21	CF	Classroom faucets	19B	4/26/2022	0610	P	<1.00	P	<1.00	
MOR-01-CF-24	CF	Classroom faucets	105							Posted Hand Wash Only
MOR-01-CF-25	CF	Classroom faucets	104	4/26/2022	0615	P	5.37	P	<1.00	
MOR-01-WF-26	WF	Water fountain with filter & cooler	Corridor 100A	4/26/2022	0613	P	<1.00	P	<1.00	
MOR-01-CF-28	CF	Classroom faucets	102	4/26/2022	0617	P	10.3	P	2.89	
MOR-01-CF-29	CF	Classroom faucets	101	4/26/2022	0619	F	73.2	P	6.65	Retested and Passed on 5/18/2022
MOR-01-WF-30	WF	Water fountain with filter & cooler	Corridor 100	4/26/2022	0622	P	<1.00	P	<1.00	
MOR-01-WF-31	WF	Water fountain with filter & cooler	Corridor 100	4/26/2022	0621	P	<1.00	P	<1.00	
MOR-01-NF-34	NF	Nurse's office sink faucets	109	4/26/2022	0626	P	7.68	P	1.12	
MOR-01-CF-37	CF	Classroom faucets	108	4/26/2022	0628	P	7.26	P	2.56	
MOR-01-WF-41	WF	Water fountain with filter & cooler	Corridor 100	4/26/2022	0630	P	<1.00	P	<1.00	
MOR-01-WFC-42	WFC	Filtering water cooler w/ bottle filler	Corridor 100	4/26/2022	0631	P	<1.00	P	<1.00	
MOR-01-MS-43	MS	Miscellaneous sinks	Library (118)	4/26/2022	0634	P	1.31	P	1.19	
MOR-01-CF-44	CF	Classroom faucets	116	4/26/2022	0636	P	1.68	P	<1.00	
MOR-02-CF-45	CF	Classroom faucets	205	4/26/2022	0640	P	5.98	P	<1.00	
MOR-02-CF-46	CF	Classroom faucets	204	4/26/2022	0643	P	3.83	P	<1.00	
MOR-02-CF-47	CF	Classroom faucets	207	4/26/2022	0645	F	16.0	P	5.40	Retested and Passed on 5/18/2022
MOR-02-CF-48	CF	Classroom faucets	201	4/26/2022	0646	P	7.79	P	9.80	
MOR-02-WF-49	WF	Water fountain with filter & cooler	Corridor 200	4/26/2022	0648	P	<1.00	P	<1.00	
MOR-02-WF-50	WF	Water fountain with filter & cooler	Corridor 200	4/26/2022	0649	P	<1.00	P	<1.00	
MOR-02-OF-53	OF	Office sink faucets	209	4/26/2022	0651	P	4.63	P	<1.00	
MOR-02-WF-58	WF	Water fountain with filter & cooler	Corridor 200	4/26/2022	0652	P	<1.00	P	<1.00	
MOR-02-WFC-59	WFC	Filtering water cooler w/ bottle filler	Corridor 200	4/26/2022	0653	P	<1.00	P	<1.00	
MOR-02-WF-61	WF	Water fountain with filter & cooler	Corridor 200F	4/26/2022	0655	P	<1.00	P	<1.00	
MOR-02-CF-63	CF	Classroom faucets	218A	4/26/2022	0656	P	1.60	P	3.99	
MOR-01-CF-64	CF	Classroom faucets	106	4/26/2022	0625	P	8.06	P	2.72	
MOR-02-WF-67	WF	Water fountain with filter & cooler	Corridor 200A	4/26/2022	0641	P	<1.00	P	<1.00	
MOR-01-OF-71	OF	Office sink faucets	114B	4/26/2022	0632	P	1.57	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Online Academy (South Annex)

Address: 93 S. 10th Street, Pittsburgh, PA 15203

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SOU-BS-SL-00	SL	Service Line	Utility Room (5)	7/12/2022	0603	P	<1.00	N/A	N/A	
SOU-BS-WM-00	WM	Water Main	Utility Room (5)	7/12/2022	0606	P	<1.00	N/A	N/A	
SOU-01-CF-02	CF	Classroom faucets	104							Posted Hand Wash Only
SOU-01-CF-03	CF	Classroom faucets	104							Posted Hand Wash Only / Not in Operation
SOU-01-CF-04	CF	Classroom faucets	104							Posted Hand Wash Only / Not in Operation
SOU-01-CF-06	CF	Classroom faucets	110							Not in Operation - Covered with a Bag
SOU-01-CF-07	CF	Classroom faucets	110	7/12/2022	0616	P	1.88	P	<1.00	
SOU-01-WO-08	WO	Water fountain attached to sink	110							Not in Operation
SOU-01-WF-15	WF	Water fountain with filter & cooler	Corridor 100-A	7/12/2022	0610	P	<1.00	P	<1.00	
SOU-01-MS-18	MS	Miscellaneous sinks	108	7/12/2022	0612	P	3.90	P	<1.00	
SOU-02-CF-20	CF	Classroom faucets	204	7/12/2022	0627	P	2.78	P	<1.00	
SOU-02-CF-21	CF	Classroom faucets	204	7/12/2022	0629	P	2.83	P	1.26	
SOU-02-WC-22	WC	Water fountain with cooler	204	7/12/2022	0631	P	4.64	P	4.92	
SOU-02-CF-25	CF	Classroom faucets	205							Hand Wash Station / Not in Operation
SOU-02-WO-26	WO	Water fountain without cooler	203							Not in Operation
SOU-02-CF-27	CF	Classroom faucets	203	7/12/2022	0637	P	5.12	P	1.23	
SOU-02-CF-28	CF	Classroom faucets	203	7/12/2022	0638	P	5.03	P	4.13	
SOU-02-CF-29	CF	Classroom faucets	210							Not an Occupied Room / No Access to Fixture
SOU-02-CF-30	CF	Classroom faucets	210							Not an Occupied Room / No Access to Fixture
SOU-02-WO-31	WO	Water fountain without cooler	210							Not an Occupied Room / No Access to Fixture
SOU-02-WC-32	WC	Water fountain with cooler	210							Not an Occupied Room / No Access to Fixture
SOU-02-CF-34	CF	Classroom faucets	210							Not an Occupied Room
SOU-02-CF-35	CF	Classroom faucets	210							Not an Occupied Room
SOU-02-WO-36	WO	Water fountain without cooler	210							Not an Occupied Room / Not in Operation
SOU-02-WO-37	WO	Water fountain without cooler	202							Not an Occupied Room
SOU-02-CF-38	CF	Classroom faucets	202							Not an Occupied Room
SOU-02-CF-39	CF	Classroom faucets	202							Not an Occupied Room
SOU-02-MS-40	MS	Miscellaneous sinks	201							Posted Hand Wash Only
SOU-02-WC-44	WC	Water fountain with cooler	207							Not in Operation
SOU-02-WC-46	WC	Water fountain with cooler	205	7/12/2022	0621	F	36.4	F	20.1	Taken Out of Service on 9/7/2022
SOU-02-CF-47	CF	Classroom faucets	204	7/12/2022	0626	F	24.5	P	1.94	Taken Out of Service on 9/7/2022
SOU-02-CF-48	CF	Classroom faucets	204							Not in Operation - Could Not Turn On
SOU-01-WFC-50	WFC	Filtering water cooler w/ bottle filler	Corridor 100-A	7/12/2022	0608	P	<1.00	P	<1.00	

Pittsburgh Perry Field House

Lead in Drinking Water Sample Results

School: Pittsburgh Perry Field House

Address: 119 Richards Street, Pittsburgh, PA 15214

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PFH-01-SL-00	SL	Service Line	Maintenance Room	6/10/2022	0702	P	<1.00	N/A	N/A	
PFH-01-WM-00	WM	Water Main	Maintenance Room	6/10/2022	0705	P	<1.00	N/A	N/A	
PFH-01-WF-01	WF	Water fountain with filter & cooler	Maintenance Room	6/10/2022	0701	P	<1.00	P	<1.00	
PFH-01-IM-02	IM	Ice machines	Maintenance Room							Not in Operation - No Ice
PFH-01-MS-05	MS	Miscellaneous Sinks	Office	6/10/2022	0709	P	6.65	P	1.25	
PFH-01-WC-06	WC	Water fountain with cooler	Office	6/10/2022	0707	P	3.25	P	3.79	
PFH-01-WFC-07	WFC	Filtering water cooler w/ bottle filler	Home Locker Room	6/10/2022	0712	P	<1.00	P	<1.00	
PFH-01-WFC-11	WFC	Filtering water cooler w/ bottle filler	Visitor Locker Room	6/10/2022	0715	P	<1.00	P	<1.00	

Pittsburgh Perry High School

Lead in Drinking Water Sample Results

School: Pittsburgh Perry High School

Address: 3875 Perrysville Avenue, Pittsburgh, PA 15214

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PER-BS-SL-00	SL	Service Line	Pipe Space 035	6/11/2022	0721	P	<1.00	N/A	N/A	
PER-BS-WM-00	WM	Water Main	Pipe Space 035	6/11/2022	0724	P	<1.00	N/A	N/A	
PER-BS-WF-02	WF	Water fountain with filter & cooler	Hall 021	6/11/2022	0725	P	<1.00	P	<1.00	
PER-BS-WFC-03	WFC	Filtering water cooler w/ bottle filler	Hall 021	6/11/2022	0726	P	<1.00	P	<1.00	
PER-BS-MS-04	MS	Miscellaneous sinks	024A	6/11/2022	0727	P	6.92	P	1.04	
PER-BS-WC-05	WC	Water fountain with cooler	Band Room (020)	6/11/2022	0729	P	<1.00	P	<1.00	
PER-SB-MS-06	MS	Miscellaneous sinks	019							Posted Hand Wash Only
PER-SB-WF-08	WF	Water fountain with filter & cooler	ROTC (010)	6/11/2022	0733	P	<1.00	P	<1.00	
PER-01-WF-10	WF	Water fountain with filter & cooler	Corridor 130	6/11/2022	0737	P	<1.00	P	<1.00	
PER-01-WFC-11	WFC	Filtering water cooler w/ bottle filler	Corridor 130	6/11/2022	0738	P	<1.00	P	<1.00	
PER-01-MS-25	MS	Miscellaneous sinks	140E	6/11/2022	0740	P	2.06	P	<1.00	
PER-01-TF-26	TF	Teacher's lounge sinks	142	6/11/2022	0743	P	<1.00	P	<1.00	
PER-01-WC-38	WC	Water fountain with cooler	Corridor 130	6/11/2022	0744	P	<1.00	P	<1.00	
PER-01-WC-39	WC	Water fountain with cooler	Corridor 130	6/11/2022	0745	P	<1.00	P	<1.00	
PER-01-MS-46	MS	Miscellaneous sinks	Library (149)	6/11/2022	0747	P	1.59	P	<1.00	
PER-01-NF-49	NF	Nurse's office sink faucets	147D	6/11/2022	0751	P	5.00	P	<1.00	
PER-01-NF-50	NF	Nurse's office sink faucets	147A	6/11/2022	0750	P	6.88	P	3.68	
PER-01-KF-51	KF	Kitchen faucets	Kitchen (162)	6/11/2022	0756	P	1.66	P	<1.00	
PER-01-KF-52	KF	Kitchen faucets	Kitchen (162)	6/11/2022	0757	P	1.93	P	<1.00	
PER-01-WFC-54	WFC	Filtering water cooler w/ bottle filler	Cafeteria (160)	6/11/2022	0800	P	<1.00	P	<1.00	
PER-01-WF-55	WF	Water fountain with filter & cooler	Cafeteria (160)	6/11/2022	0758	P	<1.00	P	<1.00	
PER-02-WC-59	WC	Water fountain with cooler	Corridor 200	6/11/2022	0806	P	<1.00	P	<1.00	
PER-02-WC-60	WC	Water fountain with cooler	Corridor 200	6/11/2022	0805	P	<1.00	P	<1.00	
PER-02-WF-85	WF	Water fountain with filter & cooler	Corridor 200	6/11/2022	0809	P	<1.00	P	<1.00	
PER-02-WFC-86	WFC	Filtering water cooler w/ bottle filler	Corridor 200	6/11/2022	0810	P	<1.00	P	<1.00	
PER-02-WF-96	WF	Water fountain with filter & cooler	Corridor 200D	6/11/2022	0817	P	<1.00	P	<1.00	
PER-02-CF-117	CF	Classroom faucets	267	6/11/2022	0813	P	<1.00	P	<1.00	
PER-02-CF-119	CF	Classroom faucets	267	6/11/2022	0814	P	6.53	P	<1.00	
PER-03-WC-131	WC	Water fountain with cooler	Corridor 300	6/11/2022	0827	P	<1.00	P	<1.00	
PER-03-WC-132	WC	Water fountain with cooler	Corridor 300	6/11/2022	0826	P	1.22	P	<1.00	
PER-03-CF-134	CF	Classroom faucets	326	6/11/2022	0824	P	3.64	P	1.03	
PER-03-CF-135	CF	Classroom faucets	326	6/11/2022	0823	P	4.49	P	1.05	
PER-03-HF-142	HF	Home economics faucets (with cooking)	Home Economics (333)	6/11/2022	0829	P	<1.00	P	<1.00	
PER-03-HF-143	HF	Home economics faucets (with cooking)	Home Economics (333)	6/11/2022	0830	P	<1.00	P	<1.00	
PER-03-HF-144	HF	Home economics faucets (with cooking)	Home Economics (333)	6/11/2022	0831	P	<1.00	P	<1.00	
PER-03-HF-145	HF	Home economics faucets (with cooking)	Home Economics (333)	6/11/2022	0832	P	<1.00	P	<1.00	
PER-03-CF-146	CF	Classroom faucets	338	6/11/2022	0835	P	1.91	P	<1.00	
PER-03-CF-147	CF	Classroom faucets	342	6/11/2022	0837	P	1.27	P	1.41	
PER-03-CF-148	CF	Classroom faucets	342	6/11/2022	0838	P	2.69	P	<1.00	
PER-03-WC-149	WC	Water fountain with cooler	Corridor 300	6/11/2022	0840	P	<1.00	P	1.06	
PER-03-WC-150	WC	Water fountain with cooler	Corridor 300	6/11/2022	0841	P	1.40	P	<1.00	
PER-03-WFC-157	WFC	Filtering water cooler w/ bottle filler	Corridor 300E	6/11/2022	0845	P	<1.00	P	<1.00	
PER-02-SL-159	SL	Service Line	825	6/11/2022	0656	P	<1.00	N/A	N/A	

Lead in Drinking Water Sample Results

School: Pittsburgh Perry High School

Address: 3875 Perrysville Avenue, Pittsburgh, PA 15214

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PER-02-WM-159	WM	Water Main	825	6/11/2022	0659	P	<1.00	N/A	N/A	
PER-02-WFC-176	WFC	Filtering water cooler w/ bottle filler	Corridor 800	6/11/2022	0703	P	<1.00	P	<1.00	
PER-02-WO-211	WO	Water fountain without cooler	Pool Deck	8/2/2022	0605	P	5.80	P	<1.00	
PER-02-WO-236	WO	Water fountain without cooler	818B	6/11/2022	0706	P	1.49	P	<1.00	
PER-01-WO-246	WO	Water fountain without cooler	Corridor 700	8/2/2022	0610	P	<1.00	P	<1.00	
PER-03-WF-250	WF	Water fountain with filter & cooler	Corridor 900	6/11/2022	0713	P	<1.00	P	<1.00	
PER-03-MS-251	MS	Miscellaneous sinks	903	6/11/2022	0711	P	7.44	P	1.01	
PER-01-KF-256	KF	Kitchen faucets	Kitchen (162)	6/11/2022	0755	P	2.25	P	<1.00	
PER-02-MS-258	MS	Miscellaneous sinks	823	6/11/2022	0701	P	3.04	P	<1.00	
PER-02-IM-259	IM	Ice Machines	823	8/2/2022	0601	P	<1.00	N/A	N/A	
PER-02-WF-261	WF	Water fountain with filter & cooler	Corridor 200D	6/11/2022	0816	P	<1.00	P	<1.00	
PER-03-WF-292	WF	Water fountain with filter & cooler	Corridor 300E	6/11/2022	0844	P	<1.00	P	<1.00	
PER-03-WFC-294	WFC	Filtering water cooler w/ bottle filler	Corridor 900	6/11/2022	0712	P	<1.00	P	<1.00	
PER-03-CF-309	CF	Classroom faucets	Cosmetology	6/11/2022	0847	P	<1.00	P	<1.00	
PER-03-CF-310	CF	Classroom faucets	Cosmetology	6/11/2022	0848	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Pioneer

Address: 775 Dunster Street, Pittsburgh, PA 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PIO-BS-SL-00	SL	Service Line	Boiler Room	6/7/2022	0600	P	<1.00	N/A	N/A	
PIO-BS-WM-00	WM	Water Main	Boiler Room	6/7/2022	0603	P	<1.00	N/A	N/A	
PIO-01-CF-5	CF	Classroom faucets	135							Posted Hand Wash Only
PIO-01-MS-6	MS	Miscellaneous sinks	Multi-Purpose Area							Posted Hand Wash Only
PIO-01-MS-7	MS	Miscellaneous sinks	Multi-Purpose Area							Posted Hand Wash Only
PIO-BS-MS-9	MS	Miscellaneous sinks	Corridor A011	6/7/2022	0605	P	1.05	P	<1.00	
PIO-01-WC-12	WC	Water fountain with cooler	Corridor D	6/7/2022	0609	P	1.41	P	2.73	
PIO-01-CF-17	CF	Classroom faucets	128							Posted Hand Wash Only
PIO-01-CF-20	CF	Classroom faucets	125							Posted Hand Wash Only - Dishwasher Hooked Up to Sink
PIO-01-CF-21	CF	Classroom faucets	126							Posted Hand Wash Only
PIO-01-WFC-22	WFC	Filtering water cooler w/ bottle filler	Corridor C	6/7/2022	0611	P	<1.00	P	<1.00	
PIO-01-CF-23	CF	Classroom faucets	125							Posted Hand Wash Only
PIO-01-NF-28	NF	Nurse's office sink faucets	Nurse's Office (122.2)	6/7/2022	0613	P	1.13	P	<1.00	
PIO-01-CF-33	CF	Classroom faucets	115							Posted Hand Wash Only
PIO-01-CF-36	CF	Classroom faucets	114							Posted Hand Wash Only
PIO-01-CF-37	CF	Classroom faucets	111	6/7/2022	0616	P	1.61	P	<1.00	
PIO-01-CF-40	CF	Classroom faucets	109							Posted Hand Wash Only
PIO-01-WFC-43	WFC	Filtering water cooler w/ bottle filler	Corridor E	6/7/2022	0618	P	<1.00	P	<1.00	
PIO-01-KF-46	KF	Kitchen faucets	108							Posted Hand Wash Only
PIO-01-KF-48	KF	Kitchen faucets	108							Posted Hand Wash Only
PIO-01-CF-49	CF	Classroom faucets	107							Posted Hand Wash Only
PIO-01-CF-50	CF	Classroom faucets	105							Posted Hand Wash Only
PIO-01-CF-51	CF	Classroom faucets	106							Posted Hand Wash Only
PIO-01-CF-52	CF	Classroom faucets	104							Posted Hand Wash Only
PIO-01-CF-53	CF	Classroom faucets	102							Posted Hand Wash Only
PIO-01-CF-54	CF	Classroom faucets	103							Posted Hand Wash Only
PIO-01-CF-55	CF	Classroom faucets	101							Posted Hand Wash Only
PIO-01-GF-58	GF	Filtered glass filler	Nurse's Office (122.2)	6/7/2022	0614	P	<1.00	P	<1.00	
PIO-01-GF-59	GF	Filtered glass filler	107	6/7/2022	0620	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Roosevelt 2-5

Address: 17 W. Cherryhill Street, Pittsburgh, PA 15210

Fixture ID	School Code	Building Level	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
RSV-BS-SL-00	RSV	BS	SL	Service Line	Boiler Room	6/1/2022	0611	P	<1.00	N/A	N/A	
RSV-BS-WM-00	RSV	BS	WM	Water Main	Boiler Room	6/1/2022	0614	P	<1.00	N/A	N/A	
RSV-BS-KF-02	RSV	BS	KF	Kitchen faucets	Kitchen (001A)	6/1/2022	0616	P	1.43	P	<1.00	
RSV-BS-WF-06	RSV	BS	WF	Water fountain with filter & cooler	Outside 005	6/1/2022	0621	P	<1.00	P	<1.00	
RSV-BS-WFC-07	RSV	BS	WFC	Filtering water cooler w/ bottle filler	Outside 005	6/1/2022	0619	P	<1.00	P	<1.00	
RSV-01-WF-15	RSV	01	WF	Water fountain with filter & cooler	Corridor 100A	6/1/2022	0625	P	<1.00	P	<1.00	
RSV-01-WFC-16	RSV	01	WFC	Filtering water cooler w/ bottle filler	Corridor 100A	6/1/2022	0624	P	<1.00	P	<1.00	
RSV-01-TF-26	RSV	01	TF	Teacher's lounge sinks	110	6/1/2022	0629	P	<1.00	P	<1.00	
RSV-02-WF-31	RSV	02	WF	Water fountain with filter & cooler	Corridor 200A	6/1/2022	0635	P	<1.00	P	<1.00	
RSV-02-WFC-32	RSV	02	WFC	Filtering water cooler w/ bottle filler	Corridor 200A	6/1/2022	0634	P	<1.00	P	<1.00	
RSV-02-MS-37	RSV	02	MS	Miscellaneous sinks	Library (214B)	6/1/2022	0637	P	<1.00	P	<1.00	
RSV-03-WC-43	RSV	03	WC	Water fountain with cooler	Corridor 300A	6/1/2022	0641	P	<1.00	P	<1.00	
RSV-03-WFC-44	RSV	03	WFC	Filtering water cooler w/ bottle filler	Corridor 300A	6/1/2022	0640	P	<1.00	P	<1.00	
RSV-03-MS-49	RSV	03	MS	Miscellaneous sinks	309	6/1/2022	0643	P	1.05	P	<1.00	
RSV-03-CF-50	RSV	03	CF	Classroom faucets	311	6/1/2022	0646	P	<1.00	P	<1.00	
RSV-03-CF-51	RSV	03	CF	Classroom faucets	311	6/1/2022	0647	P	<1.00	P	<1.00	
RSV-01-CF-53	RSV	01	CF	Classroom faucets	108	6/1/2022	0627	P	<1.00	P	<1.00	
RSV-01-CF-54	RSV	01	CF	Classroom faucets	112	6/1/2022	0631	P	<1.00	P	<1.00	

Pittsburgh Schenley Field House

Lead in Drinking Water Sample Results

School: Pittsburgh Schenley Field House

Address: 3031 Iowa Street, Pittsburgh, PA 15219

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SFH-BS-SL-00	SL	Service Line	Heater Room	5/28/2022	0706	P	<1.00	N/A	N/A	
SFH-BS-WM-00	WM	Water Main	Heater Room	5/28/2022	0708	P	<1.00	N/A	N/A	
SFH-BS-IM-01	IM	Ice machines	Heater Room	10/14/2022	0650	P	10.8	N/A	N/A	
SFH-GF-FF-02	FF	Field House sink faucets	Home's Dressing Room	5/28/2022	0705	P	7.24	P	<1.00	
SFH-GF-FF-03	FF	Field House sink faucets	Home's Dressing Room	5/28/2022	0710	P	4.55	P	<1.00	
SFH-GF-WFC-06	WFC	Filtering water cooler w/ bottle filler	Outside	10/14/2022	0712	P	<1.00	P	<1.00	
SFH-GF-WF-07	WF	Water fountain with filter & cooler	Outside	10/14/2022	0715	P	<1.00	P	<1.00	
SFH-GF-FF-12	FF	Field House sink faucets	Visitor's Dressing Room	5/28/2022	0714	P	4.29	P	<1.00	
SFH-GF-FF-13	FF	Field House sink faucets	Visitor's Dressing Room	5/28/2022	0716	F	16.6	P	<1.00	Retested and Passed on 10/14/2022

Pittsburgh Science and Technology Academy 6-12

Lead in Drinking Water Sample Results

School: Pittsburgh Science and Technology Academy 6-12

Address: 107 Thackery Avenue, Pittsburgh, PA 15213

Fixture ID	School Code	Building Level	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (Fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SAT-GF-SL-00	SAT	GF	SL	Service Line	055B	9/29/2022	0602	P	<1.00	N/A	N/A	
SAT-GF-WM-00	SAT	GF	WM	Water Main	055B	9/29/2022	0605	P	1.66	N/A	N/A	
SAT-GF-WF-05	SAT	GF	WF	Water fountain with filter & cooler	Corridor 032	9/29/2022	0607	P	<1.00	P	<1.00	
SAT-GF-WFC-06	SAT	GF	WFC	Filtering water cooler w/ bottle filler	Corridor 032	9/29/2022	0610	P	<1.00	P	<1.00	
SAT-GF-WF-28	SAT	GF	WF	Water fountain with filter & cooler	Corridor 032	6/24/2022	0608	P	<1.00	P	<1.00	
SAT-GF-WFC-29	SAT	GF	WFC	Filtering water cooler w/ bottle filler	Corridor 032	6/24/2022	0607	P	<1.00	P	<1.00	
SAT-GF-WF-35	SAT	GF	WF	Water fountain with filter & cooler	031	6/24/2022	0614	P	<1.00	P	<1.00	
SAT-GF-WF-37	SAT	GF	WF	Water fountain with filter & cooler	029	6/24/2022	0616	P	<1.00	P	<1.00	
SAT-GF-WF-56	SAT	GF	WF	Water fountain with filter & cooler	Gym (067)	6/24/2022	0611	P	<1.00	P	<1.00	
SAT-01-MS-58	SAT	01	MS	Miscellaneous sinks	144	6/24/2022	0629	P	<1.00	P	<1.00	
SAT-01-NF-60	SAT	01	NF	Nurse's office sink faucets	Nurse's Office (134A)							Posted Hand Wash Only
SAT-01-WF-62	SAT	01	WF	Water fountain with cooler	Corridor 120	9/29/2022	0613	P	<1.00	P	<1.00	
SAT-01-WF-63	SAT	01	WF	Water fountain with cooler	Corridor 120	9/29/2022	0615	P	<1.00	P	<1.00	
SAT-01-IM-82	SAT	01	IM	Ice machines	123							Not in Operation - No Ice (Posted Not for Human Consumption)
SAT-01-WF-86	SAT	01	WF	Water fountain with filter & cooler	Corridor 120	6/24/2022	0633	P	<1.00	P	<1.00	
SAT-01-WFC-87	SAT	01	WFC	Filtering water cooler w/ bottle filler	Corridor 120	6/24/2022	0632	P	<1.00	P	<1.00	
SAT-01-WF-88	SAT	01	WF	Water fountain with filter & cooler	Corridor 111	6/24/2022	0637	P	<1.00	P	<1.00	
SAT-01-WFC-89	SAT	01	WFC	Filtering water cooler w/ bottle filler	Corridor 111	6/24/2022	0636	P	<1.00	P	<1.00	
SAT-01-KF-91	SAT	01	KF	Kitchen faucets	Kitchen (108)	6/24/2022	0639	P	2.59	P	<1.00	
SAT-01-KF-95	SAT	01	KF	Kitchen faucets	Kitchen (109)	6/24/2022	0641	P	2.57	P	<1.00	
SAT-01-KF-96	SAT	01	KF	Kitchen faucets	Kitchen (109)	6/24/2022	0642	P	7.27	P	<1.00	
SAT-01-KF-97	SAT	01	KF	Kitchen faucets	Kitchen (109)	6/24/2022	0643	P	3.30	P	<1.00	
SAT-01-CF-107	SAT	01	CF	Classroom faucets	100	6/24/2022	0647	P	<1.00	P	<1.00	
SAT-02-WF-108	SAT	02	WF	Water fountain with filter & cooler	Corridor 208	6/24/2022	0655	P	<1.00	P	<1.00	
SAT-02-WF-109	SAT	02	WF	Water fountain with filter & cooler	Corridor 208	6/24/2022	0656	P	<1.00	P	<1.00	
SAT-02-MS-114	SAT	02	MS	Miscellaneous sinks	225	6/24/2022	0653	P	<1.00	P	<1.00	
SAT-02-WF-119	SAT	02	WF	Water fountain with filter & cooler	Corridor 208	6/24/2022	0700	P	<1.00	P	<1.00	
SAT-02-WFC-120	SAT	02	WFC	Filtering water cooler w/ bottle filler	Corridor 208	6/24/2022	0659	P	<1.00	P	<1.00	
SAT-03-WF-149	SAT	03	WF	Water fountain with filter & cooler	Corridor 300	9/29/2022	0620	P	<1.00	P	<1.00	
SAT-03-WF-150	SAT	03	WF	Water fountain with filter & cooler	Corridor 300	9/29/2022	0623	P	<1.00	P	<1.00	
SAT-03-WF-158	SAT	03	WF	Water fountain with filter & cooler	Corridor 300	6/24/2022	0705	P	<1.00	P	<1.00	
SAT-03-WFC-159	SAT	03	WFC	Filtering water cooler w/ bottle filler	Corridor 300	6/24/2022	0703	P	<1.00	P	<1.00	
SAT-GF-CF-162	SAT	GF	CF	Classroom faucets	022	6/24/2022	0620	P	2.95	P	2.04	
SAT-01-GF-189	SAT	01	GF	Filtered Glass Filler	100	6/24/2022	0648	P	<1.00	P	<1.00	
SAT-01-GF-190	SAT	01	GF	Filtered Glass Filler	Nurse's Office (134A)	6/24/2022	0626	P	<1.00	P	<1.00	

Pittsburgh Service Center

Lead in Drinking Water Sample Results

School: Pittsburgh Service Center

Address: 1305 Muriel Street, Pittsburgh, PA 15203

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SCN-01-SL-00	SL	Service Line	Lay Out Area	7/14/2022	0557	P	<1.00	N/A	N/A	
SCN-01-WM-00	WM	Water Main	Lay Out Area	7/14/2022	0559	P	<1.00	N/A	N/A	
SCN-01-MS-01	MS	Miscellaneous sinks	Food Service Shop	7/14/2022	0556	P	<1.00	P	<1.00	
SCN-01-WC-07	WC	Water fountain with cooler	Outside Custodian's Office	7/14/2022	0601	P	<1.00	P	<1.00	
SCN-01-IM-10	IM	Ice machines	Boiler Room							Not in Operation - No Ice
SCN-01-MS-13	MS	Miscellaneous sinks	Music Repair Shop	7/14/2022	0613	P	7.06	P	<1.00	
SCN-01-WC-14	WC	Water fountain with cooler	Music Repair Shop	7/14/2022	0614	P	1.40	P	1.37	
SCN-01-MS-17	MS	Miscellaneous sinks	Call Center	7/14/2022	0604	P	<1.00	P	<1.00	
SCN-02-MS-18	MS	Miscellaneous sinks	Facilities Design / Construction	7/14/2022	0622	P	<1.00	P	1.14	
SCN-02-MS-19	MS	Miscellaneous sinks	Next to Purchasing	7/14/2022	0619	P	2.08	P	<1.00	
SCN-02-WC-29	WC	Water fountain with cooler	Plumbing	7/14/2022	0626	P	<1.00	P	<1.00	
SCN-02-MS-31	MS	Miscellaneous sinks	Shipping Office	7/14/2022	0635	P	1.83	P	<1.00	
SCN-02-MS-33	MS	Miscellaneous sinks	General Office	7/14/2022	0637	P	1.47	P	<1.00	
SCN-02-IM-34	IM	Ice machines	General Storage	7/14/2022	0629	P	<1.00	N/A	N/A	
SCN-02-WC-36	WC	Water fountain with cooler	Corridor	7/14/2022	0631	P	<1.00	P	<1.00	
SCN-02-WC-41	WC	Water fountain with cooler	Shipping Dock	7/14/2022	0640	P	<1.00	P	1.90	
SCN-02-GF-46	GF	Filtered Glass Filler	Corridor	7/14/2022	0632	P	<1.00	P	<1.00	

Pittsburgh South Brook 6-8

Lead in Drinking Water Sample Results

School: Pittsburgh South Brook 6-8

779 Dunster Street, Pittsburgh, PA 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SBK-BS-SL-00	SL	Service Line	Boiler Room	6/7/2022	0600	P	<1.00	N/A	N/A	
SBK-BS-WM-00	WM	Water Main	Boiler Room	6/7/2022	0603	P	<1.00	N/A	N/A	
SBK-01-NF-37	NF	Nurse's office sink faucets	151.6	6/7/2022	0625	P	<1.00	P	<1.00	
SBK-01-IM-39	IM	Ice machines	Receiving (158)							Not in Operation - No Ice
SBK-01-WF-41	WF	Water fountain with filter & cooler	Corridor 101	6/7/2022	0631	P	<1.00	P	<1.00	
SBK-01-WFC-42	WFC	Filtering water cooler w/ bottle filler	Corridor 101	6/7/2022	0632	P	<1.00	P	<1.00	
SBK-01-KF-45	KF	Kitchen faucets	Kitchen (157)	6/7/2022	0634	P	<1.00	P	<1.00	
SBK-01-TF-46	TF	Teacher's lounge sinks	159	6/7/2022	0636	P	1.25	P	<1.00	
SBK-01-CF-47	CF	Classroom faucets	160	6/7/2022	0638	P	2.41	P	<1.00	
SBK-01-CF-48	CF	Classroom faucets	161	6/7/2022	0639	P	2.40	P	<1.00	
SBK-01-CF-49	CF	Classroom faucets	162	6/7/2022	0647	P	<1.00	P	<1.00	
SBK-01-CF-50	CF	Classroom faucets	162	6/7/2022	0648	P	<1.00	P	<1.00	
SBK-01-CF-51	CF	Classroom faucets	163	6/7/2022	0641	P	<1.00	P	<1.00	
SBK-01-CF-52	CF	Classroom faucets	164	6/7/2022	0643	P	1.04	P	<1.00	
SBK-01-CF-53	CF	Classroom faucets	165	6/7/2022	0645	P	<1.00	P	<1.00	
SBK-01-WF-58	WF	Water fountain with filter & cooler	Corridor 100	6/7/2022	0653	P	<1.00	P	<1.00	
SBK-01-WFC-59	WFC	Filtering water cooler w/ bottle filler	Corridor 100	6/7/2022	0652	P	<1.00	P	<1.00	
SBK-02-CF-69	CF	Classroom faucets	206	6/7/2022	0656	P	<1.00	P	<1.00	
SBK-02-CF-70	CF	Classroom faucets	207	6/7/2022	0658	P	<1.00	P	<1.00	
SBK-02-CF-71	CF	Classroom faucets	208	6/7/2022	0705	P	<1.00	P	<1.00	
SBK-02-CF-72	CF	Classroom faucets	208	6/7/2022	0706	P	<1.00	P	<1.00	
SBK-02-CF-73	CF	Classroom faucets	209	6/7/2022	0659	P	<1.00	P	<1.00	
SBK-02-CF-74	CF	Classroom faucets	210	6/7/2022	0701	P	<1.00	P	<1.00	
SBK-02-CF-75	CF	Classroom faucets	211	6/7/2022	0703	P	<1.00	P	<1.00	
SBK-02-WF-80	WF	Water fountain with filter & cooler	Corridor 200	6/7/2022	0709	P	<1.00	P	<1.00	
SBK-02-WFC-81	WFC	Filtering water cooler w/ bottle filler	Corridor 200	6/7/2022	0708	P	<1.00	P	<1.00	
SBK-01-GF-91	GF	Filtered glass filler	151.6	6/7/2022	0628	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Sterrett 6-8

Address: 7100 Reynolds Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
STE-GF-SL-00	SL	Service Line	Janitor's Office	8/17/2022	0555	P	<1.00	N/A	N/A	
STE-GF-WM-00	WM	Water Main	Janitor's Office	8/17/2022	0558	P	<1.00	N/A	N/A	
STE-GF-CF-03	CF	Classroom faucets	G-014	8/17/2022	0559	P	3.35	P	<1.00	
STE-GF-WFC-04	WFC	Filtering water cooler w/ bottle filler	Corridor 007	8/17/2022	0601	P	<1.00	P	<1.00	
STE-GF-CF-06	CF	Classroom faucets	B-01	8/17/2022	0604	P	1.95	P	<1.00	
STE-GF-CF-07	CF	Classroom faucets	B-01	8/17/2022	0605	P	3.89	P	<1.00	
STE-GF-WF-31	WF	Water fountain with filter & cooler	Outside Staff Restroom (Addition)	8/17/2022	0621	P	<1.00	P	<1.00	
STE-GF-WFC-32	WFC	Filtering water cooler w/ bottle filler	Outside Staff Restroom (Addition)	8/17/2022	0620	P	<1.00	P	<1.00	
STE-GF-WF-38	WF	Water fountain with filter & cooler	Cafeteria (115)	8/17/2022	0609	P	<1.00	P	<1.00	
STE-GF-WFC-39	WFC	Filtering water cooler w/ bottle filler	Cafeteria (115)	8/17/2022	0608	P	<1.00	P	<1.00	
STE-GF-KF-40	KF	Kitchen faucets	Kitchen (116)	8/17/2022	0617	P	1.21	P	<1.00	
STE-GF-KF-42	KF	Kitchen faucets	Kitchen (116)	8/17/2022	0613	P	<1.00	P	<1.00	
STE-01-WF-45	WF	Water fountain with filter & cooler	Corridor 100	8/17/2022	0626	P	<1.00	P	<1.00	
STE-01-WFC-46	WFC	Filtering water cooler w/ bottle filler	Corridor 100	8/17/2022	0625	P	<1.00	P	<1.00	
STE-01-WF-49	WF	Water fountain with filter & cooler	Corridor 100	8/17/2022	0632	P	<1.00	P	<1.00	
STE-01-WF-50	WF	Water fountain with filter & cooler	Corridor 100	8/17/2022	0631	P	<1.00	P	<1.00	
STE-01-CF-52	CF	Classroom faucets	105	8/17/2022	0635	P	5.99	P	<1.00	
STE-01-TF-53	TF	Teacher's lounge sinks	Teacher's Lounge	8/17/2022	0628	P	1.19	P	<1.00	
STE-01-NF-54	NF	Nurse's office sink faucets	Nurse's Office	8/17/2022	0645	P	2.06	P	<1.00	
STE-01-WF-62	WF	Water fountain with filter & cooler	Outside 122	8/17/2022	0642	P	<1.00	P	<1.00	
STE-01-WFC-63	WFC	Filtering water cooler w/ bottle filler	Outside 122	8/17/2022	0641	P	<1.00	P	<1.00	
STE-02-WF-69	WF	Water fountain with filter & cooler	Corridor 200	8/17/2022	0656	P	<1.00	P	<1.00	
STE-02-WFC-70	WFC	Filtering water cooler w/ bottle filler	Corridor 200	8/17/2022	0655	P	<1.00	P	<1.00	
STE-02-WF-76	WF	Water fountain with filter & cooler	Corridor 200A	8/17/2022	0653	P	<1.00	P	<1.00	
STE-02-WFC-77	WFC	Filtering water cooler w/ bottle filler	Corridor 200A	8/17/2022	0652	P	<1.00	P	<1.00	
STE-02-CF-85	CF	Classroom faucets	203	8/17/2022	0649	F	21.7	P	1.93	Retested and Passed on 9/30/2022
STE-GF-KF-86	KF	Kitchen faucets	Kitchen (116)	8/17/2022	0612	P	<1.00	P	<1.00	
STE-01-MS-87	MS	Miscellaneous sinks	Library	8/17/2022	0639	P	<1.00	P	<1.00	
STE-GF-IM-88	IM	Ice machines	Kitchen (116)	8/17/2022	0615	P	<1.00	N/A	N/A	
STE-01-GF-89	GF	Filtered Glass Filler	Nurse's Office	8/17/2022	0644	P	<1.00	P	<1.00	

Pittsburgh Sunnyside PreK-8

Lead in Drinking Water Sample Results

School: Pittsburgh Sunnyside PreK-8

Address: 4801 Stanton Avenue, Pittsburgh, PA 15201

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SUN-BS-SL-00	SL	Service Line	Boiler Room	5/10/2022	0553	P	<1.00	N/A	N/A	
SUN-BS-WM-00	WM	Water Main	Boiler Room	5/10/2022	0556	P	<1.00	N/A	N/A	
SUN-01-CF-02	CF	Classroom faucets	124	5/10/2022	0603	P	<1.00	P	<1.00	
SUN-01-WFC-05	WFC	Filtering water cooler w/ bottle filler	Corridor 103	5/10/2022	0601	P	<1.00	P	<1.00	
SUN-01-WF-06	WF	Water fountain with filter & cooler	Corridor 103	5/10/2022	0600	P	<1.00	P	<1.00	
SUN-01-MS-15	MS	Miscellaneous sinks	115	5/10/2022	0558	P	1.66	P	<1.00	
SUN-01-TF-17	TF	Teacher's lounge sinks	112	5/10/2022	0620	P	3.72	P	<1.00	
SUN-01-MS-18	MS	Miscellaneous sinks	111A	5/10/2022	0622	P	4.04	P	<1.00	
SUN-01-NF-19	NF	Nurse's office sink faucets	110	5/10/2022	0623	P	4.18	P	<1.00	
SUN-01-WF-28	WF	Water fountain with filter & cooler	Outside Café (190)	5/10/2022	0626	P	<1.00	P	<1.00	
SUN-01-WF-29	WF	Water fountain with filter & cooler	Outside Café (190)	5/10/2022	0627	P	<1.00	P	<1.00	
SUN-01-KF-31	KF	Kitchen faucets	Kitchen (192)	5/10/2022	0631	P	<1.00	P	<1.00	
SUN-01-KF-32	KF	Kitchen faucets	Kitchen (192)	5/10/2022	0629	P	<1.00	P	<1.00	
SUN-01-WF-54	WF	Water fountain with filter & cooler	Corridor 102	5/10/2022	0637	P	<1.00	P	<1.00	
SUN-01-WFC-55	WFC	Filtering water cooler w/ bottle filler	Corridor 102	5/10/2022	0638	P	<1.00	P	<1.00	
SUN-01-CF-61	CF	Classroom faucets	149	5/10/2022	0640	P	1.20	P	<1.00	
SUN-01-CF-62	CF	Classroom faucets	147	5/10/2022	0642	P	8.47	P	1.04	
SUN-01-CF-63	CF	Classroom faucets	145	5/10/2022	0643	P	3.57	P	<1.00	
SUN-01-CF-64	CF	Classroom faucets	146	5/10/2022	0645	P	5.95	P	1.76	
SUN-01-WF-65	WF	Water fountain with filter & cooler	Corridor 102	5/10/2022	0646	P	<1.00	P	<1.00	
SUN-01-WF-66	WF	Water fountain with filter & cooler	Corridor 102	5/10/2022	0647	P	<1.00	P	<1.00	
SUN-01-CF-67	CF	Classroom faucets	126	5/10/2022	0607	P	1.68	P	<1.00	
SUN-01-CF-68	CF	Classroom faucets	127	5/10/2022	0605	P	<1.00	P	<1.00	
SUN-01-CF-69	CF	Classroom faucets	128	5/10/2022	0609	P	<1.00	P	<1.00	
SUN-01-CF-70	CF	Classroom faucets	129	9/16/2022	0644	P	4.73	P	<1.00	
SUN-01-WF-71	WF	Water fountain with filter & cooler	Corridor 103	5/10/2022	0612	P	<1.00	P	<1.00	
SUN-01-WF-72	WF	Water fountain with filter & cooler	Corridor 103	5/10/2022	0613	P	<1.00	P	<1.00	
SUN-01-CF-73	CF	Classroom faucets	131	5/10/2022	0614	P	3.31	P	<1.00	
SUN-01-CF-75	CF	Classroom faucets	132	5/10/2022	0616	P	<1.00	P	<1.00	
SUN-01-CF-76	CF	Classroom faucets	132	5/10/2022	0617	P	1.21	P	<1.00	
SUN-01-CF-79	CF	Classroom faucets	136	5/10/2022	0651	P	<1.00	P	<1.00	
SUN-01-CF-85	CF	Classroom faucets	140	5/10/2022	0700	P	2.09	P	<1.00	
SUN-01-WF-86	WF	Water fountain with filter & cooler	Corridor 160	5/10/2022	0653	P	<1.00	P	<1.00	
SUN-01-WF-87	WF	Water fountain with filter & cooler	Corridor 160	5/10/2022	0654	P	<1.00	P	<1.00	
SUN-01-CF-88	CF	Classroom faucets	140	5/10/2022	0704	P	1.15	P	1.11	
SUN-01-CF-89	CF	Classroom faucets	140	5/10/2022	0706	P	<1.00	P	<1.00	
SUN-01-CF-91	CF	Classroom faucets	142	5/10/2022	0708	P	<1.00	P	<1.00	
SUN-01-CF-92	CF	Classroom faucets	142	5/10/2022	0709	P	1.63	P	<1.00	
SUN-01-WF-93	WF	Water fountain with filter & cooler	180	9/16/2022	0647	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Sunnyside PreK-8

Address: 4801 Stanton Avenue, Pittsburgh, PA 15201

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SUN-01-WF-94	WF	Water fountain with filter & cooler	172	9/16/2022	0649	P	<1.00	P	<1.00	
SUN-01-CF-95	CF	Classroom faucets	140	5/10/2022	0659	P	<1.00	P	<1.00	
SUN-01-CF-96	CF	Classroom faucets	140	5/10/2022	0703	P	<1.00	P	<1.00	
SUN-01-KF-97	KF	Kitchen faucets	Kitchen (192)	5/10/2022	0630	P	<1.00	P	<1.00	
SUN-01-CF-98	CF	Classroom faucets	140	5/11/2022	0658	P	1.65	P	<1.00	
SUN-01-CF-99	CF	Classroom faucets	140	5/10/2022	0702	P	<1.00	P	1.14	

Lead in Drinking Water Sample Results

School: Pittsburgh Weil PreK-5

Address: 2250 Centre Avenue, Pittsburgh, PA 15219

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WEI-BS-SL-00	SL	Service Line	12	5/4/2022	0605	P	<1.00	N/A	N/A	
WEI-BS-WM-00	WM	Water Main	12	5/4/2022	0607	P	<1.00	N/A	N/A	
WEI-BS-MS-01	MS	Miscellaneous sinks	7	5/4/2022	0604	P	<1.00	P	<1.00	
WEI-01-WFC-09	WFC	Filtering water cooler w/ bottle filler	Corridor 100	5/4/2022	0610	P	<1.00	P	<1.00	
WEI-01-NF-11	NF	Nurse's office sink faucets	102	5/4/2022	0620	P	2.24	P	<1.00	
WEI-01-CF-15	CF	Classroom faucets	111A							Inaccessible - Sink Full of Classroom Items
WEI-01-WFC-18	WFC	Filtering water cooler w/ bottle filler	Corridor 100	5/4/2022	0632	P	<1.00	P	<1.00	
WEI-01-WF-19	WF	Water fountain with filter & cooler	Corridor 100	5/4/2022	0631	P	<1.00	P	<1.00	
WEI-01-CF-24	CF	Classroom faucets	112	5/4/2022	0630	P	<1.00	P	<1.00	
WEI-01-CF-25	CF	Classroom faucets	113	5/4/2022	0627	P	<1.00	P	<1.00	
WEI-01-CF-26	CF	Classroom faucets	114	5/4/2022	0623	P	5.37	P	<1.00	
WEI-01-CF-27	CF	Classroom faucets	115							Posted Hand Wash Only
WEI-01-CF-28	CF	Classroom faucets	120	5/4/2022	0613	P	1.25	P	<1.00	
WEI-01-CF-31	CF	Classroom faucets	121	5/4/2022	0614	P	<1.00	P	<1.00	
WEI-01-KF-32	KF	Kitchen faucets	130	5/4/2022	0616	P	<1.00	P	<1.00	
WEI-02-TF-35	TF	Teacher's lounge sinks	209	5/4/2022	0637	P	<1.00	P	<1.00	
WEI-02-WF-38	WF	Water fountain with filter & cooler	Corridor 200	5/4/2022	0640	P	<1.00	P	<1.00	
WEI-02-WFC-39	WFC	Filtering water cooler w/ bottle filler	Corridor 200	5/4/2022	0641	P	<1.00	P	<1.00	
WEI-02-WF-40	WF	Water fountain with filter & cooler	Corridor 200B	5/4/2022	0643	P	<1.00	P	<1.00	
WEI-02-WF-41	WF	Water fountain with filter & cooler	Corridor 200B	5/4/2022	0644	P	<1.00	P	<1.00	
WEI-02-CF-42	CF	Classroom faucets	210	5/4/2022	0647	P	8.74	P	1.00	
WEI-02-CF-43	CF	Classroom faucets	210	5/4/2022	0646	P	5.31	P	1.59	
WEI-02-CF-44	CF	Classroom faucets	208	5/4/2022	0649	F	19.9	P	<1.00	Retested and Passed on 7/27/2022
WEI-02-CF-45	CF	Classroom faucets	207	5/4/2022	0651	P	11.2	P	10.9	
WEI-02-CF-46	CF	Classroom faucets	206	5/4/2022	0653	F	17.1	P	3.91	Retested on 7/27/2022; Posted Hand Wash Only on 10/26/2022
WEI-02-WF-51	WF	Water fountain with filter & cooler	Corridor 200	5/4/2022	0654	P	<1.00	P	<1.00	
WEI-02-WF-52	WF	Water fountain with filter & cooler	Corridor 200	5/4/2022	0656	P	<1.00	P	<1.00	
WEI-03-WF-55	WF	Water fountain with filter & cooler	Corridor 300A	5/4/2022	0701	P	<1.00	P	<1.00	
WEI-03-WF-56	WF	Water fountain with filter & cooler	Corridor 300A	5/4/2022	0700	P	<1.00	P	<1.00	
WEI-03-WF-61	WF	Water fountain with filter & cooler	Corridor 300A	5/4/2022	0705	P	<1.00	P	<1.00	
WEI-03-WFC-62	WFC	Filtering water cooler w/ bottle filler	Corridor 300A	5/4/2022	0706	P	<1.00	P	<1.00	
WEI-02-MS-63	MS	Miscellaneous sinks	Library 205A							Posted Hand Wash Only
WEI-03-CF-64	CF	Classroom faucets	311	5/4/2022	0703	P	6.91	P	<1.00	
WEI-01-GF-66	GF	Filtered Glass Filler	102	5/4/2022	0619	P	<1.00	P	<1.00	
WEI-01-GF-67	GF	Filtered Glass Filler	112	5/4/2022	0629	P	<1.00	P	<1.00	
WEI-01-GF-68	GF	Filtered Glass Filler	113	5/4/2022	0626	P	<1.00	P	<1.00	
WEI-01-GF-69	GF	Filtered Glass Filler	114	5/4/2022	0622	P	<1.00	P	<1.00	

Pittsburgh West Liberty K-5

Lead in Drinking Water Sample Results

School: Pittsburgh West Liberty K-5

Address: 785 Dunster Street, Pittsburgh, PA 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WLB-BS-SL-00	SL	Service Line	Boiler Room - Equipment Room 004A	6/28/2022	0556	P	<1.00	N/A	N/A	
WLB-BS-WM-00	WM	Water Main	Boiler Room - Equipment Room 004A	6/28/2022	0559	P	<1.00	N/A	N/A	
WLB-BS-TF-03	TF	Teacher's lounge sinks	014	6/28/2022	0601	P	2.49	P	<1.00	
WLB-01-WF-07	WF	Water fountain with filter & cooler	Corridor 101	6/28/2022	0612	P	<1.00	P	<1.00	
WLB-01-WFC-08	WFC	Filtering water cooler w/ bottle filler	Corridor 101	6/28/2022	0611	P	<1.00	P	<1.00	
WLB-01-WFC-17	WFC	Filtering water cooler w/ bottle filler	Corridor 122	6/28/2022	0619	P	<1.00	P	<1.00	
WLB-01-KF-20	KF	Kitchen faucets	Kitchen (118)	6/28/2022	0616	P	<1.00	P	<1.00	
WLB-01-CF-23	CF	Classroom faucets	139	6/28/2022	0604	P	2.14	P	<1.00	
WLB-01-WF-27	WF	Water fountain with filter & cooler	Corridor 101	9/13/2022	0628	P	<1.00	P	<1.00	
WLB-01-WO-28	WO	Water fountain without cooler	Corridor 101	6/28/2022	0606	P	2.53	P	4.19	
WLB-02-WF-33	WF	Water fountain with filter & cooler	Corridor 210	6/28/2022	0635	P	<1.00	P	<1.00	
WLB-02-WFC-34	WFC	Filtering water cooler w/ bottle filler	Corridor 210	6/28/2022	0636	P	<1.00	P	<1.00	
WLB-02-WO-41	WO	Water fountain with filter & cooler	Corridor 210	6/28/2022	0640	P	2.14	P	1.71	
WLB-02-WO-42	WO	Water fountain with filter & cooler	Corridor 210	6/28/2022	0641	P	1.87	P	1.69	
WLB-02-CF-46	CF	Classroom faucets	239	6/28/2022	0639	P	2.49	P	<1.00	
WLB-01-KF-47	KF	Kitchen faucets	Kitchen (118)	6/28/2022	0617	P	<1.00	P	<1.00	
WLB-01-CF-51	CF	Classroom faucets	141	6/28/2022	0610	P	2.26	P	<1.00	
WLB-BS-GF-52	GF	Filtered Glass Filler	014	6/28/2022	0600	P	<1.00	P	<1.00	
WLB-01-WF-53	WF	Water fountain with filter & cooler	Corridor 122	6/28/2022	0620	P	<1.00	P	<1.00	
WLB-01-GF-54	GF	Filtered Glass Filler	Corridor 122	6/28/2022	0621	P	<1.00	P	<1.00	
WLB-01-CF-55	CF	Classroom faucets	Art Room (126)	6/28/2022	0625	P	1.12	P	<1.00	
WLB-01-CF-56	CF	Classroom faucets	Art Room (126)	6/28/2022	0624	P	1.10	P	<1.00	
WLB-01-CF-57	CF	Classroom faucets	Music and Instrumental (127)	6/28/2022	0628	P	2.15	P	<1.00	
WLB-01-GF-58	GF	Filtered Glass Filler	Music and Instrumental (127)	6/28/2022	0627	P	<1.00	P	<1.00	
WLB-01-CF-59	CF	Classroom faucets	140	6/28/2022	0608	P	2.06	P	<1.00	
WLB-02-CF-63	CF	Classroom faucets	222	6/28/2022	0646	P	1.40	P	<1.00	
WLB-02-CF-64	CF	Classroom faucets	222	6/28/2022	0647	P	1.35	P	<1.00	
WLB-02-CF-65	CF	Classroom faucets	241	6/28/2022	0634	P	<1.00	P	<1.00	
WLB-02-GF-66	GF	Filtered Glass Filler	241	6/28/2022	0633	P	<1.00	P	<1.00	

Pittsburgh Westinghouse Academy 6-12

Lead in Drinking Water Sample Results

School: Pittsburgh Westinghouse Academy 6-12

Address: 1101 N. Murtland Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WES-BS-SL-00	SL	Service Line	921	4/14/2022	0743	P	<1.00	N/A	N/A	
WES-BS-WM-00	WM	Water Main	921	4/14/2022	0745	P	<1.00	N/A	N/A	
WES-BS-WF-01	WF	Water fountain with filter & cooler	Dining Area	4/14/2022	0742	P	<1.00	P	<1.00	
WES-BS-WFC-02	WFC	Filtering water cooler w/ bottle filler	Dining Area	4/14/2022	0746	P	<1.00	P	<1.00	
WES-BS-KF-05	KF	Kitchen faucets	Kitchen (935)	4/14/2022	0748	P	<1.00	P	<1.00	
WES-BS-KF-07	KF	Kitchen faucets	Kitchen (935)	4/14/2022	0750	P	<1.00	P	<1.00	
WES-BS-KF-08	KF	Kitchen faucets	Kitchen (935)	4/14/2022	0751	P	1.17	P	<1.00	
WES-BS-KF-09	KF	Kitchen faucets	Kitchen (935)	4/14/2022	0753	P	<1.00	P	<1.00	
WES-BS-WF-13	WF	Water fountain with filter & cooler	977	4/14/2022	0757	P	<1.00	P	<1.00	
WES-BS-IM-25	IM	Ice machines	976	4/14/2022	0758	P	<1.00	N/A	N/A	
WES-BS-WF-29	WF	Water fountain with filter & cooler	975	4/14/2022	0802	P	<1.00	P	<1.00	
WES-BS-WF-41	WF	Water fountain with filter & cooler	Corridor F	4/14/2022	0804	P	<1.00	P	<1.00	
WES-SB-MS-45	MS	Miscellaneous sinks	875B	4/14/2022	0816	P	1.08	P	<1.00	
WES-SB-WF-66	WF	Water fountain with filter & cooler	Pool (872)	4/14/2022	0824	P	<1.00	P	<1.00	
WES-SB-WF-67	WF	Water fountain with filter & cooler	Pool (872)	4/14/2022	0819	P	<1.00	P	<1.00	
WES-GF-WF-74	WF	Water fountain with filter & cooler	Corridor B	4/14/2022	0844	P	<1.00	P	<1.00	
WES-GF-WF-75	WF	Water fountain with filter & cooler	Corridor B	4/14/2022	0845	P	<1.00	P	<1.00	
WES-GF-CF-76	CF	Classroom faucets	11	4/14/2022	0847	P	2.05	P	<1.00	
WES-GF-MS-79	MS	Miscellaneous sinks	58N	4/14/2022	0849	P	<1.00	P	<1.00	
WES-GF-WF-80	WF	Water fountain with filter & cooler	Corridor B	4/14/2022	0838	P	<1.00	P	<1.00	
WES-GF-WF-81	WF	Water fountain with filter & cooler	Corridor B	4/14/2022	0839	P	<1.00	P	<1.00	
WES-GF-CF-82	CF	Classroom faucets	18	4/14/2022	0832	P	5.96	P	<1.00	
WES-GF-MS-83	MS	Miscellaneous sinks	18	4/14/2022	0835	P	<1.00	P	<1.00	
WES-GF-CF-102	CF	Classroom faucets	22	4/14/2022	0842	P	<1.00	P	<1.00	
WES-GF-NF-105	NF	Nurse's office sink faucets	046C	4/14/2022	0904	P	<1.00	P	<1.00	
WES-GF-NF-106	NF	Nurse's office sink faucets	046D	4/14/2022	0903	P	<1.00	P	<1.00	
WES-GF-NF-107	NF	Nurse's office sink faucets	046E	4/14/2022	0902	P	11.4	P	<1.00	
WES-GF-WC-114	WC	Water fountain with cooler	44	4/14/2022	0854	P	<1.00	P	<1.00	
WES-GF-WC-115	WC	Water fountain with cooler	44	4/14/2022	0855	P	<1.00	P	<1.00	
WES-GF-NF-117	NF	Nurse's office sink faucets	52D	4/14/2022	0909	P	3.63	P	<1.00	
WES-GF-NF-118	NF	Nurse's office sink faucets	52C	4/14/2022	0908	F	19.3	P	<1.00	Retested on 5/11/2022; Posted Hand Wash Only on 11/9/2022
WES-GF-WF-128	WF	Water fountain with filter & cooler	Corridor D	4/14/2022	0913	P	<1.00	P	<1.00	
WES-GF-WF-129	WF	Water fountain with filter & cooler	Corridor D	4/14/2022	0914	P	<1.00	P	<1.00	
WES-GF-WF-163	WF	Water fountain with filter & cooler	Gym	4/14/2022	0920	P	<1.00	P	<1.00	
WES-GF-WF-169	WF	Water fountain with filter & cooler	77	4/14/2022	0918	P	<1.00	P	<1.00	
WES-GF-WF-172	WF	Water fountain with filter & cooler	Gym	4/14/2022	0922	P	<1.00	P	<1.00	
WES-GF-WF-173	WF	Water fountain with filter & cooler	Lobby	4/14/2022	0946	P	<1.00	P	<1.00	
WES-GF-WFC-174	WFC	Filtering water cooler w/ bottle filler	Lobby	4/14/2022	0947	P	<1.00	P	<1.00	
WES-GF-MS-183	MS	Miscellaneous sinks	Concession Stand (67)	4/14/2022	0932	P	2.46	P	<1.00	
WES-GF-KF-185	KF	Kitchen faucets	Kitchen (69)	4/14/2022	0935	P	<1.00	P	<1.00	
WES-GF-KF-187	KF	Kitchen faucets	Kitchen (69)	4/14/2022	0936	P	1.49	P	<1.00	
WES-GF-KF-188	KF	Kitchen faucets	Kitchen (69)	4/14/2022	0938	P	1.49	P	<1.00	
WES-GF-KF-190	KF	Kitchen faucets	Kitchen (69)	4/14/2022	0941	P	<1.00	P	<1.00	
WES-GF-KF-191	KF	Kitchen faucets	Kitchen (69)	4/14/2022	0940	P	1.27	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Westinghouse Academy 6-12

Address: 1101 N. Murtland Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WES-GF-IM-192	IM	Ice machines	Kitchen (69)	4/14/2022	0942	P	<1.00	N/A	N/A	
WES-01-WF-198	WF	Water fountain with filter & cooler	Corridor B	4/14/2022	1020	P	<1.00	P	<1.00	
WES-01-WFC-199	WFC	Filtering water cooler w/ bottle filler	Corridor B	4/14/2022	1021	P	<1.00	P	<1.00	
WES-01-TF-205	TF	Teacher's lounge sinks	111	4/14/2022	1023	P	3.24	P	<1.00	
WES-01-CF-207	CF	Classroom faucets	125A	4/14/2022	1009	P	<1.00	P	<1.00	
WES-01-CF-208	CF	Classroom faucets	125A	4/14/2022	1010	P	3.95	P	<1.00	
WES-01-WF-209	WF	Water fountain with filter & cooler	125A	4/14/2022	1011	P	<1.00	P	<1.00	
WES-01-MS-212	MS	Miscellaneous sinks	125B	4/14/2022	1013	P	9.01	P	<1.00	
WES-01-WF-216	WF	Water fountain with filter & cooler	Corridor D	11/4/2022	0603	P	<1.00	P	<1.00	
WES-01-WF-217	WF	Water fountain with filter & cooler	Corridor D	11/4/2022	0605	P	<1.00	P	<1.00	
WES-01-WF-243	WF	Water fountain with filter & cooler	Choir Room (149)	4/14/2022	1032	P	<1.00	P	<1.00	
WES-01-WF-244	WF	Water fountain with filter & cooler	Band Room (147)	5/11/2022	0611	P	<1.00	P	<1.00	
WES-01-CF-245	CF	Classroom faucets	Band Room (147)	4/14/2022	1036	P	1.33	P	<1.00	
WES-01-CF-246	CF	Classroom faucets	168	4/14/2022	1042	P	<1.00	P	<1.00	
WES-02-CF-273	CF	Classroom faucets	242							Posted Hand Wash Only
WES-02-CF-274	CF	Classroom faucets	235							Posted Hand Wash Only
WES-02-WF-284	WF	Water fountain with filter & cooler	Corridor D	4/14/2022	1056	P	<1.00	P	<1.00	
WES-02-WFC-285	WFC	Filtering water cooler w/ bottle filler	Corridor D	4/14/2022	1057	P	<1.00	P	<1.00	
WES-03-WF-316	WF	Water fountain with filter & cooler	Corridor B	4/14/2022	1103	P	<1.00	P	<1.00	
WES-03-CF-318	CF	Classroom faucets	346	4/14/2022	1113	P	4.09	P	<1.00	
WES-03-WF-319	WF	Water fountain with filter & cooler	Corridor D	4/14/2022	1115	P	<1.00	P	<1.00	
WES-03-WFC-320	WFC	Filtering water cooler w/ bottle filler	Corridor D	4/14/2022	1116	P	<1.00	P	<1.00	
WES-03-CF-327	CF	Classroom faucets	312	4/14/2022	1106	P	3.25	P	<1.00	
WES-03-CF-328	CF	Classroom faucets	312							Cold Water Not in Operation
WES-02-WF-330	WF	Water fountain with filter & cooler	Corridor B	4/14/2022	1050	P	<1.00	P	<1.00	
WES-01-WF-332	WF	Water fountain with filter & cooler	125E	4/14/2022	1015	P	<1.00	P	<1.00	
WES-01-CF-333	CF	Classroom faucets	125E	4/14/2022	1017	P	4.04	P	<1.00	
WES-02-CF-336	CF	Classroom faucets	235							Posted Hand Wash Only
WES-02-CF-337	CF	Classroom faucets	235							Posted Hand Wash Only
WES-03-CF-338	CF	Classroom faucets	312	4/14/2022	1107	P	4.11	P	<1.00	
WES-03-CF-339	CF	Classroom faucets	312	4/14/2022	1109	P	13.3	P	<1.00	
WES-GF-CF-340	CF	Classroom faucets	18	4/14/2022	0833	P	3.04	P	<1.00	
WES-GF-CF-341	CF	Classroom faucets	18	4/14/2022	0834	P	3.70	P	<1.00	
WES-BS-WF-343	WF	Water fountain with filter & cooler	Auxiliary Gym (982)	4/14/2022	0808	P	<1.00	P	<1.00	
WES-BS-WFC-344	WFC	Filtering water cooler w/ bottle filler	Auxiliary Gym (982)	4/14/2022	0809	P	<1.00	P	<1.00	
WES-BS-WF-345	WF	Water fountain with filter & cooler	Auxiliary Gym (982B)	4/14/2022	0811	P	<1.00	P	<1.00	
WES-BS-WFC-346	WFC	Filtering water cooler w/ bottle filler	Auxiliary Gym (982B)	4/14/2022	0812	P	<1.00	P	<1.00	
WES-SB-WF-349	WF	Water fountain with filter & cooler	Pool (872)	4/14/2022	0822	P	<1.00	P	<1.00	
WES-SB-WF-350	WF	Water fountain with filter & cooler	Pool (872)	4/14/2022	0820	P	<1.00	P	<1.00	
WES-GF-WF-352	WF	Water fountain with filter & cooler	41	5/11/2022	0607	P	<1.00	P	<1.00	
WES-GF-WF-353	WF	Water fountain with filter & cooler	45	4/14/2022	0859	P	<1.00	P	<1.00	
WES-01-WF-354	WF	Water fountain with filter & cooler	Choir Room (149)	4/14/2022	1033	P	<1.00	P	<1.00	
WES-01-MS-355	MS	Miscellaneous sinks	Library (142A)	4/14/2022	1029	P	7.64	P	<1.00	
WES-02-CF-357	CF	Classroom faucets	228	4/14/2022	1053	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Westinghouse Academy 6-12

Address: 1101 N. Murtland Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WES-02-CF-358	CF	Classroom faucets	242	4/14/2022						Posted Hand Wash Only
WES-02-CF-359	CF	Classroom faucets	242	4/14/2022						Posted Hand Wash Only
WES-GF-GF-377	GF	Filtered Glass Filler	52D	4/14/2022	0911	P	<1.00	P	<1.00	

Pittsburgh Westinghouse Field House

Lead in Drinking Water Sample Results

School: Pittsburgh Westinghouse Field House

Address: 1102 North Murtland Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Locations	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WFH-GF-SL-00	SL	Service Line	Mechanical Room	4/14/2022	0721	P	<1.00	N/A	N/A	
WFH-GF-WM-00	WM	Water Main	Mechanical Room	4/14/2022	0724	P	<1.00	N/A	N/A	
WFH-GF-MS-01	MS	Miscellaneous sinks	Mechanical Room	4/14/2022	0720	P	<1.00	P	<1.00	
WFH-GF-IM-02	IM	Ice machines	Mechanical Room							Not in Operation - No Ice
WFH-GF-MS-03	MS	Miscellaneous sinks	Office	4/14/2022	0727	P	<1.00	P	<1.00	
WFH-GF-MS-09	MS	Miscellaneous sinks	Concession Room	4/14/2022	0728	P	1.86	P	<1.00	
WFH-GF-MS-10	MS	Miscellaneous sinks	Concession Room	4/14/2022	0729	P	5.80	P	<1.00	